

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
BENEFICIAL USE FIELD REPORT

A. GENERAL INFORMATION

Permit No: 95-9408

Exam Date: 11/19/2008

1. Current Owner: KIRK HILL
6430 E MAPLEWOOD AVE
POST FALLS ID 83854
(208)777-0233

Or

SALLIE HILL
6430 E MAPLEWOOD AVE
POST FALLS ID 83854
(208)777-0233

2. Accompanied by: OWNER

Phone No: SAME

Address: SAME

Relationship to Permit Holder:

3. SOURCE

SPOKANE RIVER

TRIBUTARY

COLUMBIA RIVER

B. OVERLAP REVIEW

1. Other water rights with the same place of use: *none*
2. Other water rights with the same point of diversion: *95-9409*

C. DIVERSION AND DELIVERY SYSTEM**1. LOCATION OF POINT(S) OF DIVERSION:**

SPOKANE RIVER

L2 NE1/4NW1/4

Sec. 8, Twp 50N, Rge 04W, B.M.

KOOTENAI County

Method of Determination: MAP

2.

PLACE OF USE: IRRIGATION

Twp Rge Sec	NE				NW				SW				SE				Totals
	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
50N 04W 8					2.5												2.5
					L 2												

Total Acres: 2.5

Method of Determination:

3. ☒ Delivery System Diagram Attached (required). Indicate all major components and distances between components. Indicate weir size/pipe as applicable.
- ☒ Map Attached Showing Location(s) of point(s) of diversion and place(s) of use (required). Scale must be 1:24,000 or greater.
- ☒ Aerial Photo Attached (required for irrigation of 10+ acres).
- ☒ Photo of Diversion and System Attached

4.

<u>Well or Diversion ID No.*</u>	<u>Motor Make</u>	<u>Hp</u>	<u>Motor Serial No.</u>	<u>Pump Make</u>	<u>Pump Serial No. or Discharge Size</u>
	Grundfos	5	U/K	Grundfos	60530-56P

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

<u>Measurement Equipment</u>	<u>Type</u>	<u>Make</u>	<u>Model No.</u>	<u>Serial No.</u>	<u>Size</u>	<u>Calib. Date</u>

2. Measurements:

E. FLOW CALCULATIONS

____ Additional Computation Sheets Attached

Measured Method:

PUMP EQUATIONS WATER RIGHT No.						
		HP	H in feet	Efficiency as a decimal	Pumping lift in feet	System pressure in PSI
Q	=	5	254.0816327	0.75	150	45
HP*8.8*Eff/H						
Q	=	0.130 cfs				
		58.4 gpm				

F. VOLUME CALCULATIONS**1. Volume Calculations for Irrigation:**

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) = 2.5 \text{ ac} \times 3 \text{ AF} = 7.5 \text{ AF}$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation season}) \times 1.9835 = 0.13 \text{ cfs} \times 246 \text{ days} \times 1.9835 = 63.4$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} = 7.5 \text{ AF}$$

2. Volume Calculations for Other Uses:**G. NARRATIVE/REMARKS/COMMENTS: This is a good system.**

Have conditions of permit approval been met? ☒ Yes ☐ No

H. RECOMMENDATIONS**1. Recommended Amounts**

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>DIVERSION RATE</u>	<u>ANNUAL VOLUME</u>
IRRIGATION	03/15 to 11/15	0.080 CFS	7.50 AF
<u>Totals:</u>		0.080 CFS	7.50 AF

2. Recommended Amendments

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☒ None

☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☐ Other

I. AUTHENTICATION

Field Examiner's Name Eric R. [Signature] Date 11-19-2008

Reviewer [Signature] Date 11/20/8

95-9408



0 105 210 420 630 840 Feet

Legend




SYSTEM DIAGRAM



0 105 210 420 630 840 Feet

Legend





POD.JPG



POU.JPG



POU1.JPG



System.JPG

95-9408



95-9405





95-9408

