


3. **Delivery System Diagram.** Indicate all major components and distances between components. Indicate weir size/ditch size/pipe I.D. as applicable.



Scale: 1" = _____

____ Copy of USGS Quadrangle Attached Showing location(s) of point(s) of diversion and place(s) of use (required).

____ Aerial Photo Attached (required for irrigation of 10+ acres)

____ Photo of Diversion and System Attached

4.

Well or Diversion Identification No.*	Motor Make	Hp	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size
	Franklin	5	2821138110	Sob	2"

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date

2. Measurements: _____

This image shows a single sheet of white paper with horizontal ruling lines. The lines are evenly spaced and run across the width of the page. There are no margins, text, or other markings on the paper.

Have conditions of permit approval been met? ✓ yes no

F. FLOW CALCULATIONS

Measured Method:

Additional Computation Sheets Attached

Theoretical

$$\frac{8.8(5)(.9)}{400 + (2.31 \times 30)} = \frac{39.6}{529.3} = .0748 = .08$$

.088 = .09

G. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation:

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) = 3 \times 3 = 9$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation Season}) \times 1.9835 = .06 \times 245 \times 1.9835 = 29.1$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} = 9$$

2. Volume Calculations for Other Uses:

H. RECOMMENDATIONS

1. Recommended Amounts

Beneficial Use	Period of Use		Rate of Diversion Q (cfs)	Annual Volume V (afa)
	From	To		
<i>Domestic</i>	<i>01-01</i>	<i>12-31</i>	<i>.04</i>	<i>.6</i>
<i>Irrigation</i>	<i>03-15</i>	<i>11-15</i>	<i>.06</i>	<i>9</i>
Totals:			<i>.09</i>	<i>9.6</i>

2. Recommended Amendments

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☐ None
☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☐ Other

I. AUTHENTICATION

Field Examiner's Name *Wayne Caldwell* Date *9-30-08*

Reviewer *[Signature]* Date *11/3/8*

SEAL



Pod



Pod
Domestic



Pod
FRR



Inside
Pump House



Pou IRR



Pou IRR

96-9119



Legend

- ⊙ Right POD
-  Right POU

0 37.5 75 150 225 300 Feet

