



STATE OF IDAHO
DEPARTMENT OF
ENVIRONMENTAL QUALITY

444 Hospital Way, #300 • Pocatello, Idaho 83201 • (208) 236-6160

C.L. "Butch" Otter, Governor
Toni Hardesty, Director

September 30, 2008

Doug Johnson
Bear Lake Group, LLC
P.O. Box 473
Garden City, UT 84028

RECEIVED
OCT 03 2008
Department of Water Resources
Eastern Region

Re: Canyon Estates Well House and Booster Station
Fish Haven – Bear Lake County
DEQ # 04-08-11

Dear Mr. Johnson:

We have reviewed the revised plans and specifications submitted by your consultant for the referenced project. The plans and specifications appear to meet state standards and are hereby **approved**, with the following comment:

- Installing individual flow meters on all source and booster pumps would provide a helpful tool in operation and maintenance of the water system, and therefore the Department recommends that they be included in the design.

Our approval is for design only. The standard conditions on the DEQ review stamp are part of this approval. Any supporting reports or documents are considered to be part of the approved documents.

Final project approval will be given after it is established that the systems are operating properly. Deviations from the approved plans and specifications that might result in violation of Idaho Regulations must be reviewed by this office prior to field installation. This office must be kept informed of the scheduling of all construction phases so that spot inspections can be made as necessary. Two copies of the approved plans and specifications are being sent to your consultant, one of which is to be placed on the job during construction

This approval will expire **September 30, 2009**. If construction has not commenced by the expiration date, plans will need to be resubmitted for approval before further construction proceeds.

The approval of the design is conditioned upon you providing to the Department, within 30 days after the completion of construction, plans and specifications prepared and stamped by the Idaho registered professional engineer responsible for supervision of construction observation on your behalf depicting the significant deviations in the actual construction, alteration, or modification

Doug Johnson
September 30, 2008
Page 2

performed, based on as-built drawings provided by the contractor and through field observations made by the professional engineer or observers under the direction of the professional engineer. Please call me with any questions at (208) 236-6160 or contact me via e-mail at chuck.ketterman@deq.idaho.gov.

Sincerely,

Charles R. Ketterman, P.E.
Water Quality Engineer

sg

cc: Tom Hepworth – DEQ – PRO (e-mail)
Barbara Jones – DEQ – PRO (e-mail)
Michael Stambulis, P.E. – DEQ – Boise
Mitchell Greer, P.E. – RMES – Pocatello (enclosure – 2 copies)
Evan Love, President – Canyon Estates POA
Dennis Dunn – IDWR – Idaho Falls
Alex Hudson, P.E. – A.A. Hudson & Associates – Preston
Tom Wood, P.G. – Clearwater Geosciences – Idaho Falls
DEQ File #04-08-11