


[illegible]

3. **Delivery System Diagram:** Indicate all major components and distances between components. Indicate well size/ditch size/pipe I.D. as applicable



Scale: 1" = _____

____ Copy of USGS Quadrangle Attached Showing location(s) of point(s) of diversion and place(s) of use (required).

____ Aerial Photo Attached (required for irrigation of 10+ acres)

____ Photo of Diversion and System Attached

4.

Well or Diversion Identification No.*	Motor Make	Hp	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size
	Central Machine	75		Central Machine	5/8"

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date

2. Measurements: _____

This image shows a single sheet of white paper with horizontal ruling lines. The lines are evenly spaced and run across the width of the page. There are no margins, text, or other markings on the paper.

Have conditions of permit approval been met? ✓ yes ___ no

F. FLOW CALCULATIONS

Measured Method:

Additional Computation Sheets Attached

5 gal bucket

5 gal in 60 sec = 5 gpm

$$\frac{5 \times 0.133681}{60} = .01 \text{ cfs}$$

G. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation:

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) = .3 \times 3 = .9$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation Season}) \times 1.9835 = .01 \times 213 \times 1.9835 = 4.2$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} = .9$$

2. Volume Calculations for Other Uses:

IRR AREA

$$\frac{100 \times 125}{43560} = 0.286 = .3 \text{ ACRES}$$

H. RECOMMENDATIONS

1. Recommended Amounts

Beneficial Use	Period of Use		Rate of Diversion Q (cfs)	Annual Volume V (afa)
	From	To		
Irrigation	04-01	10-31	.01	.9
Totals:			.01	.9

2. Recommended Amendments

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☐ None
☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☐ Other

I. AUTHENTICATION

Field Examiner's Name Wayne Baldwin Date 8-13-08

Reviewer Ethel Ball Date 8/26/08

SEAL



004



place of use




pod 96-9193



pump

96-9193





96-9193



0 10 20 40 60 80
Meters

Legend

- QQ
- Right POD
- Sections

