

Miller, Nick

From: Miller, Nick
Sent: Tuesday, July 01, 2008 12:31 PM
To: Merritt, Allen
Subject: Permits 71-7178 and 71-7179

Attachments: BROWN_LEEPMT.pdf

Allen,

While I was up in Stanley last week, I met with Jack Brown about measurement and control of the above-referenced permits. I GPS'd the well and reviewed the system and I found two items that I think should be reviewed or changed with the permits.

1. The well was GPS'd by both me and well drilling and is located in the SESE, not in the SWSE as shown on the permit.
2. It looks like permit 71-7178 is for onstream storage from Lost Creek. However, water is actually diverted from the north channel and conveyed down a pipe to the ponds, while water from the south channel (and any groundwater that is pumped under 71-7179) remains, as far as I could see, in the natural channel to the ponds. I know it is a little atypical, since both channels ultimately sink before reaching the river, so maybe it's OK to call it onstream storage, but I thought I'd mention it to you.

I'll put a copy of this email and the attached map in the file.

Nick Miller, P.E.
Staff Engineer
Water Distribution Section
Idaho Department of Water Resources
322E. Front St. Boise, ID 83720-0098
208-287-4956 (Office)
208-287-6700 (Fax)



BROWN_LEEPMT.p
df (557 KB)

