

State of Idaho
Department of Water Resources
Permit to Appropriate Water

NO. 95-09484

Priority: May 05, 2008

Maximum Diversion Rate: 2.00 CFS

This is to certify, that KOOTENAI MEDICAL CENTER
2003 LINCOLN WAY
COEUR D ALENE ID 83814

has applied for a permit to appropriate water from:

Source: GROUND WATER

and a permit is APPROVED for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>
COOLING	01/01 to 12/31	2.00 CFS
HEATING	01/01 to 12/31	2.00 CFS

LOCATION OF POINT(S) OF DIVERSION:

GROUND WATER SW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 11, Twp 50N, Rge 04W, B.M. KOOTENAI County

GROUND WATER SW $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 11, Twp 50N, Rge 04W, B.M. KOOTENAI County


PLACE OF USE: HEATING AND COOLING

Twp	Rge	Sec	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	Totals
50N	04W	11			X										
					L 2										

CONDITIONS OF APPROVAL

1. Proof of application of water to beneficial use shall be submitted on or before **August 01, 2010**.
2. Subject to all prior water rights.
3. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
4. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
5. This right does not grant any right-of-way or easement across the land of another.
6. This right authorizes the diversion of ground water within the Rathdrum Prairie Ground Water Management Area (RPGWMA). Use of water under this right shall be subject to the provisions of the management plan approved by the director for the RPGWMA.
7. When notified by the Department, the right holder shall record the quantity of water diverted and annually report diversions of water and/or other pertinent hydrologic and system information as required by Section 42-701, Idaho Code, and/or the management plan for the Rathdrum Prairie Ground Water Management Area.
8. When notified by the Department, the right holder shall install and maintain a measuring device of a type acceptable to the Department as part of the diverting works.
9. Return flow discharged to a subsurface system must be authorized by a separate injection well permit.

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code. Witness the signature of the Director, affixed at Coeur d'Alene, this 13th day of August, 2008.


DAVID R. TUTHILL, JR., Director