

LICENSE REVIEW CHECKLIST

PERMIT NO 63-10604A DATE 3-28-1994



NAME	Yes ☒	No ☐	MIKE + JUDITH McShane Or Address Change? NO ASSIGNMENT
PRIORITY DATE	☒	☐	Advance? <u>YES</u> Advanced to: <u>APRIL 18, '88</u> Order to reinstate needed? <u>DONE</u> Incorrect fee for rate recommended? <u>NO</u>
SOURCE	☐	☒	Changes or just clarification of originally intended source? _____ Notice of Intent to Void necessary? _____
POINT OF DIV	☐	☒	Amendment needed? _____ Overlaps? _____
PLACE OF USE	☐	☒	Amendment needed? _____ Overlaps? _____
DIV RATE	☐	☒	Measurement done? <u>NONE</u> Theoretical only? ☒ <u>IRR 4 acres = .03</u> DOM HEATING = .03 <u>DOMESTIC = .03</u> DOM COOLING = .01 cfs Capacity: <u>.16</u> Combined rates exceed capacity _____ Allowable amount: _____
P/O #1 CAPACITY Pump A = .13 Pump B = .03			
ANNUAL VOLUME	☐	☒	Season of use: <u>0/4.5</u> 3-15 to 11-15 Calculations: <u>IRR@4.5=18 (allow 14.6)</u> <u>HEAT= 8.2 COOL=.5 INT DOM=.6</u> Flow limit: <u>.03</u> x <u>246</u> cfs x 1.9835 = <u>14.6</u> Combined volumes exceed capacity/allowable _____
USES	☐	☒	Change(s) in Nature of Use? _____ Amendment necessary? _____
REMARKS	<u>WB3</u>	☒	Multiple p/d(s) in 1/4 1/4? _____ Other <u>BOISE-KUNA IRRIGATION DISTRICT</u>
CONDITIONS	<u>R32</u>	☒	Measuring/Locking Devices _____ Watermaster control - District _____ Irrigation Overlap _____ Water Quality _____ Other <u>004</u> _____

COMMENTS: Pump A irrigates acres on 63-10604B also - Combined do not exceed capacity.
Pump B is for domestic, heating, + cooling - can't exceed .03 cfs

RECOMMENDED	CFS	VOLUME	LICENSE ☒
<u>Irrigation</u>	<u>.03</u>	<u>14.6</u>	
<u>Domestic</u>	<u>.03</u>	<u>.6</u>	1ST AMENDMENT LETTER _____
<u>HEATING</u>	<u>.03</u>	<u>8.2</u>	
<u>COOLING</u>	<u>.01</u>	<u>.5</u>	FINAL AMENDMENT LETTER _____
<u>TOTALS</u>	<u>.06</u>	<u>23.9</u>	