



State of Idaho

DEPARTMENT OF WATER RESOURCES

Western Region, 2735 Airport Way • Boise, Idaho 83705-5082

Phone: (208) 334-2190 • Fax: (208) 334-2348 • Web Site: www.idwr.idaho.gov

C. L. "BUTCH" OTTER
Governor

DAVID R. TUTHILL, JR.
Director

May 28, 2008

Greg Graybadger
PO Box 7942
Boise ID 83707

RE: Final Approval of Application 63-12089

Dear Mr. Graybadger:

Our office has received your response form stating a "yes" for continued processing of your ground water application. Your permit is ready for approval and mailing.

A review of your application reveals your proposed ground water well diversion is located in Township 5N, Range 01E, Section 29. The application also listed a water bearing zone of 150- 300 ft.

Ground water less than 200 feet depth is considered tributary to the Boise River at your proposed well location. Surface water in or tributary to the Boise River above Star bridge is fully appropriated. This means that a new appropriation of ground water would potentially injure a senior Boise River surface water right. Our agency can not approve your application unless the well water bearing zone is greater than 200 ft. or an acceptable mitigation plan is filed to mitigate injury to senior surface water rights.

A review of your existing domestic well log reveals a water bearing zone of 234 to 244 ft, see attached. If you intend to utilize your existing domestic well as the water source for this permit, you meet the requirement. *Please contact this office to convey your plans regarding the water source under the application.* Other options can certainly be discussed.

If a response is not received within 30 days, our office will consider voiding the application.

Please contact me at the Western Regional Office, phone 334-2190.

Sincerely,

A handwritten signature in black ink, appearing to read 'John Westra', is written over a horizontal line.

John Westra, Manager

Enclosure: Graybadger Well log 63-97-W-0277