



STATE OF IDAHO
DEPARTMENT OF
ENVIRONMENTAL QUALITY

444 Hospital Way, #300 • Pocatello, Idaho 83201 • (208) 236-6160

C.L. "Butch" Otter, Governor
Toni Hardesty, Director

Sharla Cox, Administrative Assistant
Idaho Department of Water Resources
900 N. Skyline Dr., Suite A
Idaho Falls, ID 83402-1718

RECEIVED May 6, 2008

MAY 08 2008

Department of Water Resources
Eastern Region

RE: Application to Permit No. 11-7436

Dear Ms. Cox,

The Idaho Department of Environmental Quality (Department) has reviewed the information provided regarding the subject application and we are offering the following comments.

The application appears to be for a water supply right intended to serve a municipal water supply that may be considered a public water system according to IDAPA 58.01.08, "Idaho Rules for Public Drinking Water System. In accordance with Idaho Code 39-118, construction plans & specifications prepared by a professional engineer are required for DEQ review and approval prior to construction if the water supply is for a public water system.

The Department requires a public drinking water system to be constructed and operated in compliance with the drinking water rules.

If you have questions or comments, please contact me at 236-6160 or via email at tom.hepworth@deq.idaho.gov.

Sincerely,

Tom Hepworth
Engineering Regional Manager

Route file copy: Bruce Olenick, Regional Administrator, Pocatello Regional Office

File: Land Development, Bear Lake County