



STATE OF IDAHO
DEPARTMENT OF
ENVIRONMENTAL QUALITY

444 Hospital Way, #300 • Pocatello, Idaho 83201 • (208) 236-6160

C.L. "Butch" Otter, Governor
Toni Hardesty, Director

RECEIVED

FEB 29 2008

Sharla Cox, Administrative Assistant
Idaho Department of Water Resources
900 N. Skyline Dr., Suite A
Idaho Falls, ID 83402-1718

Department of Water Resources
Eastern Region

February 26, 2008

RE: Application to Permit No. 15-7299, City of Malad Public Water Supply Well

Dear Ms. Cox,

The Idaho Department of Environmental Quality (IDEQ) has reviewed the information provided regarding the subject application and we are offering the following comments.

In accordance with Idaho Code 39-118, construction plans & specifications prepared by a professional engineer are required for IDEQ review and approval prior to construction if the water supply is for a public water system. A water system serving 10 or more connections must be designed, constructed and operated in compliance with IDAPA 58.01.08, "Idaho Rules for Public Drinking Water Systems."

If you have questions or comments, please contact me at 236-6160 or via email at tom.hepworth@deq.idaho.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Tom Hepworth".

Tom Hepworth
Engineering Regional Manager

Route file copy: Bruce Olenick, Regional Administrator, Pocatello Regional Office

File: Drinking Water, City of Malad, Correspondence 2008