

5 February 2008

Memo: To the File, Tallboy LLC, 22-13800

Re: Well Proximity to Sewer Line

On 5 February 2008 I was notified by Roger Warner (Rocky Mountain Environmental) that two wells they had proposed to drill would be seven feet or less from the community sewer line in Driggs. One is a production well the second an injection well for heat pump use.

The minimum distance from a sewer line a well may be placed is 50 feet. Roger said they cannot meet that distance.

I spoke with Brian Patton and Thomas Neace in Boise. The injection well application will be held until the water right application is approved.

The water right application for Tall Boy LLC should not be approved until the applicant obtains sufficient property to allow for the 50 feet of required offset from the sewer line.

Dennis M. Dunn

21, March 2008

The City of Driggs has agreed to allow Tallboy LLC to drill their well on the City owned parking lot twenty seven feet west of the proposed project. This with enhanced drilling and sealing requirements should provide sufficient protection for the well.

The applicant is required to provide a minimum of four inches annular space around the well casing, centralize the casing, and pressure grout from fifty eight feet to land surface.

The City, DEQ, and Water Resources are in agreement with the proposed plan and well design.

Water Right 22-13800 may be approved. Dennis M. Dunn *DMD*

*well
construction
requirements.*

5 February 2008

DMD

Memo: To the File, Tallboy LLC, 22-13800

Re: Well Proximity to Sewer Line

On 5 February 2008 I was notified by Roger Warner (Rocky Mountain Environmental) that two wells they had proposed to drill would be seven feet or less from the community sewer line in Driggs. One is a production well the second an injection well for heat pump use.

The minimum distance from a sewer line a well may be placed is 50 feet. Roger said they cannot meet that distance.

I spoke with Brian Patton and Thomas Neace in Boise. The injection well application will be held until the water right application is approved.

The water right application for Tall Boy LLC should not be approved until the applicant obtains sufficient property to allow for the 50 feet of required offset from the sewer line.

Dennis M. Dunn



