



STATE OF IDAHO
DEPARTMENT OF
ENVIRONMENTAL QUALITY

444 Hospital Way, #300 • Pocatello, Idaho 83201 • (208) 236-6160

RECEIVED

FEB 12 2008

Department of Water Resources
Eastern Region

C.L. "Butch" Otter, Governor
Toni Hardesty, Director

Sharla Cox, Administrative Assistant
Idaho Department of Water Resources
900 N. Skyline Dr., Suite A
Idaho Falls, ID 83402-1718

February 8, 2008

RE: Application to Permit Nos. 27-12163 and 35-13701

Dear Ms. Cox,

The Idaho Department of Environmental Quality (Department) has reviewed the information provided regarding the subject application and we are offering the following comments.

Both applications appear to be for water supply rights intended to serve public water systems. In accordance with Idaho Code 39-118, construction plans & specifications prepared by a professional engineer are required for DEQ review and approval prior to construction if the water supply is for a public water system. The Department requires that a water system serving 10 or more connections is constructed and operated in compliance with IDAPA 58.01.08, "Idaho Rules for Public Drinking Water Systems.

If you have questions or comments, please contact me at 236-6160 or via email at tom.hepworth@deq.idaho.gov.

Sincerely,

A handwritten signature in black ink that reads "Tom Hepworth".

Tom Hepworth
Engineering Regional Manager

Route file copy: Bruce Olenick, Regional Administrator, Pocatello Regional Office

File: Land Development, Bingham County