

23-7123~HUSKEY

Q CALCS

DEMANDS: 1 DOMESTIC HOME 0.02 CFS

COMMERCIAL STORE 0.02 CFS

↳ 3 SINKS, 2 TOILETS, FIREWAKE, 1 DRINK FNT. = 9.5 FU $\approx$ 9.5 GPM

RV SPACES (15) 0.23 CFS

↳ AVG RV 2 SINKS, 1 SHOWER, 1 TOILET = 7 F.U./EA; 1 FU $\approx$ 1 GPM $\therefore$ 105 GPM

LAUNDROMAT (2 WASHERS) 0.05 CFS

↳ 10 FU/EA.; 1 FU $\approx$ 1 GPM $\therefore$ 20 GPM $\approx$ 0.05 CFS

+

TOTAL 0.32 CFS

(REASONABLE ANTICIPATED PEAK DEMAND)

APPLICATION & PERMIT ASK FOR 0.04 CFS

RECOMMEND 0.04 CFS

† CALCS

CONCUR W/ FIELD EXAM.