



RECEIVED

FEB 04 2008

DEPARTMENT OF
WATER RESOURCES

J-U-B ENGINEERS, Inc.
ENGINEERS • SURVEYORS • PLANNERS

1630 23rd Avenue, Suite 1101-A
Lewiston, ID 83501

208-746-9010
Fax: 208-746-9926
www.jub.com

January 29, 2008

Idaho Department of Water Resources
Water Allocation Bureau
Attn: Deborah Gibson
PO Box 83720
Boise, ID 83720-0098

RE: Lewiston Orchards Irrigation District's Water Right #85-15356

Dear Ms. Gibson:

Thank you for your assistance in trying to resolve the outstanding issues with Lewiston Orchards Irrigation District's (LOID) Water Right #85-15356.

Per our discussion yesterday, I have contacted Keith Franklin with IDWR in Coeur d'Alene to begin the water rights transfer from the District's now dormant Well No. 1 (Water Right License 85-7146) to be included on Well No. 4. LOID's Well No. 4 draws approximately 1200 gpm (2.68 cfs) of groundwater. Since license No. 85-7146 only allows for 1.34 cfs diversion, LOID still need 1.34 cfs additional diversion rights under license # 85-15356.

You indicated that license #85-15356 could be reinstated if LOID provided evidence that they had diverted groundwater under their permit prior to August 1, 2006. I have attached a printout from LOID's records that demonstrate that Well No. 4 was pumping water to the District's distribution system on a regular basis from June 17, 2006 through August 6, 2006. This is only a snapshot of their production record, and if more time is needed, we can provide additional records.

It is my understanding that the Water Rights Permit #85-15356 can be reinstated with this information. If additional information is needed, please contact me at 208-746-9010.

Sincerely,


J-U-B ENGINEERS, Inc.

Cory R. Baune, PE
Project Engineer

cc: Barney Metz
File-21-07-001-010



Well4History



Legend	Trend Name	Comment	Min.	Max.	Avg.	Min. Scale	Max. Scale	Eng. Units
	Well4Flow2	10min. samples of domestic flow from Well 4	-1.516	1164	601.1	-1000	2000	gal/min
	Well4Pressure2	10min. samples of discharge pressure from Well 4	4.000	9.000	6.756	0.000	200.0	lbs
	Well4DischargeTemp2	10min. samples of Discharge Temp. from Well 4	77.27	90.8	81.72	50.00	150.0	ft
	Well4Head2	10min. samples of well head level from Well 4	n/a	n/a	n/a	0.000	18.20	ft