

M E M O R A N D U M

Date: January 30, 2008
To: Water Right File 63-12543
From: Aaron Marshall
Re: Licensing Review

Based on my January 28, 2008, telephone conversation with Kevin Boggs, the City of Nampa plans to drill a replacement well for this water right when licensed. Well 16 will replace Well 13 in the same 40 acre tract.

Well 16 will divert water from the same source as permitted and developed using Well 13. The permitted water bearing zone is from 300 to 500 feet below ground surface (bgs). Well 13 was screened at its lowest point 516 bgs. Based on evidence provided by the field examiner, this appears to be within the permitted aquifer and is not a separate source.

Well 16 will be screened in sections between 400 and 510 feet bgs which will remain consistent with the permitted source.