

Item No. 5: This quantity must be the same as in Item No. 4.

Item No. 6: (a) Please include some additional information regarding the delivery system, such as whether a sprinkler system is used. (c) If you have well information, please include it (d) this question regarding the temperature of the water must be answered for IDWR to process this application.

Item No. 7: Even though the well already exists, this question regarding the completion time needed must be answered for IDWR to process this application. As the application states, the minimum time is 1 year.

Item No. 9: (b) Your application lists 12 acres to be irrigated, however, a handwritten note from Gerald K. Myers, Director, was attached to the application. The note states, "The parcel of land is 7.7 acres instead of 7.1. My mistake Thank you". Because The District has a license for 4.5 acres of irrigation under 67-2234, I assumed the note intended for the Application to provide irrigation for the remaining 7.5 acres. If this is correct, the three places in this item that asks for acres should be 7.5.

Item No. 10: Please put the water right number for the overlapping water right 67-2234 here.

Please fill out the Amended Application for Permit and return in the enclosed envelope to my attention. I can be reached at 208-334-2190. Thank you for your attention to these matters.

Please submit the requested information for application processing to continue. You may seek additional time to provide the information by making a written request to interrupt processing for up to six months. Your response including the requested information or a request for more time to seek the information must be received within the next ninety (90) days. The application will be voided with out a timely written reply.

Sincerely,



Vicky Muste
Sr. Water Resource Agent

Enclosure: copy of original Application for Permit; Amended Application for Permit form



State of Idaho

DEPARTMENT OF WATER RESOURCES

Western Region, 2735 Airport Way, Boise, Idaho 83705-5082

PHONE: (208) 334-2190 FAX: (208) 334-2348 www.idwr.idaho.gov

C.L. "BUTCH" OTTER, Governor
DAVID R. TUTHILL, JR., Director

September 7, 2007

Midvale Maintenance Cemetery District
2376 Valley Rd.
Midvale, ID 83645

Re: Application for Permit

Dear Midvale Maintenance Cemetery District:

On December 19, 2006, the Midvale Maintenance Cemetery District submitted an Application for Permit for the irrigation of 7.7 acres from an existing well. There are some deficiencies with the application and it needs to be amended before IDWR can process it.

I have enclosed a copy of the Application the District submitted. The items that must be completed or amended are highlighted in blue. I have also enclosed a new blank Application for you to complete with the correct information.

Here is a list of the items and how and why the times must be changed. The numbers refer to the numbers on the Application.

Item No. 3: The District described the location of the point of diversion to the 10-acre quarter-quarter-quarter. IDWR only requires that the point of diversion be described to the 40-acre quarter-quarter. The advantage to the District in describing it to the 40-acre quarter-quarter is that if the well needs to be replaced and relocated within the 40 acres, it could be done without filing a transfer with IDWR. If it is described to the 10-acre and the well is relocated out of the 10-acres then a transfer must be filed with IDWR. Hence, the highlighted "NE" can be omitted and the description limited to the "SESW".

Item No. 4: The District listed a quantity of 0.09 cfs for irrigation and a season of use from 1/1 to 12/31. Although IDWR will process the application for a quantity of 0.09 cfs if that is what the District wishes, it is less than the maximum 0.02 cfs/acre that is the standard. The District stated that the parcel is 12 acres. There is already a licensed right no. 67-2234 for 4.5 acres. It appears that the District needs a water right for the remaining 7.5 acres. $(.5 \text{ acres})(.02 \text{ cfs}) = 0.01 \text{ cfs}$. Please change the quantity from 0.9 cfs to 0.15 cfs if the District wants this greater quantity.

The standard season of use for irrigation in the area is 3/1 to 10/31. Please change the season of use from 1/1 to 12/31 to 3/1 to 10/31.

3/15 - 10/31/15 (aver)

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
APPLICATION FOR PERMIT

To appropriate the public waters of the State of Idaho

1. Name of Applicant Midvale Maintenance and Construction District Phone 208-365-2322
Mailing address 2316 Valley Rd. Midvale, Idaho 83645

2. Source of water supply well which is a tributary of _____

3. Location of point of diversion is Township 15N Range 3W Sec. 10, in the _____ Co.,
SE 1/4, SW 1/4, Govt. Lot _____, B.M., Washington County;

additional points of diversion if any: _____

4. Water will be used for the following purposes:

Amount 1.25 for Irrigation purposes from 1/1 to 6/31 (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)

5. Total quantity to be appropriated is (a) .09 and/or (b) _____
cubic feet per second acre feet per annum

6. Proposed diverting works:

a. Describe type and size of devices used to divert water from the source 5 horse pump

b. Height of storage dam _____ feet; active reservoir capacity _____ acre-feet; total
reservoir capacity _____ acre-feet

c. Proposed well diameter is _____ inches; proposed depth of well is _____ feet

d. Is ground water with a temperature of greater than 85°F being sought? _____

e. If well is already drilled, when? 8/25/53; Drilling firm Harold Hartline
Well was drilled for (well owner) Michael Cementum Dist; Drilling Permit No. 24429

7. Time required for completion of works and application of water to proposed beneficial use is _____ years (minimum 1 year)

8. Description of proposed uses (if irrigation only, go to item 9):

a. Hydropower; show total feet of head and proposed capacity in kW. _____

b. Stockwatering; list number and kind of livestock. _____

c. Municipal; show name of municipality. _____

d. Domestic; show number of households. _____

e. Other; describe fully. _____

3. Description of place of use:

- a. If water is for irrigation, indicate acreage in each subdivision in the tabulation below.
b. If water is used for other purposes, place a symbol of the use (example: D for Domestic) in the corresponding place of use below. See instructions for standard symbols.

TWP	RGE	SEC	NE				NW				SW				SE				TOTALS
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
13N	3W	10												12					12

Total number of acres to be irrigated 12

10. Describe any other water rights used for the same purposes as described above.

11. a. Who owns the property at the point of diversion? Midvale Cemetery Dist.
b. Who owns the land to be irrigated or place of use? Midvale Cemetery Dist.
c. If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing:

12. Remarks: This application is for the 7.7 Acres of land that was added to the Eastside Cemetery 7/22/1982 for a total of 12 Acres

13. **MAP OF PROPOSED PROJECT REQUIRED** - Attach an 8½"x11" map clearly identifying the proposed point of diversion, place of use, section #, township & range. (A photocopy of a USGS 7.5 minute topographic quadrangle map is preferred.)

BE IT KNOWN that the undersigned hereby makes this application for permit to appropriate the public waters of the State of Idaho as herein set forth.

Vernon L. Latta - Chairman
Signature of Applicant (and title, if applicable)

Received by AMB Date 12-15-06 Time _____ Preliminary check by _____
Fee \$ 100.00 Received by AMB # C082844 Date 12-15-06
Publication prepared by _____ Date _____ Published in _____
Publication approved _____ Date _____