

Memo

To: 63-31884

From: cpadilla

Date: 10/31/2007

Re: Condition Update

SPF Engineering submitted request to have water bearing zone (condition #5) updated from 155-185 feet to 350-750 feet do to contamination at shallow levels. Area research shows several other wells within a 3 mile radius of this well site with depths >350 feet and Steve Lester at Western Region notes this isn't a problem area as far as the aquifer is concerned, therefore the request was granted.