

MEMORANDUM

Date: October 17, 2007
To: Water Right File 27-7420
From: Shelley Keen *SK*
Re: Annual volume limit

The field examiner explained that this right is used for cleaning and maintenance work, mainly related to cleaning of the UV treatment equipment. He recommended an annual volume of 0.6 af, which is the standard volume for in-house use in a home. It equates to about 500 gallons per day. Based on his description of the use, I have reduced the recommended annual volume to 0.1 af, or about 100 gallons per day.