

[illegible]

3. **Delivery System Diagram:** Indicate all major components and distances between components. Indicate weir size/ditch size/pipe i.d. as applicable.

Scale: 1" = _____

____ Copy of USGS Quadrangle Attached Showing location(s) of point(s) of diversion and place(s) of use (required).

____ Aerial Photo Attached (required for irrigation of 10+ acres)

____ Photo of Diversion and System Attached

4.

Well or Diversion Identification No.*	Motor Make	Hp	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size
	Franklin	5		Sub	1"

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date

2. Measurements: _____

This image shows a single sheet of white paper with horizontal blue or grey ruling lines. The lines are evenly spaced and run across the width of the page. There are no margins, text, or other markings on the paper.

Have conditions of permit approval been met? ✓ yes ___ no

F. FLOW CALCULATIONS

Measured Method:

Additional Computation Sheets Attached

Theoretical

$$\frac{8.8(.5)(.7)}{50 + (2.31 \times 40)} = \frac{3.08}{142.4} = .02 \text{ cfs}$$

G. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation:

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) = .5 \times 3 = 1.5$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation Season}) \times 1.9835 = .02 \times 213 \times 1.9835 = 8.4$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} = 1.5$$

2. Volume Calculations for Other Uses:

H. RECOMMENDATIONS

1. Recommended Amounts

Beneficial Use	Period of Use		Rate of Diversion Q (cfs)	Annual Volume V (afa)
	From	To		
<i>Irrigation</i>	<i>04-01</i>	<i>10-31</i>	<i>.02</i>	<i>1.5</i>
Totals:			<i>.02</i>	<i>1.5</i>

2. Recommended Amendments

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☐ None
☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☐ Other

I. AUTHENTICATION

Field Examiner's Name *Wayne Baldwin* Date *9-26-07*

Reviewer *[Signature]* Date *10/4/07*

SEAL

96-9205




-  Bonner taxlots
-  GCDB57N02W GCDB
-  GCDB56N02W GCDB
-  Permit POD



2-5611-2W (Lot 15)
25 Buck Run
Sandpoint, ID

Lot 16




590144





AW



PV



PV