

State of Idaho
Department of Water Resources
Permit to Appropriate Water

NO. 47-17441

Priority: January 17, 2007

Maximum Diversion Rate: 0.89 CFS

This is to certify, that ST LUKES REGIONAL MEDICAL CENTER
190 E BANNOCK
BOISE ID 83712

has applied for a permit to appropriate water from:

Source: GROUND WATER

and a permit is APPROVED for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>
COMMERCIAL	01/01 to 12/31	0.89 CFS

LOCATION OF POINT(S) OF DIVERSION:

GROUND WATER L3 (NE¼NW¼) Sec. 5, Twp 10S, Rge 17E, B.M. TWIN FALLS County

GROUND WATER L4 (NW¼NW¼) Sec. 5, Twp 10S, Rge 17E, B.M. TWIN FALLS County

PLACE OF USE: COMMERCIAL

Twp Rge Sec	NE				NW				SW				SE				Totals
	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
10S 17E 5					X	X											
					L 3	L 4											

CONDITIONS OF APPROVAL

1. Proof of application of water to beneficial use shall be submitted on or before **September 01, 2012**.
2. Subject to all prior water rights.
3. Commercial use is for back-up water supply for a hospital.
4. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
5. Diversion and use of water with a temperature greater than 85 degrees Fahrenheit is not authorized under this right.
6. The right holder shall make full beneficial use of all municipal water rights available to this facility. The right holder shall limit the diversion of ground water under this right to those times when the municipal water supply is not available for the use authorized under this right.
7. Prior to the diversion and use of water under this approval, the right holder shall comply with applicable water quality permitting requirements administered by the Department of Environmental Quality or the Department of Agriculture.


State of Idaho
Department of Water Resources

Permit to Appropriate Water

NO. 47-17441

8. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
9. Any license issued by IDWR pursuant to the right or portion thereof for the use of trust water is subject to a term review of 20 years after the date of this approval to determine availability of water for the use and to re-evaluate the public interest at the end of the term.
10. The right holder shall maintain a totalizing measuring device of a type approved by the Department as a part of the diverting works.
11. For each year until proof of beneficial use is submitted in connection with this right, the right holder shall record when water is diverted from the well under this right and the total quantity of water diverted annually. A written report of this data shall be submitted to the Department when proof of beneficial use is submitted.
12. If use of the municipal water rights available to this place of use are discontinued voluntarily by the right holder, this right shall not be used as a primary source of water.

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code. Witness the signature of the Director, affixed at Boise, this 16th day of September, 2007.


for DAVID R. TUTHILL, JR., Director