

RECEIVED

MAR 12 2007

Permit No: 57-7594

DEPARTMENT OF WATER RESOURCES

Page 1

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
BENEFICIAL USE FIELD REPORT

A. GENERAL INFORMATION

Permit No: 57-7594

Exam Date: 8/16/2005

1. Current Owner: EAGLE VIEW ESTATES HOMEOWNERS ASSN #1
C/O JAMES KLEVENBERG
12560 CINNABAR WAY
MURPHY ID 83650-5021
(208)495-2771
2. Accompanied by: Jim Klevenberg
Phone No: 495-2771
Address: Eagle View Estates
Relationship to Permit Holder: Resident and manager of Association No. 1

3. SOURCE TRIBUTARY
GROUND WATER

B. OVERLAP REVIEW

1. Other water rights with the same place of use: None
2. Other water rights with the same point of diversion: 57-7607

C. DIVERSION AND DELIVERY SYSTEM

1. LOCATION OF POINT(S) OF DIVERSION:

GROUND WATER SE1/4SW1/4 Sec. 10, Twp 02S, Rge 02W, B.M.
OWYHEE County

Method of Determination: Field Exam, Arc View, Plat Map

2.

PLACE OF USE: DOMESTIC

Twp Rge Sec	NE				NW				SW				SE				Totals
	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
02S 02W 9																X	
02S 02W 10									X								

Method of Determination: Exam

3. N Delivery System Diagram Attached (required). Indicate all major components and distances between components. Indicate weir size/pipe as applicable.
- Y Map Attached Showing Location(s) of point(s) of diversion and place(s) of use (required). Scale must be 1:24,000 or greater.
- Y Aerial Photo Attached (required for irrigation of 10+ acres).
- Y Photo of Diversion and System Attached

4.

<u>Well or Diversion ID No.*</u>	<u>Motor Make</u>	<u>Hp</u>	<u>Motor Serial No.</u>	<u>Pump Make</u>	<u>Pump Serial No. or Discharge Size</u>
Well #1	Aeromotor	5		Submersible	

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

<u>Measurement Equipment</u>	<u>Type</u>	<u>Make</u>	<u>Model No.</u>	<u>Serial No.</u>	<u>Size</u>	<u>Calib. Date</u>
Theoretical						

2. Measurements: Theoretical based on 70% efficiency

E. FLOW CALCULATIONS N Additional Computation Sheets Attached

Measured Method:

Per well log: 177' static water level (assume 187' pumping water level)

Per manager: pump on @ 60 psi, off @ 80 psi

187 PWL + 60 psi x 2.31 = 325.6 total dynamic head

Theoretical: $\frac{5 \text{ hp} \times 8.8 \times .7}{325.6} = .09 \text{ cfs}$ pumping capacity

325.6

F. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation:

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) =$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation season}) \times 1.9835 =$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} =$$

2. Volume Calculations for Other Uses:

Internal/external domestic use for 5 homes: $1.2 \times 5 = 6$ afa

G. NARRATIVE/REMARKS/COMMENTS

A 6 inch well equipped with a 5 hp submersible pump, located in Lot 9, Block 3, supplies water to Lots 1 through 5, Block 1, Eagle View Estates Subdivision. Lot 1 is located in both the SWSW and the SESW S10. The home and yard for Lot 1 was found developed in the SWSW S10, therefore not requiring a licensing amendment. The well also supplies water to right 57-7607 (Lot 6, Block 1).

The system consists of three 120 gallon pressure tanks, 4 inch mainline that reduces to 2 ½ inches, and 2 inch stub lines to the homes. All the lots had existing homes at the time of the exam. The permit listed .11 cfs for internal domestic use and .50 cfs for irrigation of 25 acres (5 acres per lot). The subdivision covenant states that each lot is limited to irrigation of ½ acre. Less than ½ acre per lot was found irrigated at the time of the exam. Rather than licensing the actual irrigation amount found, which was little or no irrigation per lot, only domestic use was recommended. This allows yard irrigation up to ½ acre per lot. The permit listed .61 cfs total. Proof of beneficial use and fees paid cover .09 cfs system capacity, which was recommended for licensing to account for internal and external domestic uses. This amount for domestic use is within the parameters and intent of the permit and proof of beneficial use.

The permit was lapsed at the time of the exam, however, the permit holders got it reinstated once they were aware of the situation and process.

No other rights are used. This right, when combined with 57-7607, is limited to the diversion capacity of .09 cfs.

Have conditions of permit approval been met? ☒ Yes ☐ No

H. RECOMMENDATIONS

1. Recommended Amounts

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>DIVERSION RATE</u>	<u>ANNUAL VOLUME</u>
DOMESTIC	01/01 to 12/31	0.090 CFS	6.00 AF
<u>Totals:</u>		0.090 CFS	6.00 AF

2. Recommended Amendments

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☒ None

☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☐ Other

I. AUTHENTICATION

Field Examiner's Name Lori Gnauer Date 2/26/07

Reviewer _____ Date _____



Idaho Department of Water Resources

57-7594

02S 02W S9 & S10



-  POU
-  POD
-  Sections
-  Quarter/Quarter

300 0 300 Feet



IDWR
Prepared by: Lori Graves
Date: 02-26-07
2006 Photography

ROUND POINT
SET 1/8" FROM PIN ALONG SIDE
C.P. AD. MAP 11-000

EAGLE VIEW ESTATES

SITUATED IN THE E $\frac{1}{2}$ OF THE SE $\frac{1}{4}$ OF
OF SECTION 9 AND THE S $\frac{1}{2}$ OF
THE SW $\frac{1}{4}$ OF SECTION 10 WESTERLY OF
HWY 78 T.2S., R.2W., B.M.,
OWYHEE CO., IDAHO

1995



CURVE	DELTA	RADIUS	ARC	HEIGHT	CROSS-SECTION
1	30	226	2.00	1.61	2.00
2	48	226	3.12	2.48	3.12
3	66	226	4.25	3.35	4.25
4	84	226	5.37	4.22	5.37
5	102	226	6.50	5.09	6.50
6	120	226	7.62	5.96	7.62
7	138	226	8.75	6.83	8.75
8	156	226	9.87	7.70	9.87
9	174	226	11.00	8.57	11.00
10	192	226	12.12	9.44	12.12
11	210	226	13.25	10.31	13.25
12	228	226	14.37	11.18	14.37
13	246	226	15.50	12.05	15.50
14	264	226	16.62	12.92	16.62
15	282	226	17.75	13.79	17.75
16	300	226	18.87	14.66	18.87
17	318	226	20.00	15.53	20.00
18	336	226	21.12	16.40	21.12
19	354	226	22.25	17.27	22.25
20	372	226	23.37	18.14	23.37
21	390	226	24.50	19.01	24.50
22	408	226	25.62	19.88	25.62
23	426	226	26.75	20.75	26.75
24	444	226	27.87	21.62	27.87
25	462	226	29.00	22.49	29.00
26	480	226	30.12	23.36	30.12
27	498	226	31.25	24.23	31.25
28	516	226	32.37	25.10	32.37
29	534	226	33.50	25.97	33.50
30	552	226	34.62	26.84	34.62
31	570	226	35.75	27.71	35.75
32	588	226	36.87	28.58	36.87
33	606	226	38.00	29.45	38.00
34	624	226	39.12	30.32	39.12
35	642	226	40.25	31.19	40.25
36	660	226	41.37	32.06	41.37
37	678	226	42.50	32.93	42.50
38	696	226	43.62	33.80	43.62
39	714	226	44.75	34.67	44.75
40	732	226	45.87	35.54	45.87
41	750	226	47.00	36.41	47.00
42	768	226	48.12	37.28	48.12
43	786	226	49.25	38.15	49.25
44	804	226	50.37	39.02	50.37
45	822	226	51.50	39.89	51.50
46	840	226	52.62	40.76	52.62
47	858	226	53.75	41.63	53.75
48	876	226	54.87	42.50	54.87
49	894	226	56.00	43.37	56.00
50	912	226	57.12	44.24	57.12
51	930	226	58.25	45.11	58.25
52	948	226	59.37	45.98	59.37
53	966	226	60.50	46.85	60.50
54	984	226	61.62	47.72	61.62
55	1002	226	62.75	48.59	62.75
56	1020	226	63.87	49.46	63.87
57	1038	226	65.00	50.33	65.00
58	1056	226	66.12	51.20	66.12
59	1074	226	67.25	52.07	67.25
60	1092	226	68.37	52.94	68.37
61	1110	226	69.50	53.81	69.50
62	1128	226	7		

LEGEND

- FOUND BRASS CAP MOUNTING
• SET 5/8" IRON PIN WITH PLASTIC CAP
• SET 1/2" X 24" IRON PIN WITH PLASTIC CAP
- - - - - BOUNDARY LINE
- - - - - LOT LINE
- - - - - CENTER LINE

1. A 20' E UTILITY, ROW/PAVE, AND EASEMENT/RIGHT-OF-WAY 10.00 FEET IN WIDTH IS HEREBY DEDICATED ADJACENT TO AND ALONG SIDEWAYS.

2. A 20' WIDE AND UTILITY EASEMENT 10.00 FEET IN WIDTH IS HEREBY DEDICATED ALONG ALL SIDE LOT LINES UNLESS OTHERWISE NOTED. SHOULD THE LOT LINES BE ADJUSTED, THE EASEMENT SHALL REMAIN THE SAME. THE EASEMENT SHALL BE CONSIDERED TO BE A 20' WIDE EASEMENT WITHIN THE LIMITS OF THE EASEMENT.

3. A 20.00 FOOT ACCESS STRIP TO THE BUILDING OF LAND UNDEVELOPED LAND WILL BE MADE AVAILABLE TO THE PROPERTY OWNERS WITHIN THE EASEMENT ESTATE SUBDIVISION AT THE END OF BOTH PLOTS (LOT 8 BLOCK 2 AND LOT 8 BLOCK 4) AND LOT 8 BLOCK 2 AND LOT 8 BLOCK 4 FOR RETROSPECTIVE BUILDINGS.

LANDMARK SURVEYING

ART SCHULTZ ENGINEERING
CIVIL/STRUCTURAL CONSULTANT
1104 W. FRANK DRIVE
NAPERVILLE, ILLINOIS 60563
(708) 463-0303

S 89°42'00" W 2638.63 (BASIS OF BEARING)

UNPLATTED

BOOK	PAGE
------	------

2 of 2

*Applies to
shared wells
only, not sep-
arate, private
wells.*

PROTECTIVE COVENANTS AND REGULATIONS
EAGLE VIEW ESTATES SUBDIVISION
DATED: OCTOBER 24, 1995
RECORDED: _____
DOCUMENT NO: _____

THE UNDERSIGNED, ALAN E. LINDNER & DEBRA S. LINDNER AND CHARLES S. HIGHTOWER & VICKY L. HIGHTOWER, BEING THE OWNERS IN FEE SIMPLE OF THAT CERTAIN REAL ESTATE SITUATE IN OWYHEE COUNTY, STATE OF IDAHO, AND PARTICULARLY DESCRIBED AS FOLLOWS:

SITUATED IN THE E1/2 OF THE SE1/4 OF SECTION 9 AND A PORTION OF THE S1/2 OF THE SW1/4 OF SECTION 10 WESTERLY OF HWY 78 T.2 S., R.2 W., B.M., OWYHEE COUNTY, IDAHO

1. GENERAL PROVISIONS: GRANTORS HEREBY CERTIFY AND DECLARE THAT THEY HAVE ESTABLISHED, AND DO HEREBY ESTABLISH, A GENERAL PLAN FOR THE DEVELOPMENT, IMPROVEMENT, MAINTENANCE AND PROTECTION OF THE REAL PROPERTY EMBRACED IN EAGLE VIEW ESTATES SUBDIVISION, THE SAME BEING PART OF THE COUNTY OF OWYHEE, STATE OF IDAHO, AND HAVE ESTABLISHED AND DO HEREBY ESTABLISH, THESE PROTECTIVE REGULATIONS FOR THE BENEFIT OF ALL PERSONS WHO MAY HEREAFTER BECOME THE OWNERS OF LOTS IN SAID EAGLE VIEW ESTATES SUBDIVISION, ALL OF WHICH LOTS ARE HEREBY DECLARED TO BE SUBJECT TO THESE PROTECTIVE COVENANTS AND REGULATIONS WHICH ALL ATTACH TO AND RUN WITH THE LAND, AND EVERY PART AND PARCEL THEREOF AND SHALL BIND ALL PERSONS WHO MAY AT ANY TIME AND FROM TIME TO TIME, OWN SAID PROPERTY, OR ANY PART THEREOF AND THEIR RESPECTIVE PERSONAL REPRESENTATIVES, HEIRS OR SUCCESSORS IN INTEREST.

THESE PROTECTIVE REGULATIONS SHALL BE DEEMED TO BE FULLY AND SUFFICIENTLY DESCRIBED OR INCORPORATED INTO ANY INSTRUMENT OF CONVEYANCE BY DESIGNATING AND REFERRING TO THE SAME AS THE PROTECTIVE COVENANTS AND REGULATIONS OF EAGLE VIEW ESTATES SUBDIVISION.

THE "GRANTOR" HEREINAFTER USED IN THE REGULATION SHALL REFER TO ALAN E. LINDNER & DEBRA S. LINDNER, HUSBAND AND WIFE, AND CHARLES S. HIGHTOWER & VICKY L. HIGHTOWER, HUSBAND AND WIFE. THE TERM "GRANTEE" HEREINAFTER USED SHALL REFER TO ANY PURCHASER OF A LOT IN EAGLE VIEW ESTATES SUBDIVISION, SAID PURCHASER'S SUCCESSORS IN INTEREST AND ASSIGNS.

2. TYPE OF STRUCTURE: A LOT SHALL CONSIST OF AN AREA OF FIVE (5) ACRES PLUS/MINUS 0.01 ACRES EXCEPT LOT #6 IN BLOCK 2 & LOT #9 IN BLOCK 3, WHICH ARE WELL LOTS AND ARE 2.05 ACRES AND 2.49 ACRES, RESPECTFULLY, CONTAINED ON THE OFFICIAL PLAT OF EAGLE VIEW ESTATES SUBDIVISION, AND SHALL NOT BE DIVIDED WITHOUT APPROVAL OF THE OWYHEE COUNTY COMMISSIONERS AND MEMBERS OF THE EAGLE VIEW ESTATES HOMEOWNERS ASSOCIATION. IT IS THE EXPRESS INTENTION IN THE CREATION OF EAGLE VIEW ESTATES SUBDIVISION FOR THE ACCOMMODATION OF RESIDENTIAL DWELLINGS OF A MINIMUM AREA OF 1000 SQUARE FEET. ALL BUILDINGS ERECTED UPON ANY LOT SHALL BE FINISHED, PAINTED AND MAINTAINED IN GOOD REPAIR SO AS TO BE INOFFENSIVE TO ANY OTHER PROPERTY OWNERS AND SHALL BE ON A FOUNDATION OF CONCRETE OR CEMENT BLOCKS.

CONSTRUCTION OR PLACEMENT OF ANY BUILDINGS SHALL BE PROSECUTED DILIGENTLY AND CONTINUOUSLY FROM THE TIME OF COMMENCEMENT THEREOF, AND THE SAME SHALL BE COMPLETED, WITHIN EIGHTEEN (18) MONTHS AFTER THE DATE OF COMMENCEMENT OF CONSTRUCTION UNLESS SUCH COMPLETION IS PREVENTED BY CAUSES BEYOND THE CONTROL OF THE GRANTEE, OR WITH THE APPROVAL OF THE ARCHITECTURAL CONTROL COMMITTEE. NO BUILDING SHALL BE ERECTED OR PLACED ON ANY LOT WITHOUT THE APPROVAL OF THE ARCHITECTURAL CONTROL COMMITTEE, WHICH CONSISTS OF THE

GRANTORS, AND ONE OTHER APPOINTED INDIVIDUAL FROM THE RESPECTIVE HOMEOWNER'S ASSOCIATIONS.

A TEMPORARY DWELLING MAY BE USED DURING THE EIGHTEEN (18) MONTH CONSTRUCTION PERIOD. TEMPORARY DWELLING MUST BE APPROVED BY THE ARCHITECTURAL CONTROL COMMITTEE.

3. BUILDING LOCATION: NO BUILDING SHALL BE LOCATED NEARER THAN TWENTY (20) FEET FROM THE FRONT LOT LINE, OR TEN (10) FEET FROM ANY SIDE LOT LINE. LOTS #6, #7 & #8 IN BLOCK 3 ARE RESTRICTED FROM CONSTRUCTION OF PERMANENT STRUCTURES WITHIN ONE HUNDRED (100) FEET OF THE CENTER OF THE DRAW ESTABLISHED BY NATURAL DRAINAGE, AND NO OBSTRUCTIONS MAY BE PLACED WITHIN SAID DRAINAGE WITHOUT APPROVAL FROM ARCHITECTURAL CONTROL COMMITTEE.

4. COMMERCIAL USE & HOME OCCUPATION: THE EAGLE VIEW ESTATES HOMEOWNER'S ASSOCIATION MUST APPROVE, IN ADVANCE OF SUCH USE, ANY COMMERCIAL USE OF A LOT LOCATED WITHIN THE SUBDIVISION.

5. EASEMENTS: ALL LOTS HAVE A TEN (10) FEET UTILITY EASEMENT AROUND PERIMETERS. LOTS #10 IN BLOCK 1, #1 IN BLOCK 2, & #1 IN BLOCK 3, ARE EFFECTED BY THE CULDESAC TO BE ESTABLISHED AT THE END OF EACH RESPECTIVE ROADWAY, AND THOSE CULDESACS WILL GRANT ACCESS TO BLM LAND.

6. ELECTRICAL SERVICES: ALL LOTS SHALL HAVE ELECTRICAL SERVICE TO THE PROPERTY LINE. IT WILL BE THE RESPONSIBILITY OF EACH GRANTEE TO INSTALL SERVICE TO THE REQUIRED LOCATION ON THE INDIVIDUAL LOT. GRANTOR SHALL BE RESPONSIBLE FOR THE COST OF INSTALLATION OF ELECTRICAL SERVICE TO THE PROPERTY LINE, AND GRANTEE SHALL BE RESPONSIBLE FOR THE COST OF FURTHER INSTALLATION ONTO THE LOT. ALL ELECTRICAL SERVICE SHALL BE INSTALLED UNDERGROUND.

7. WELLS AND WATER SYSTEMS: FOUR WELLS WILL BE ESTABLISHED FOR THE LOTS IN THE EAGLE VIEW ESTATES SUBDIVISION. EACH WELL WILL SERVE A MAXIMUM OF SIX LOTS FOR DOMESTIC USE, WHICH WILL INCLUDE IRRIGATION OF ONE HALF ACRE ONLY. A HOMEOWNER'S ASSOCIATION SHALL BE ESTABLISHED FOR EACH GROUP OF SIX LOTS. WELL LOTS SHALL BE DEDICATED TO EACH RESPECTIVE ASSOCIATION. WATER SYSTEM #1 WILL SERVE LOTS #1 THROUGH #6 IN BLOCK 1, WATER SYSTEM #2 SHALL SERVE LOTS #4 THROUGH #8 IN BLOCK 3, WATER SYSTEM #3 WILL SERVE LOTS #1 THROUGH #5 IN BLOCK 2 & LOT #1 IN BLOCK 3, AND WATER SYSTEM #4 WILL SERVE LOTS #7 THROUGH #10 IN BLOCK 1, LOTS #2 & #3 IN BLOCK 3. EACH WELL SYSTEM SHALL BE OWNED AND MAINTAINED BY THE MEMBERS OF THE HOMEOWNER'S ASSOCIATION THAT ARE USING THAT SYSTEM. A MONTHLY FEE SHALL BE PAID BY EACH MEMBER, AND THAT FEE SHALL BE USED TO PAY THE COST OF OPERATING THE PUMP, WITH THE REMAINDER OF THE FEES PUT INTO AN INTEREST BEARING CHECKING ACCOUNT TO BE USED FOR MAINTENANCE AND REPAIR OF EACH RESPECTIVE WATER SYSTEM. THE ASSOCIATION SHALL ELECT OFFICERS TO PERFORM THE NECESSARY DUTIES REQUIRED OF SUCH AN ASSOCIATION.

THE WELLS AND WATER SYSTEMS OF THE EAGLE VIEW ESTATES SUBDIVISION WILL MEET ALL REQUIREMENTS OF THE SOUTHWESTERN DISTRICT HEALTH DEPARTMENT.

THE COST OF WATER LINE INSTALLATION TO THE PROPERTY LINE WILL BE THE RESPONSIBILITY OF THE GRANTOR. GRANTEE SHALL BE RESPONSIBLE FOR THE COST OF FURTHER INSTALLATION ONTO THE INDIVIDUAL LOTS, AND THE COST OF MAINTENANCE AND REPAIR OF WATER LINES.

8. SEPTIC SYSTEMS: GRANTORS SHALL INSTALL, AT THEIR EXPENSE, A SEPTIC SYSTEM AT GRANTEE'S CHOICE OF LOCATION WITHIN COVENANTS GUIDELINES AND THE REGULATIONS AND LAWS OF THE STATE OF IDAHO. THE SEPTIC DISPOSAL SYSTEM SHALL BE INSTALLED BY A LICENSED PUBLIC CONTRACTOR ACCORDING TO SOUTHWESTERN DISTRICT HEALTH DEPARTMENT REQUIREMENTS. GRANTEE SHALL BE RESPONSIBLE FOR MAINTENANCE AND REPAIR OF THE SYSTEM AFTER INSTALLATION.

9. EXCAVATION: NO EXCAVATION FOR STONE, GRAVEL, EARTH OR MINERALS SHALL BE MADE UPON A BUILDING SITE, EXCEPT FOR EXCAVATION REQUIRED FOR THE CONSTRUCTION OF A BUILDING THEREON. NO OIL DRILLING, OR MINING OPERATIONS OF ANY KIND SHALL BE PERMITTED UPON OR IN ANY LOT.

10. ANIMALS: NO MORE THAN SIX HEAD OF LIVESTOCK PER LOT (INCLUDING CATTLE, HORSES, ETC.) AND ALL ANIMALS MUST BE PROPERLY CONTAINED ON EACH INDIVIDUAL LOT, AND CANNOT BE ALLOWED TO ANNOY OTHER PROPERTY OWNERS OR TRESPASS UPON THE PROPERTY OF OTHERS, INCLUDING SMALL DOMESTIC PETS, SUCH AS DOGS AND CATS.

11. ROADWAY MAINTENANCE: WAR EAGLE ROAD AND CINNABAR WAY WILL BE MAINTAINED BY THE HOMEOWNERS' ASSOCIATIONS.

ATTESTED:

ALAN E. LINDNER

DATED: _____

DEBRA S. LINDNER

DATED: _____

CHARLES S. HIGHTOWER

DATED: _____

VICKY L. HIGHTOWER

DATED: _____

ACKNOWLEDGEMENT

STATE OF IDAHO, COUNTY OF OWYHEE

On this day of OCTOBER 24, 1995, before me personally appeared;

ALAN E. LINDNER, DEBRA S. LINDNER, CHARLES S. HIGHTOWER & VICKY L. HIGHTOWER

known to me to be the persons whose names subscribed to the within instrument, and acknowledged to me that they executed the same.

IN WITNESS WHEREOF, I have set my hand and affixed my official seal the day and year in this certificate first above written.

Notary Public

Residence: _____

Comm. Expires: _____

RES

S89°42'18"W (1355.17)

N013°22'09"W (1356.83)

5

5.00 ACRES

4

5.00 ACRES

3

5.00 ACRES

2

5.00 ACRES

1

5.00 ACRES

THRUST
BLOCK
(TYP)

WATER SYSTEM NO. 1

CLAY BAR RAY

2" CAP

2 1/2" - 2"
REDUCER

4" - 2 1/2"
REDUCER

WATER SYSTEM NO. 2

20

5.00 ACRES

21

5.00 ACRES

22

5.00 ACRES

23

5.00 ACRES

24

5.00 ACRES

25

WELL #1

WELL #2

N00°42'00"E (1668.65)

on 2 60 T
off 2 80

well #1

IDAHO DEPARTMENT OF WATER RESOURCES

WELL INSPECTION FORM

1. DRILLING PERMIT NO: 0019815 OTHER APPLICABLE NO: 57-7607
57-7594
2. OWNER: Eagle View Estate Homeowners Phone: 495-2771
Address: HC 79 Box 323
3. WELL LOCATION: Twp 2N, Rge. 2W, Sec. 10, SE 1/4 SW 1/4
County Owyhee (Provide sketch map and photo on reverse.)
4. DRILLER: h. damson Lic. No. 457
When Drilled? 4/11/02
5. WELL CONSTRUCTION:
Casing Diameter 6 inches Water tight cap? ☒ Yes ☐ No Access Port: ☐ Yes ☒ No
Casing $\geq$ 12 inches above ground? ☒ Yes ☐ No - Describe _____
Depth of Casing 208 ft. Method Drilled air rotary
Condition of Well Casing: ☒ Good ☐ Fair ☐ Poor Describe _____
Control Valve? ☐ Yes ☒ No Pressure Gauge: ☒ Yes ☐ No inside pump house
Condition of Piping and Valving good
Auger to a depth of _____ ft. Evidence of Annular Seal ☐ Yes ☐ No
Are there obvious construction problems that may be a source for contamination or waste of water?
☐ Yes ☒ No (Describe in Remarks and Attach Photo - On Reverse)
6. HYDROLOGIC INFORMATION:
Depth to Static Water 177 ft. Water Temperature 68 °F
Flowing Artesian ☐ Yes ☒ No Pressure: 60-80 (psi)
Water Sample Taken? ☐ Yes ☒ No If yes, describe purpose _____
Water Quality Measurements/Observations (Describe) _____
7. WELL USE:
☒ Domestic ☐ Irrigation ☐ Stock
☐ Test ☐ Municipal ☐ Industrial
☐ Abandoned ☐ Waste Disposal/Injection ☐ Not Used
☐ Other: _____

8. POSSIBLE CONTAMINATION SOURCES:

Is there evidence of Chemigation? ☐ Yes ☒ No

If yes, is there a check-valve present? ☐ Yes ☐ No

Is there a possible source of contamination nearby? ☐ Yes ☐ No

If yes, what Type? _____

How far away from the well is this source? _____

9. REMARKS: server 6 homes Total : 57-7594
57-7607

Replaced 57-94-C-0043 which was
drilled in 1994 and abandoned
in 2002 per tag no. 776801

Loi Braver

Signature of Dept. Representative & Title

8/16/05

Inspection Date

PHOTOS, DRAWINGS, OTHER ATTACHMENTS:

Other IDWR No. 57-07594

Name Home Owners INC., ALAN LINDNER

Address HC 79 Box 34X

City MCIBA State Id. Zip 83641

Charles Hightower 495-7809

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



T. 2 North ☐ or South ☒
 E. 2 East ☐ or West ☒
 Sec. 10 1/4 SE 1/4 SW 1/4
10 acres 40 acres 160 acres
 Gov't Lot _____ County Owyhee

Address of Well Site HWY 78 4 1/2 miles past
Blue Canyon Murphy Id.
(Give at least Direction + Distance to Road or Landmark)

Lot No. _____ Block No. _____ Subd. Name _____

4. PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK

☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD

☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	40	10'	over bore

Was drive shoe seal tested? Y ☐ N ☐ How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Casting	Liner	Steel	Plastic	Welded	Threaded
4 1/2	10'	220				☐	☒	☐	☐
4 1/2	200	20	Same cut per spec				☒	☐	☐
10'	cut off	carrying					☐	☐	☐
						☐	☐	☐	☐

Final location of shoes _____

Top Packer or Headpipe _____ Bottom Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____

☐ Screens Type _____ Material _____

From	To	Slot Size	Number	Diameter	Tel./Pipe Size	Casting	Linear
						☐	☐
						☐	☐
						☐	☐
						☐	☐

10. WELL TESTS:

☐ Pump ☒ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Depth	Time
35	180	185	4 Hr.

Temperature of water _____ Was a water analysis done? Yes ☐ No ☒

By whom? _____

Water Quality (odor, etc.) _____

Bottom Hole Temperature _____

11) STATIC WATER LEVEL:

150 ft. below surface Depth artesian flow found _____

Artesian pressure _____ lb. Describe access port _____

Describe Controlling Devices: _____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

[illegible]

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Ernie Wellbill Inc Firm No. 411

Firm Official Mike Kassir Date _____

Supervisor or Operator _____ Date _____

(Sign once if Firm Official & Operator)

57-7594 & 57-7607



Pump House System & Well
Located in the SESW S10 T2S R2W
Lot 9, Block 3

