

RECEIVED

MAR 12 2007

Permit No: 57-7598

DEPARTMENT OF WATER RESOURCES

Page 1

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
BENEFICIAL USE FIELD REPORT

A. GENERAL INFORMATION

Permit No: 57-7598

Exam Date: 8/16/2005

1. Current Owner: EAGLE VIEW ESTATES HOMEOWNERS ASSN #2
12621 CINNABAR WAY
MURPHY ID 83650
(208)495-2522
2. Accompanied by: Tim Simmonds
Phone No: 495-2522
Address: Same as above
Relationship to Permit Holder: Association President

3. SOURCE TRIBUTARY
GROUND WATER

B. OVERLAP REVIEW

1. Other water rights with the same place of use: None
2. Other water rights with the same point of diversion: None

C. DIVERSION AND DELIVERY SYSTEM

1. LOCATION OF POINT(S) OF DIVERSION:

GROUND WATER SE1/4SW1/4 Sec. 10, Twp 02S, Rge 02W, B.M.
OWYHEE County

Method of Determination: Field Exam, ArcView Photo, Plat map

2.

PLACE OF USE: DOMESTIC

Twp	Rge	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
02S	02W	9																X	
02S	02W	10									X								

Method of Determination: Exam

3. N Delivery System Diagram Attached (required). Indicate all major components and distances between components. Indicate weir size/pipe as applicable.
- Y Map Attached Showing Location(s) of point(s) of diversion and place(s) of use (required). Scale must be 1:24,000 or greater.
- Y Aerial Photo Attached (required for irrigation of 10+ acres).
- Y Photo of Diversion and System Attached

4.

<u>Well or Diversion ID No.*</u>	<u>Motor Make</u>	<u>Hp</u>	<u>Motor Serial No.</u>	<u>Pump Make</u>	<u>Pump Serial No. or Discharge Size</u>
Well #2	Franklin	7.5	Submersible	Grandfos	40S75-21
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

<u>Measurement Equipment</u>	<u>Type</u>	<u>Make</u>	<u>Model No.</u>	<u>Serial No.</u>	<u>Size</u>	<u>Calib. Date</u>
_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____

2. Measurements:

Pump curve supplied by Adamson Pump & Drilling (pump installer)

Theoretical based on 70% efficiency

E. FLOW CALCULATIONS

Measured Method:

Per well log: 190' static water level (assume 200' pumping water level)

Per field exam: pump on @ 60 psi, off @ 80 psi

200' PWL + 60 psi x 2.31 = 339' total dynamic head

Theoretical:

$$\frac{.7 \times 8.8 \times 7.5 \text{ hp}}{339 \text{ TDH}} = .14 \text{ cfs pumping capacity}$$

Pump Curve: 50 gpm or .11 cfs pumping capacity

(Pump Curve)
 ___Y___ Additional Computation Sheets Attached

F. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation:

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) =$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation season}) \times 1.9835 =$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} =$$

2. Volume Calculations for Other Uses:

Internal/external domestic use for 5 homes: 1.2 af x 5 = 6 af

G. NARRATIVE/REMARKS/COMMENTS

A 6 inch well equipped with a 7.5 hp submersible pump, located in Lot 9, Block 3, supplies water to Lots 4 through 8, Block 3, Eagle View Estates Subdivision. Four of the five lots have homes. Lot 6 was undeveloped at the time of the exam, but had a stub to the system. Lot 8 is located in both the SESW and the SWSW S10. The home and yard for Lot 8 was found developed in the SWSW S10, therefore not requiring a licensing amendment.

The well was drilled by Knie Well and Pump in 1994. The current pump was installed by Adamson Pump and Drilling in 2002. The system consists of three 120 gallon pressure tanks, 4 inch mainline that reduces to 2 ½ inches, and 2 inch stub lines. Proof of beneficial use was submitted in 2003 listing .089 cfs, equivalent to 40 gpm. The pump invoice referenced a 40 gpm Grundfos pump. As indicated on the pump curve, optimal performance is at 40 gpm, however, based on the system TDH, the pump capacity is 50 gpm or .11 cfs. This amount is within the limits of the permit and proof fee paid and has been recommended for licensing.

The permit listed irrigation of 5 acres per lot along with domestic use. The subdivision covenant states that each lot is limited to irrigation of ½ acre. Less than ½ acre per lot was found irrigated at the time of the exam. Rather than licensing the actual irrigation amount found, which was little or no irrigation per lot, only domestic use was recommended. This allows yard irrigation up to ½ acre per lot.

No other water rights are used.

Have conditions of permit approval been met? ☒ Yes ☐ No

H. RECOMMENDATIONS

1. Recommended Amounts

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>DIVERSION RATE</u>	<u>ANNUAL VOLUME</u>
DOMESTIC	01/01 to 12/31	0.110 CFS	6.00 AF
<u>Totals:</u>		0.110 CFS	6.00 AF

2. Recommended Amendments

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☒ None

☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☐ Other

I. AUTHENTICATION

Field Examiner's Name Lon Givner Date 8/31/05

Reviewer _____ Date _____

57-7598

T2S R2W
P/U: SESE S9, SWSW S10
P/D: SESW S10



Pu.shp
Pd.shp
PLSS Section LinesGcdb_sections.shp
GCDB02S02W GCDB





EAGLE VIEW ESTATES

PLAT SHOWING

SITUATED IN THE E 1/2 OF THE SE 1/4 OF
OF SECTION 9 AND THE S 1/2 OF
THE SW 1/4 OF SECTION 10 WESTERLY OF
HWY 78 T.25S., R.2W., B.M.,
OWYHEE CO., IDAHO

1995



CURVE DATA			
CURVE	DELTA	RADIUS	ARC
1	20°00'00"	20	31.42
2	88°22'36"	20	31.02
3	14°11'39"	250	61.81
4	14°11'39"	250	61.81
5	14°11'39"	250	61.81
6	80°17'20"	310	39.78
7	88°41'49"	20	31.32
8	88°41'49"	20	31.32
9	130°22'15"	55	132.84
10	130°22'15"	55	132.84
11	48°11'23"	20	16.42
12	48°11'23"	20	16.42
13	48°11'23"	20	16.42
14	48°11'23"	20	16.42
15	48°11'23"	20	16.42
16	130°40'48"	16	130.40
17	137°41'58"	17	137.42

NOTES

1. PUBLIC UTILITY, DRAINAGE, AND IRRIGATION EASEMENT 10.00 FEET IN WIDTH IS HEREBY DEDICATED ADJACENT TO ALL STREETS.
2. A DRAINAGE AND UTILITY EASEMENT 10.00 FEET IN WIDTH IS HEREBY DEDICATED ALONG ALL SIDE LOT LINES UNLESS OTHERWISE NOTED. SHOULD THE LOT LINES BE ADJUSTED, THE EASEMENT SHALL MOVE WITH THE ADJUSTMENT. LOT LINES PROVIDED AND UTILITIES HAVE BEEN INSTALLED WITHIN THE LIMITS OF THE EASEMENT.
3. A 30.00 FOOT ACCESS STRIP TO THE REAR OF LOTS 1 THROUGH 10 WILL BE MOVED AWAY FROM LOTS 1 TO THE PROPERTY LINES WITHIN THE EAGLE VIEW ESTATES SUBDIVISION AT THE END OF BOTH ROWS.
4. LOT 6 BLOCK 2 AND LOT 8 BLOCK 3 ARE COMMUNITY WELL LOTS AND NOT FOR RESIDENTIAL BUILDINGS.

LEGEND


- FOUND BRASS CAP MONUMENT
- SET 5/8" IRON PIN WITH PLASTIC CAP
- SET 1/2" x 24" IRON PIN WITH PLASTIC CAP
- BOUNDARY LINE
- LOT LINE
- CENTER LINE
- BLOCK #
- LOT #

-Latest-
subdivision plat
re-numbered

LANDMARK SURVEYING



ART SCHULTZ ENGINEERING
CIVIL/STRUCTURAL CONSULTANT
1154 W. DAVIS RD.
IDAHO FALLS, IDAHO 83401
(208) 463-0305



Adamson Pump & Drilling Company

Pumps *Dave Adamson* Wells

1320 Smith Avenue - Nampa, ID 83651

208-466-8439 Fax 208-466-0008

Fax Cover Sheet

To: *Lois Graves @ IDWR*

Fax: _____

From: *Jan*

Fax# _____

Number of pages: *2* (Including cover sheet)

Remarks: _____

*Mr Tim Simmons of Eagle View - Well #2
asked that I fax you a copy of the pump
curve for their pump - Grundfos 40S75-21*

Please call if you need any further info!

If not all pages were received, the fax is not readable, or for any reason this fax is not complete, please call 466-6439 as soon as possible. Thank You!

PERFORMANCE CURVES


40 GPM

MODEL 40S

FLOW RANGE: 24 - 55 GPM

OUTLET SIZE: 2" NPT

NOMINAL DIA. 4"



SPECIFICATIONS SUBJECT TO CHANGE WITHOUT NOTICE.

4" MOTOR STANDARD, 1-10 HP/3450 RPM.

6" MOTOR STANDARD, 15-20 HP/3450 RPM.

* Also available with 6" motor.

Performance conforms to ISO 9906 Annex A
@ 5 ft. min. submergence.

Adamson Pump & Drilling

1320 Smith Avenue
Nampa, ID 83651

INVOICE

Date

Invoice No.

05/03/2002

02-288

Bill To

Eagle View Estates
Attn: Tim Simmonds
HC 79 Box 322
Melba, ID 83641

Job Description/Location

Well #2
Replaced pump & motor
There was no sand problem at this time

Terms

Due Date

Completion Date

Company Rep

Work Performed By

Net 10 days

05/13/2002

05/03/2002

DKA

Jim, Brian

Quantity	Description	Amount
1	Grundfos 40 gpm 7.5 hp pump end	2,074.00
1	7.5hp Motor - Franklin	1,423.00
1	#6 Underwater Splice	15.30
1	Misc Fittings - 2" check valve, tape, nipple union	138.40
1	Freight Charges	49.00
	Customer Discount - Adamson's paid frt	-49.00
6	Labor- 2 men	510.00
1	Winch Truck	35.00
1	Mileage	75.00
	20% Customer Discount on parts only	-730.14
	State Use Tax	182.54
TOTAL 3743.10 $\div 5 = 744.62$ EACH LOTS		
PAID FOR VOI 2 CH 1005 PAID 2978.98 CH 1005		
Total		\$3,723.10

PLEASE PAY FROM THIS INVOICE. WE DO NOT SEND STATEMENTS. A finance charge of 1.5% per month (18%apr) will be added to all accounts 30 days or more past due. The prevailing party is entitled to attorney's fees & costs in any legal proceeding. A lien will be filed on accounts 75 days past due.

**PROTECTIVE COVENANTS AND REGULATIONS
EAGLE VIEW ESTATES SUBDIVISION**

DATED: OCTOBER 24, 1995

RECORDED: _____

DOCUMENT NO: _____

THE UNDERSIGNED, ALAN E. LINDNER & DEBRA S. LINDNER AND CHARLES S. HIGHTOWER & VICKY L. HIGHTOWER, BEING THE OWNERS IN FEE SIMPLE OF THAT CERTAIN REAL ESTATE SITUATE IN OWYHEE COUNTY, STATE OF IDAHO, AND PARTICULARLY DESCRIBED AS FOLLOWS:

SITUATED IN THE E1/2 OF THE SE1/4 OF SECTION 9 AND A PORTION OF THE S1/2 OF THE SW1/4 OF SECTION 10 WESTERLY OF HWY 78 T.2 S., R.2 W., B.M., OWYHEE COUNTY, IDAHO

1. **GENERAL PROVISIONS:** GRANTORS HEREBY CERTIFY AND DECLARE THAT THEY HAVE ESTABLISHED, AND DO HEREBY ESTABLISH, A GENERAL PLAN FOR THE DEVELOPMENT, IMPROVEMENT, MAINTENANCE AND PROTECTION OF THE REAL PROPERTY EMBRACED IN EAGLE VIEW ESTATES SUBDIVISION, THE SAME BEING PART OF THE COUNTY OF OWYHEE, STATE OF IDAHO, AND HAVE ESTABLISHED AND DO HEREBY ESTABLISH, THESE PROTECTIVE REGULATIONS FOR THE BENEFIT OF ALL PERSONS WHO MAY HEREAFTER BECOME THE OWNERS OF LOTS IN SAID EAGLE VIEW ESTATES SUBDIVISION, ALL OF WHICH LOTS ARE HEREBY DECLARED TO BE SUBJECT TO THESE PROTECTIVE COVENANTS AND REGULATIONS WHICH ALL ATTACH TO AND RUN WITH THE LAND, AND EVERY PART AND PARCEL THEREOF AND SHALL BIND ALL PERSONS WHO MAY AT ANY TIME AND FROM TIME TO TIME, OWN SAID PROPERTY, OR ANY PART THEREOF AND THEIR RESPECTIVE PERSONAL REPRESENTATIVES, HEIRS OR SUCCESSORS IN INTEREST.

THESE PROTECTIVE REGULATIONS SHALL BE DEEMED TO BE FULLY AND SUFFICIENTLY DESCRIBED OR INCORPORATED INTO ANY INSTRUMENT OF CONVEYANCE BY DESIGNATING AND REFERRING TO THE SAME AS THE PROTECTIVE COVENANTS AND REGULATIONS OF EAGLE VIEW ESTATES SUBDIVISION.

THE "GRANTOR" HEREINAFTER USED IN THE REGULATION SHALL REFER TO ALAN E. LINDNER & DEBRA S. LINDNER, HUSBAND AND WIFE, AND CHARLES S. HIGHTOWER & VICKY L. HIGHTOWER, HUSBAND AND WIFE. THE TERM "GRANTEE" HEREINAFTER USED SHALL REFER TO ANY PURCHASER OF A LOT IN EAGLE VIEW ESTATES SUBDIVISION, SAID PURCHASER'S SUCCESSORS IN INTEREST AND ASSIGNS.

2. **TYPE OF STRUCTURE:** A LOT SHALL CONSIST OF AN AREA OF FIVE (5) ACRES PLUS/MINUS 0.01 ACRES EXCEPT LOT #6 IN BLOCK 2 & LOT #9 IN BLOCK 3, WHICH ARE WELL LOTS AND ARE 2.05 ACRES AND 2.49 ACRES, RESPECTFULLY, CONTAINED ON THE OFFICIAL PLAT OF EAGLE VIEW ESTATES SUBDIVISION, AND SHALL NOT BE DIVIDED WITHOUT APPROVAL OF THE OWYHEE COUNTY COMMISSIONERS AND MEMBERS OF THE EAGLE VIEW ESTATES HOMEOWNERS ASSOCIATION. IT IS THE EXPRESS INTENTION IN THE CREATION OF EAGLE VIEW ESTATES SUBDIVISION FOR THE ACCOMMODATION OF RESIDENTIAL DWELLINGS OF A MINIMUM AREA OF 1000 SQUARE FEET. ALL BUILDINGS ERRECTED UPON ANY LOT SHALL BE FINISHED, PAINTED AND MAINTAINED IN GOOD REPAIR SO AS TO BE INOFFENSIVE TO ANY OTHER PROPERTY OWNERS AND SHALL BE ON A FOUNDATION OF CONCRETE OR CEMENT BLOCKS.

CONSTRUCTION OR PLACEMENT OF ANY BUILDINGS SHALL BE PROSECUTED DILIGENTLY AND CONTINUOUSLY FROM THE TIME OF COMMENCEMENT THEREOF, AND THE SAME SHALL BE COMPLETED, WITHIN EIGHTEEN (18) MONTHS AFTER THE DATE OF COMMENCEMENT OF CONSTRUCTION UNLESS SUCH COMPLETION IS PREVENTED BY CAUSES BEYOND THE CONTROL OF THE GRANTEE, OR WITH THE APPROVAL OF THE ARCHITECTURAL CONTROL COMMITTEE. NO BUILDING SHALL BE ERRECTED OR PLACED ON ANY LOT WITHOUT THE APPROVAL OF THE ARCHITECTURAL CONTROL COMMITTEE, WHICH CONSISTS OF THE

*1/2 ac limit applies
to users of shared
wells, not
private wells*

GRANTORS, AND ONE OTHER APPOINTED INDIVIDUAL FROM THE RESPECTIVE HOMEOWNER'S ASSOCIATIONS.

A TEMPORARY DWELLING MAY BE USED DURING THE EIGHTEEN (18) MONTH CONSTRUCTION PERIOD. TEMPORARY DWELLING MUST BE APPROVED BY THE ARCHITECTURAL CONTROL COMMITTEE.

3. BUILDING LOCATION: NO BUILDING SHALL BE LOCATED NEARER THAN TWENTY (20) FEET FROM THE FRONT LOT LINE, OR TEN (10) FEET FROM ANY SIDE LOT LINE. LOTS #6, #7 & #8 IN BLOCK 3 ARE RESTRICTED FROM CONSTRUCTION OF PERMANENT STRUCTURES WITHIN ONE HUNDRED (100) FEET OF THE CENTER OF THE DRAW ESTABLISHED BY NATURAL DRAINAGE, AND NO OBSTRUCTIONS MAY BE PLACED WITHIN SAID DRAINAGE WITHOUT APPROVAL FROM ARCHITECTURAL CONTROL COMMITTEE.

4. COMMERCIAL USE & HOME OCCUPATION: THE EAGLE VIEW ESTATES HOMEOWNER'S ASSOCIATION MUST APPROVE, IN ADVANCE OF SUCH USE, ANY COMMERCIAL USE OF A LOT LOCATED WITHIN THE SUBDIVISION.

5. EASEMENTS: ALL LOTS HAVE A TEN (10) FEET UTILITY EASEMENT AROUND PERIMETERS. LOTS #10 IN BLOCK 1, #1 IN BLOCK 2, & #1 IN BLOCK 3, ARE EFFECTED BY THE CULDESAC TO BE ESTABLISHED AT THE END OF EACH RESPECTIVE ROADWAY, AND THOSE CULDESACS WILL GRANT ACCESS TO BLM LAND.

6. ELECTRICAL SERVICES: ALL LOTS SHALL HAVE ELECTRICAL SERVICE TO THE PROPERTY LINE. IT WILL BE THE RESPONSIBILITY OF EACH GRANTEE TO INSTALL SERVICE TO THE REQUIRED LOCATION ON THE INDIVIDUAL LOT. GRANTOR SHALL BE RESPONSIBLE FOR THE COST OF INSTALLATION OF ELECTRICAL SERVICE TO THE PROPERTY LINE, AND GRANTEE SHALL BE RESPONSIBLE FOR THE COST OF FURTHER INSTALLATION ONTO THE LOT. ALL ELECTRICAL SERVICE SHALL BE INSTALLED UNDERGROUND.

7. WELLS AND WATER SYSTEMS: FOUR WELLS WILL BE ESTABLISHED FOR THE LOTS IN THE EAGLE VIEW ESTATES SUBDIVISION. EACH WELL WILL SERVE A MAXIMUM OF SIX LOTS FOR DOMESTIC USE, WHICH WILL INCLUDE IRRIGATION OF ONE HALF ACRE ONLY. A HOMEOWNER'S ASSOCIATION SHALL BE ESTABLISHED FOR EACH GROUP OF SIX LOTS. WELL LOTS SHALL BE DEDICATED TO EACH RESPECTIVE ASSOCIATION. WATER SYSTEM #1 WILL SERVE LOTS #1 THROUGH #6 IN BLOCK 1, WATER SYSTEM #2 SHALL SERVE LOTS #4 THROUGH #8 IN BLOCK 3, WATER SYSTEM #3 WILL SERVE LOTS #1 THROUGH #5 IN BLOCK 2 & LOT #1 IN BLOCK 3, AND WATER SYSTEM #4 WILL SERVE LOTS #7 THROUGH #10 IN BLOCK 1, LOTS #2 & #3 IN BLOCK 3. EACH WELL SYSTEM SHALL BE OWNED AND MAINTAINED BY THE MEMBERS OF THE HOMEOWNER'S ASSOCIATION THAT ARE USING THAT SYSTEM. A MONTHLY FEE SHALL BE PAID BY EACH MEMBER, AND THAT FEE SHALL BE USED TO PAY THE COST OF OPERATING THE PUMP, WITH THE REMAINDER OF THE FEES PUT INTO AN INTEREST BEARING CHECKING ACCOUNT TO BE USED FOR MAINTENANCE AND REPAIR OF EACH RESPECTIVE WATER SYSTEM. THE ASSOCIATION SHALL ELECT OFFICERS TO PERFORM THE NECESSARY DUTIES REQUIRED OF SUCH AN ASSOCIATION.

THE WELLS AND WATER SYSTEMS OF THE EAGLE VIEW ESTATES SUBDIVISION WILL MEET ALL REQUIREMENTS OF THE SOUTHWESTERN DISTRICT HEALTH DEPARTMENT.

THE COST OF WATER LINE INSTALLATION TO THE PROPERTY LINE WILL BE THE RESPONSIBILITY OF THE GRANTOR. GRANTEE SHALL BE RESPONSIBLE FOR THE COST OF FURTHER INSTALLATION ONTO THE INDIVIDUAL LOTS, AND THE COST OF MAINTENANCE AND REPAIR OF WATER LINES.

8. SEPTIC SYSTEMS: GRANTORS SHALL INSTALL, AT THEIR EXPENSE, A SEPTIC SYSTEM AT GRANTEE'S CHOICE OF LOCATION WITHIN COVENANTS GUIDELINES AND THE REGULATIONS AND LAWS OF THE STATE OF IDAHO. THE SEPTIC DISPOSAL SYSTEM SHALL BE INSTALLED BY A LICENSED PUBLIC CONTRACTOR ACCORDING TO SOUTHWESTERN DISTRICT HEALTH DEPARTMENT REQUIREMENTS. GRANTEE SHALL BE RESPONSIBLE FOR MAINTENANCE AND REPAIR OF THE SYSTEM AFTER INSTALLATION.

9. EXCAVATION: NO EXCAVATION FOR STONE, GRAVEL, EARTH OR MINERALS SHALL BE MADE UPON A BUILDING SITE, EXCEPT FOR EXCAVATION REQUIRED FOR THE CONSTRUCTION OF A BUILDING THEREON. NO OIL DRILLING, OR MINING OPERATIONS OF ANY KIND SHALL BE PERMITTED UPON OR IN ANY LOT.

10. ANIMALS: NO MORE THAN SIX HEAD OF LIVESTOCK PER LOT (INCLUDING CATTLE, HORSES, ETC.) AND ALL ANIMALS MUST BE PROPERLY CONTAINED ON EACH INDIVIDUAL LOT, AND CANNOT BE ALLOWED TO ANNOY OTHER PROPERTY OWNERS OR TRESPASS UPON THE PROPERTY OF OTHERS, INCLUDING SMALL DOMESTIC PETS, SUCH AS DOGS AND CATS.

11. ROADWAY MAINTENANCE: WAR EAGLE ROAD AND CINNABAR WAY WILL BE MAINTAINED BY THE HOMEOWNERS' ASSOCIATIONS.

ATTESTED:

ALAN E. LINDNER

DATED: _____

DEBRA S. LINDNER

DATED: _____

CHARLES S. HIGHTOWER

DATED: _____

VICKY L. HIGHTOWER

DATED: _____

ACKNOWLEDGEMENT

STATE OF IDAHO, COUNTY OF OWYHEE

On this day of OCTOBER 24, 1995, before me personally appeared;

ALAN E. LINDNER, DEBRA S. LINDNER, CHARLES S. HIGHTOWER & VICKY L. HIGHTOWER

known to me to be the persons whose names subscribed to the within instrument, and acknowledged to me that they executed the same.

IN WITNESS WHEREOF, I have set my hand and affixed my official seal the day and year in this certificate first above written.

Notary Public

Residence: _____
Comm. Expires: _____

IDAHO DEPARTMENT OF WATER RESOURCES

WELL INSPECTION FORM

1. DRILLING PERMIT NO: 57-94-C-0047 OTHER APPLICABLE NO: 57-7598
2. OWNER: Eagle View Estates Homeowners Assoc. #2 Phone: 495-2522
Address: C/O Tim Simmonds, 12621 Cinnabar Way
Murphy Id 83650
3. WELL LOCATION: Twp 2N, Rge. 2W, Sec. 10, SE 1/4 SW 1/4
County Owyhee (Provide sketch map and photo on reverse.)
4. DRILLER: Knice Well + Pump Lic. No. 417
When Drilled? 1994
5. WELL CONSTRUCTION:
Casing Diameter 6 inches Water tight cap? ☒ Yes ☐ No Access Port: ☐ Yes ☒ No
Casing $\geq$ 12 inches above ground? ☒ Yes ☐ No - Describe _____
Depth of Casing 200 ft. Method Drilled air Rotary
Condition of Well Casing: ☒ Good ☐ Fair ☐ Poor Describe _____
Control Valve? ☐ Yes ☒ No Pressure Gauge: ☒ Yes ☐ No
Condition of Piping and Valving good
Auger to a depth of _____ ft. Evidence of Annular Seal ☐ Yes ☐ No
Are there obvious construction problems that may be a source for contamination or waste of water?
☐ Yes ☒ No (Describe in Remarks and Attach Photo - On Reverse)
6. HYDROLOGIC INFORMATION:
Depth to Static Water 190 ft. Water Temperature cold °F
Flowing Artesian ☐ Yes ☒ No Pressure: 60-80 (psi)
Water Sample Taken? ☐ Yes ☒ No If yes, describe purpose _____
Water Quality Measurements/Observations (Describe) _____
7. WELL USE:
☒ Domestic ☐ Irrigation ☐ Stock
☐ Test ☐ Municipal ☐ Industrial
☐ Abandoned ☐ Waste Disposal/Injection ☐ Not Used
☐ Other: _____

Department of Water Resources

Yield gal./min.	Drawdown	Pumping Depth	Time
40	10'	200	2 hr

By whom?

Bottom Hole Temperature

190 ft. below surface Depth artesian flow found

Artesian pressure lb. Describe access port

Describe Controlling Devices: well cap

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

[illegible]

RECEIVED

SEP 30 1994

**WATER RESOURCES
WESTERN REGION**

SCANNED

FEB 21 2002

Date: Started 9-20-94 Completed 9-26-94

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Knic Well & pump Firm No. 417

Firm Official M. L. Krue Date 9-27-9

and
Supervisor or Operator Rod Ransom Date 9-26-97

(Sign once if Firm Official & Operator)

well #2

2. OWNER:


2. OWNER:
Name Homeowners Inc. - Alan Lindner

Address Hc 79 Box 34 X

City MCIBA State Id Zip 83641

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



T. 2 North ☐ or South ☒
 E. 2 East ☐ or West ☒
 Sec. 10 $\frac{1}{4}$ SE $\frac{1}{4}$ SW $\frac{1}{4}$
10 acres 40 acres 160 acres
 Gov't Lot _____ County OWYHCC

Address of Well Site HWY 78 4 1/2 miles past
Blue CANOE MURPHY Id.
(Give at least Direction - Distance to Road or landmark)

Lot No. 25 Block No. Subd. Name Eagle View

4. PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Monitor ☒ Irrigation
☐ Thermal ☐ Injection ☒ Other *half Dom*

5. TYPE OF WORK

☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD

☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or (Pounds)	
Bentonite	0	19	300	Over Bore

Was drive shoe seal tested? Y ☐ N ☒ How?

8. CASING/LINER:

Diameter	From	To	Gauge	Casting	Liner	Steel	Plastic	Welded	Threaded
6	20	20			X	☐	☒	☐	☐
6	20	25		X		☒	☐	☐	☐
						☐	☐	☐	☐
						☐	☐	☐	☐

Final location of shoes 200' TOTAL p.v.c.

Top Packer or Headpipe 20' per F. Bottom Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method _____
☐ Screens Type _____ Material P.V.C.

From	To	Slot Size	Number	Diameter	Tele/Pipe Size	Casting	Liner
~~200~~	~~230~~	S&W	cut	6		☐	☒
200	230					☐	☐
						☐	☐
						☐	☐

57-7598



SWSW S10 T2S R2W
Lot 8 Block 3



Typical Stub Line

57-7598



Pump House System & Well
Located in SESW S10 T2S R2W
Lot 9, Block 3

