



State of Idaho

DEPARTMENT OF WATER RESOURCES

Southern Region, 1341 Fillmore Street, Suite 200 • Twin Falls, Idaho 83301-3380

Phone: (208) 736-3033 • Fax: (208) 736-3037 • Web Site: www.idwr.idaho.gov

C. L. "BUTCH" OTTER
Governor

DAVID R. TUTHILL, JR.
Director

July 23, 2007

EHM Engineers
Attn: Gary Burkett
621 North College Rd
Twin Falls, ID 83301

HAND DELIVERED

RE: Crossroads Point East Subdivision

Dear Gary:

This letter is intended to replace the letter I delivered to you on July 19, 2007.

I have reviewed the plat you have provided of the proposed subdivision. Review of the water right records indicate that the property is within the service area of the North Side Canal Company and aerial show that the land is currently irrigated at the site of the proposed subdivision, I assume it is watered from canal shares. Any future irrigation within the subdivision should be made with existing canal shares.

Review of the plat seems to indicate that the non-irrigation water uses may come from connection to the water system associated with the Crossroads Truck Stop and area south of this site. That system is covered by permits 36-7619 and 36-8234 and does not authorize the use of these rights or these wells at Crossroads Point East Subdivision. Those permits are pending licensing.

As noted on the plat it is proposed that water service will be "public". I find that currently the Department is processing transfer No. 72803 that modifies right 36-2526 and the associated well for that right and associates it with a service area that includes the site of the subdivision. On approval of this transfer the other municipal rights for the City of Jerome should be associated with the service area described in this transfer.

It appears that the proper water right filings have not yet been made to utilize the Cross Roads wells with the City of Jerome municipal rights.

If you have questions please feel free to contact this office.

Sincerely,

Allen Merritt, PE
Southern Region Manager