

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
PERMIT TO DRILL A WELL
NO. 61-93-W-0004-000

1. This is to certify, that

J R SIMPLOT CO
PO BOX 27
BOISE ID 83707

O

has applied for a permit on 3/12/1993 to drill a well and a permit is
APPROVED for construction as follows:

2. **Proposed Well Location:** Township 05S, Range 04E, Sec. 6, SENE
ELMORE County

Street Address of Well Site: HC 85 BOX 275
GRANDVIEW

ID

3. **Proposed Use of Well:** Non-Domestic Irrigation

4. **Well Construction Information:**

- A. Replace
- B. Proposed Surface Diameter 20 In. Proposed Maximum Depth 800 Ft.
- C. Anticipated Bottom Hole Temperature: 85 F or less (Cold water well)

5. **Construction Start Date:** 3/15/1993

6. **Anticipated Well Driller:**

MARTINS WELL SERVICE

NOTE: The actual well driller must be identified prior to drilling.

GENERAL CONDITIONS:

1. This well shall not be drilled deeper than 10% of proposed total depth or enlarged without prior authorization.
2. The well must be constructed or modified in compliance with the applicable statutes; specific conditions of approval shown on the water right permit, transfer, amendment, or injection well permit; and the rules and regulations of the Department of water appropriation, injection wells, and well construction.
3. This drilling permit is valid for two (2) months from approval date for the start of drilling.
4. This permit does not constitute other local, county, state or federal approvals which may be required for construction of a well. All wells must be drilled a minimum distance of 100 feet from a drain field. Domestic and Public Water Supply wells must be drilled a minimum distance of 50 feet and 100 feet respectively from a septic tank.

(Continued)

— COPY —

— COPY —


5. The well shall be constructed by a driller licensed in the State of Idaho.
6. Approval of this drilling permit does not authorize trespass on the land of another party.
7. This drilling permit does not represent a right to divert and use the water of the State of Idaho.
8. If a bottom hole temperature of 85 F or greater is encountered, well construction shall cease and the well driller and the well owner shall contact the Department immediately.
9. If this permit is for a replacement well, the well being replaced must be abandoned in accordance with Department Rules and Regulations.

SPECIFIC CONDITIONS:

10. Diversion from this well is not authorized until the replaced well is properly abandoned.
11. The applicant shall submit an application for abandonment for the well being replaced.
12. Diversion from this well is not authorized until the transfer application has been approved.

This permit is issued pursuant to the provisions of Section 42-235, Idaho Code, Witness the signature of the Director, or his authorized agent, this

12th day of March, 1973.

 For:

DAVID R. TUTHILL JR.
R. Keith Higginson, Director

MANAGER
WESTERN REGIONAL OFFICE