

Comment Report

47-17441

1. jstanton 5/7/2007 9:50:20 AM Special Administration Area Notes

Comment: Special Administration Areas : Twin Falls GWMA

Exempt: N

Reason:

Doc Attached:

Explanation:

2. jstanton 5/7/2007 9:50:49 AM Additional Information Supporting Application

Comment: Residency affidavit for hydropower development: N/A

Additional hydropower project information: N/A

Additional fish propagation project information: N/A

Appropriation Rule 40.05.c information: N/A

Mitigation Plan or acceptance form: N/A

Evidence of Pre-1987 development: N/A

3. jstanton 5/7/2007 Comment/Analysis

Comment: This application covers the drilling of a backup well for the new hospital being built on the subject property. Twin Falls city water, which comes from both wells and springs, will provide the water for this facility whenever possible. A backup water supply is required in order for the hospital to operate, but would only be used in an emergency; the actual amount of water diverted from the well will be minimal. The well will be tested monthly to ensure proper functioning. The application does not request any water that is not already covered by existing rights and permits, so should be processible under the current moratoriums. The application appears to be approvable with proper conditions.

4. jstanton 5/7/2007 Legal Notice Remarks

Comment: This application covers the drilling of a new well for the new hospital to be built at the corner of Poleline Road and Grandview Drive. The well will provide an emergency backup water supply in case Twin Falls city water ever becomes unavailable.