

6/1/2007

[illegible]

Method of Determination:

3. ☐ Delivery System Diagram Attached (required). Indicate all major components and distances between components. Indicate weir size/pipe as applicable.
- ☒ Map Attached Showing Location(s) of point(s) of diversion and place(s) of use (required). Scale must be 1:24,000 or greater.
- ☐ Aerial Photo Attached (required for irrigation of 10+ acres).
- ☐ Photo of Diversion and System Attached

4.

<u>Well or Diversion ID No.*</u>	<u>Motor Make</u>	<u>Hp</u>	<u>Motor Serial No.</u>	<u>Pump Make</u>	<u>Pump Serial No. or Discharge Size</u>
		5hp			

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

<u>Measurement Equipment</u>	<u>Type</u>	<u>Make</u>	<u>Model No.</u>	<u>Serial No.</u>	<u>Size</u>	<u>Calib. Date</u>

2. Measurements:

E. FLOW CALCULATIONS☐ Additional Computation Sheets Attached

Measured Method:

calculation from Exam 25-7344

$$Q = \frac{5hp \times 8.814 \times .8 \text{ eff}}{200' \times 2.308 (35 \text{ psi})} = .13 \text{ CFS}$$

185'

from well log

F. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation:

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) =$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation season}) \times 1.9835 =$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} =$$

2. Volume Calculations for Other Uses:

2 homes x 1.2 AF/A = 2.40 AF
with
lawns

G. NARRATIVE/REMARKS/COMMENTS

well/pump to seven homes. 5 hp pump field examined on 25-7344.
this permit is for 2 additional homes

Have conditions of permit approval been met? ☒ Yes ☐ No

H. RECOMMENDATIONS

1. Recommended Amounts

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>DIVERSION RATE</u>	<u>ANNUAL VOLUME</u>
DOMESTIC	01/01 to 12/31	0.080 CFS	2.40 AF
<u>Totals:</u>		0.080 CFS	2.40 AF

2. Recommended Amendments

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☒ None

☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☐ Other

I. AUTHENTICATION


Field Examiner's Name DAVE CARLSON Date 6/1/2007

Reviewer _____ Date _____

49TH S

IN
38E
sec 1
NWNE
Lot 2

LOT 2
40.20



Place were
well is located,
WELL Location

MICHO
OCT 07 2003