

#194
Thomas McDewitt
CRP: CN #27
86-96
F-1
49.6 HEL

#194
T McDewitt
CRP: CN #27
86-96
F-2 HEL
70.9

R36E

T9S

CRP
CN #27 HEL
F-3 4.0

31 32

6 5

Lot 4

Lot 3

T10S

Lot 2

Lot 1

2
12.1

See H15B

1 HEL
52.4

POU in yellow
5

T
10
S



POD -> 6

29-08018

NA



POD

29-8018

1. DRILLING PERMIT NO. 29-94-E-097-001
Other IDWR No. 29-08018

2. OWNER:

Name Meadowbrook Ranch
Address 10053 S. Marsh Creek Road
City McLammon State ID Zip 83250

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



Twp. 10 North ☐ or South ☒
 Rge. 36 East ☒ or West ☐
 Sec. 5 $\frac{1}{4}$ SE $\frac{1}{4}$ SW $\frac{1}{4}$
 Gov't Lot _____ County Bannock

Address of Well Site _____
 City _____
 (Give at least name of road + Distance to Road or Landmark)

4. PROPOSED USE:

☐ Domestic ☐ Municipal ☐ Monitor ☒ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK

☐ New Well ☒ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD

☐ Mud Rotary ☐ Air Rotary ☒ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	

Was drive shoe used? ☐ Y ☐ N Shoe Depth(s) _____

Was drive shoe seal tested? Y ☐ N ☐ How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
16"	263	317	302	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations Method Machine
☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
60	110	3/8" x 3/4"	4/44			☒	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

53 ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ ft. Describe access port or
control devices:

11. WELL TESTS:

☒ Pump ☐ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
2,000 +	40	250	10:00 AM

Water Temp. _____ Bottom hole temp. _____

Water Quality test or comments:

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
16	263	265	Sandy gravel	X	
"	265	290	Gravel with layers of clay	X	
"	290	294	Sand	X	
"	294	296	gravel	XX	
"	296	300	muddy gravel	X	
"	300	308	pea gravel	xx	
"	308	318	big gravel with layers of clay	x	
"	318	325	Sandy gravel	xxx	

Gravel Packed Well
to 233

How: Was well filled with gravel from 325 to 283?

no annular space to back

RECEIVED

NOV 17 1994

NOV 03 1994

Department of Water Resource

Department of Water Resources
Eastern District Office

Completed Depth 283 (Measurable)
Date: Started Sept. 29, 94 Completed Oct. 27, 94

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name L.W. Frandsen & Sons Drilling Firm No. 354

Firm Official L. W. Frandsen Date 11-2-94

and
Supervisor or Operator Rickey Landrum Date Nov. 2, 94

(Sign once if Firm Official & Operator)