

10/1/03

Drilling Permit No. _____

Drilling Permit I.D. Tag No. D0045658

Water Right Permit No. _____

Injection Permit No. _____

State of Idaho
Department of Water Resources

RECEIVED

JAN 08 2007

APPLICATION FOR DRILLING PERMIT
(FOR THE CONSTRUCTION OF A WELL)

1. Owner (please print): BEAR LAKE GROUP, SAMS HOLLOW WATER Department of Water Resources Eastern Region

2. Mailing Address: 24 COUNTRY CLUB CIRCLE

City: TEQUESTA State: FL Zip Code: 33469 Telephone: (561) 743-6748

3. Proposed Well Location: Twp. 16 S, Rge. 43 E, Sec. 8 2, SE 1/4 SW 1/4 SW 1/4; per GPS + telecom

Gov't Lot No. _____ County BEAR LAKE Lat. 42 : 03 : 31.4 Long. 111 : 24 : 05.9

Street Address of Well Site 101 ASTER PLACE City St. Charles
Give at least name of road + Distance to Road or Landmark

Lot, block and subdivision LOT 56 PH. 4 THE RESERVE AT BEAR LAKE

4. Proposed Use of Well:

- ☐ DOMESTIC: The use of water for homes, organization camps, public campgrounds, livestock and for any other purpose in connection therewith, including irrigation of up to 1/2 acre of land, if the total use is not in excess of 13,000 gpd; or any other uses, if the total use does not exceed a diversion rate of 0.04 cfs and a diversion volume of 2500 gpd.

Domestic does not include water for multiple ownership subdivisions, mobile home parks, commercial or business establishments, unless the use does not exceed a diversion rate of 0.04 cfs and a diversion volume of 2500 gpd.

NON-DOMESTIC: ☐ Irrigation ☐ Municipal ☐ Industrial
☐ Livestock ☒ Test ☐ Other _____
 Type _____ Number Hd. _____ (Describe)

☐ INJECTION☐ MONITORING: A well bore schematic and map is required for each blanket permit. No. of proposed wells: _____

5. Well Construction Information:

A. ☒ New well ☐ Modify ☐ Replace

B. Proposed Casing Diameter _____ Proposed Maximum Depth 600 FT.

C. Anticipated bottom hole temperature:
☒ 85 F or less (Cold Water Well) ☐ 85 F to 212 F (Low Temp. Geo. Well) ☐ 212 F. or more (Geothermal Well)

6. Construction Start Date: JANUARY 15 20077. Anticipated Well Driller: TREASURE VALLEY DRILLING, JOHN POST Driller's Lic. No. 560

NOTE: The actual well driller must be identified prior to drilling.

8. Applicant's Signature: Alvin Hudson Date JAN 4 2007Address (if different than owner): 132 So. STATECity: PRESTON State: ID Zip Code: 83268 Telephone 208-852-1155Title: ENGINEER

(Owner, Firm Representative, Other)

ACTION OF THE DEPARTMENT OF WATER RESOURCES

This Permit is Approved

Date 8 January 2007

If approved, this permit authorizes the construction or modification of a well subject to the following conditions. **READ CAREFULLY!**

GENERAL CONDITIONS:

1. This drilling permit is valid for two (2) months from the above approval date for the start of construction and is valid for one(1) year from the approval date for completion of the well unless an extension has been granted.
2. This permit does not constitute an approval of the District Health Department or the Idaho Department of Health and Welfare, which may be required before construction of the well. All wells must be drilled a minimum distance of 100 feet from a drain field. Domestic and Public Water Supply wells must be drilled a minimum of 50 feet and 100 feet respectively from a septic tank.
3. The well shall be constructed by a driller currently licensed in the State of Idaho who must maintain a copy of the drilling permit at the drilling site.
4. Approval of this drilling permit does not authorize trespass on the land of another party.
5. This permit does not constitute other local, county, state or federal approvals, which may be required for construction of a well.
6. This drilling permit does not represent a right to divert and use the water of the State of Idaho. If the well being drilled is associated with approved water right(s) use of the well must comply with conditions of said water right(s).
7. If a bottom hole temperature of 85 or greater is encountered, well construction shall cease and the well driller and the well owner shall contact the Department immediately.
8. Idaho Code, S 55-2201 - 55-2210 requires the applicant and/or his contractors to contact "Digline" (DigLine is a one-call center for utility notification) not less than 2 working days prior to the start of any excavation for this project. The "DigLine" Number for your area is 1-800-342-1585.
9. Please be advised that this drilling permit should be considered and treated as a preliminary permit. If you are in disagreement with this preliminary permit you have fourteen (14) days of the service date of this permit to petition the Department for reconsideration pursuant to Section 67-5243, Idaho Code.
10. The well tag for the drilling permit/start card shall be securely and permanently attached to the well casing through welding or by the use of four closed end domed stainless steel pop rivets. The tag attachment will be done at the time of completion of the well, and prior to removing the drill rig from the drill site.

SPECIFIC CONDITIONS:

1. The well may be tested for 30 days after completion of the well.
2. If an application for permit, transfer, or amendment of permit is not received within 30 days of completion of the well it must be abandoned.
3. If the well is abandoned it must have the casing pulled. Once the casing is removed the well must be filled with bentonite from TD to land surface.
4. This well may not be used except testing without benefit of a water right.

Dennis M. Dunn
Signature of Authorized Department Representative

Sr Water Resource Agent
Title


Receipt No E032526 Received by [Signature] Fee \$75⁰⁰ Date 1-8-07

EXTENSION OF DRILLING PERMIT


Extension approved by _____ Approval Date _____

This extension expires: _____

The lat/long you provided was 42° 3' 31.400" N; 111° 24' 5.900" W
Here are the results:
SW quarter of the **SW** quarter of Section 2, Township 16S, Range 43E
 IDTM NAD83 coordinates: Easting=2715000; Northing=1209787



Choose the map-display background:



☐ Wells ☐ Water Rights ☐ Water Right Permits ☐ Adjudication Claims ☐ Adjudication Recommendations

* Positions of wells/headgates may be based upon the center of a quarter-quarter section; those obtained by GPS or survey are accurate.