

AFFIDAVIT OF PUBLICATION

STATE OF IDAHO }
County of Bonner, } ss.

.....Pete Thompson.....
being duly sworn, says that he is the publisher
of the PRIEST RIVER TIMES, a weekly newspaper printed and
published at Priest River, Bonner County, Idaho, and has been
continuously and uninterruptedly published in said County during
a period of 78 consecutive weeks prior to the first publication of
the annexed notice for publication, is a newspaper of general cir-
culation made up of at least eight pages of at least six columns
each, printed from typematter or stereotyped forms of at least
nineteen and three-fourths inches depth, has at least 1250 bona fide
subscribers living within said Bonner County, and is published at
regular weekly intervals. That the annexed is a true copy of the
notice for publication in the case of

Dept. of Water Resources #96-8419

as it was published in the regular and entire issue of said paper
for a period of ...two... consecutive weeks, commencing on
the ...8th... day of ...November..., 19.84.
and.....
ending on the ...15th... day of ...November..., 19.84.
and that said notice was published in said newspaper proper, and
not in supplement form.

Pete Thompson
.....

Subscribed and sworn to before me this
...19th... day of ...Nov... 1984.

Gary E. Winter
Notary Public for Idaho

Residing at Priest River, Idaho
Sandpoint,

NOTICE OF APPLICATION
FOR WATER RIGHT
The following application(s) have
been filed to appropriate the public
waters of the State of Idaho:
96-8419

HALL, ROGER C.
WHALEN, SHEILA
GENERAL DELIVERY, JACKSON,
WY 83001
Source: UNNAMED STREAM trib. to
SINKS
SPRINGS trib. to SINKS
Date Filed: 10/30/1984
Diversion Pt.: NWSW Sec 14 T 56N R
04W
Use: IRRIGATION (0.04 CFS)
DOMESTIC (0.04 CFS)
In: NWSW Sec 14 T 56N R 04W FOR 1
ACRES


The permit(s) will be subject to all
prior water rights. Protests must be
filed with the Director, Dept. of Water
Resources, 4055 Gov't. Way, Coeur
d'Alene, Id. 83814 on or before
NOVEMBER 26, 1984.

Ken Dunn, Dir.

Publ. PRT-Nov. 8, 15-2t 28

[Signature]
RECEIVED
NOV 20 1984
Department of Water Resources
Northern District Office

MICROFILMED



FIELD PICTURES


TAKEN

8/27/92

A2

98-08419


SPRING
BOX



CISTERN



SPIGOT



MISSOURI HERBARIUM

SEP 22 1994

State of Idaho
Department of Water Resources

WATER RIGHT LICENSE

WATER RIGHT NO. 96-08419

Priority: October 30, 1984

Maximum Diversion Rate:

0.02 CFS

Maximum Diversion Volume:

0.6 AF

This is to certify, that SHEILA WHALEN
ROGER C HALL

15839 14TH AVE NE
SEATTLE WA 98155

has complied with the terms and conditions
of the permit, issued pursuant to Application for Permit dated October 30, 1984; and
has submitted Proof of Beneficial Use on December 23, 1991. An examination indicates
that the works have a diversion capacity of .020 cfs of water from:

SPRING

tributary to SINKS

source, and a water right has been established as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>	<u>ANNUAL VOLUME</u>
DOMESTIC	01/01 to 12/31	0.02 CFS	0.6 AF

LOCATION OF POINT(S) OF DIVERSION:

NWNWSW , Sec. 14, Township 56N, Range 04W
BONNER County

PLACE OF USE: DOMESTIC

TWN RGE SEC

56N 04W 14


NWSW

CONDITIONS/REMARKS:

1. The maximum diversion volume is defined as the maximum allowable volume of water that may be diverted annually from the source under this right. The use of water confirmed by this right is limited to the amount which can actually be beneficially used. The maximum diversion volume may be adjusted to more accurately describe the beneficial use or to implement accepted standards of diversion and use efficiency.
2. This water right is appurtenant to the described place of use.
3. This right is subject to all prior water rights and may be forfeited by five years of non-use.
4. Modifications to or variance from this license must be made within the limits of Section 42-222, Idaho Code, or the applicable Idaho law.
5. Domestic use is for 1 home.

This license is issued pursuant to the provisions of Section 42-219, Idaho Code.
Witness the seal and signature of the Director, affixed at Boise, this 3RD
day of AUGUST, 1994.

SEP 22 1994

Acting for  R. Keith Higginson, Director

RECEIVED
DEC 23 1991

RECEIVED
STATE OF IDAHO JAN 02 1992

For Office Use Only
Amt. of Fee \$ 50.00
Date 1/2/92
Receipt No. CD 27831
Received by WLB

Department of Water Resources

DEPARTMENT OF WATER RESOURCES
Department of Water Resources
PROOF OF BENEFICIAL USE

The Idaho Department of Water Resources will consider this form as a statement that the permit holder(s) has/have completed all development that will occur under this permit and that water has been applied according to the provisions of the permit for the beneficial use(s) described below. This form must be accompanied by a license examination fee or a completed field examination report prepared by a certified water right examiner who has been appointed by the department.

Permit No. 96-08419 Telephone No. 206-362-5079

Name(s) of Permit Holder(s): ROGER C. HALL & Sheila Whalen

Post Office Address: 15839 14th Ave NE Seattle WA 98155

Source of Water: UNNAMED SPRINGS AND STREAM

If ground water, well driller's name: _____ Date drilled: _____

Extent of Use:
Domestic 1 (No. of households) Irrigation 1 (No. of acres)
Stockwater _____ (No. and type of stock) Other _____

Total rate and/or volume for which proof is submitted .04 cfs _____ acre/feet

Show date water was first diverted and beneficially used under this permit: August 24, 1991

One of the following may be a condition of approval of your permit:

Measuring device: Required? Yes ☒ No Installed? Yes ☐ No

OR

Flow Measurement Port: Required? Yes ☒ No Installed? Yes ☐ No

(NOT REQUIRED)
Fee Enclosed: \$ 0 (See License Examination Fee Schedule)

Person to contact to accompany the Department representative during the field examination:

ROGER HALL 206-362-5079
Name Telephone No.
15839 14th NE SEATTLE WA 98155
Address

The above information is my true statement of the extent to which the above numbered permit has been developed and I relinquish any undeveloped portion of the permit to the state of Idaho.

12/17/91 Roger C. Hall + Sheila Whalen
Date Signature (and title if on behalf of a company or organization)

RECEIVED
FEB 2 1992

RECEIVED

DEC 12 1989

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCESFor Office Use Only
\$15 FEE Received by C. Wong
Date 12/12/89
Receipt # 2013460

REQUEST FOR EXTENSION OF TIME

Department of Water Resources

To provide additional time in which to submit proof
of beneficial use for a water right permit

The Idaho Department of Water Resources will consider this form as a request that the permit holder(s) be granted an additional period of time in which to complete development of a water right under the provisions of Section 42-204, Idaho Code.

Permit No. 96-8419Name(s) of Permit Holder: ROGER C. HALL & SHEILA WHALENPost Office Address: 15839 14th AVE. NESEATTLE, WA 98155 Telephone No. 206-362-5079Date Proof is Due: January 1, 1990Describe what work has been completed toward the development of this water right: 1985 - PARTIALLY DUG
(This must be filled out! If no work has been completed, show "none".)

OUT AND COVERED SPRINGS TO PROTECT THEM TEMPORARILY, BOUGHT WATER PIPE.
1986 - HAD ROAD CLEARED TO BUILDING SITES. 1987 - CLEARED ROAD TO SPRING
SITES. 1988 - MEASURED HEAD AND RUN, BOUGHT MORE WATER
PIPE AND SOME FITTINGS. Costing \$ 350.00

The permit holder(s) has been unable to complete the remainder of the work for the following reasons:

WE ARE DOING THIS WORK DURING OUR SUMMER VACATION TIME. IN THE
SUMMER OF 1989 I HURT MY BACK AS MY VACATION TIME WAS COMING
UP AND I HAD TO SPEND MY VACATION RECUPERATING.

Permit holder(s) request an extension to JAN. 1, 1992.
(1 yr. minimum)Roger C. Hall + Sheila Whalen
(Signature)*

FEE: \$15.00

*IF OTHER THAN PERMIT HOLDER,
POWER OF ATTORNEY MUST BE SUPPLIED

ACTION OF THE DEPARTMENT OF WATER RESOURCES

MAR 26 1990

IT IS HEREBY ORDERED that the above request for extension of time be APPROVED and the time within which to submit proof of beneficial use is extended to January 1, 1992.

Signed this 2nd day of January, 1990.L. Glen Saylor
Chief, Water Allocation Bureau

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
APPLICATION FOR PERMIT

APPROVED

To appropriate the public waters of the State of Idaho

1. Name of applicant ROGER C. HALL & SHEILA WHALEN Phone 307-733-5260
Post office address GENERAL DELIVERY, JACKSON, WYOMING 83001
2. Source of water supply UNNAMED STREAM & SPRINGS which is a tributary of sinks*
3. Location of point of diversion is NW $\frac{1}{4}$ of SW $\frac{1}{4}$ of Section 14 Township 56N
Range 4W B.M. BONNER County, additional points of diversion if any: _____

*kw 12/18/1984

4. Water will be used for the following purposes:

- Amount .04 for domestic purposes from JAN 1 to DEC 31 (both dates inclusive)
(cfs or acre-feet per annum)
Amount 0.03 for IRRIGATION purposes from 3/15 to 11/15 pms per correspondence.
(cfs or acre-feet per annum) JAN 1 to DEC 31 (both dates inclusive)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)
Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per annum)

5. Total quantity to be appropriated:

- a. .04 cubic feet per second and/or b. _____ acre-feet per annum.

6. Proposed diverting works:

- a. Description of ditches, flumes, pumps, headgates, etc. 1" PLASTIC PIPE FROM
STREAM and/or SPRINGS TO CABIN SITES
b. Height of storage dam _____ feet, active reservoir capacity _____ acre-feet; total reservoir
capacity _____ acre-feet, materials used in storage dam: _____
Period of year when water will be diverted to storage _____ to _____ inclusive.
(Month/Day) (Month/Day)
c. Proposed well diameter is _____ inches; proposed depth of well is _____ feet.

7. Time required for the completion of the works and application of the water to the proposed beneficial
use is 5 years (minimum 1 year - maximum 5 years).

8. Description of proposed uses:

- a. If water is not for irrigation:
(1) Give the place of use of water: NW $\frac{1}{4}$ of SW $\frac{1}{4}$ of Section 14 Township 56N
Range 4W B.M.
(2) Amount of power to be generated: _____ horsepower under _____ feet of head.
(3) List number of each kind of livestock to be watered _____
(4) Name of municipality to be served _____, or number of families to be
supplied with domestic water 1.
(5) If water is to be used for other purposes describe: domestic

MICROFILMED

b. If water is for irrigation, indicate acreage in each subdivision in the tabulation below:

TWP	RANGE	SEC.	NE¼				NW¼				SW¼				SE¼				TOTALS
			NE¼	NW¼	SW¼	SE¼	NE¼	NW¼	SW¼	SE¼	NE¼	NW¼	SW¼	SE¼	NE¼	NW¼	SW¼	SE¼	
56N	4W	14										1							1

Total number of acres to be irrigated 1

c. Describe any other water rights used for the same purposes as described above. NONE


9. a. Who owns the property at the point of diversion SAME AS APPLICANTS

b. Who owns the land to be irrigated or place of use SAME AS APPLICANTS

c. If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing

10. Remarks

11. Map of proposed project: show clearly the proposed point of diversion, place of use, section number, township and range number.



Scale: 2 inches equal 1 mile.

BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

Roger C. Halp & Sheila Whalen
(Applicant)

MICROFILMED

Proposed Priority 10/30/84

MICROFILMED

Received by [signature] Date 10/30/84 Time 1:30 pm

Preliminary check by [signature] Fee \$ 30.00

Receipted by [signature] Date 10/31/84 (31670)

Publication prepared by [signature] Date 10/31/84

Published in Great River News

Publication dates 11/8 & 15/84

Publication approved [signature] Date 11/20/84

Protests filed by: None

Copies of protests forwarded by _____

Hearing held by _____ Date _____

Recommended for approval denial by [signature] kw

ACTION OF THE DIRECTOR, DEPARTMENT OF WATER RESOURCES

This is to certify that I have examined Application for Permit to appropriate the public waters of the State of Idaho No. 96-8419, and said application is hereby APPROVED.

1. Approval of said application is subject to the following limitations and conditions:

- a. SUBJECT TO ALL PRIOR WATER RIGHTS.
- b. Proof of construction of works and application of water to beneficial use shall be submitted on or before January 1, 19 90.
- c. The rate of diversion, if water is to be used for irrigation under this permit, when combined with all other water rights for the same land shall not exceed 0.02 cubic feet per second for each acre of land.
- d. Other:
Permit holder shall commence the excavation or construction of diverting works within one year of the date this permit is issued and shall proceed diligently until the project is complete.

Witness my hand this 3rd day of January, 1985.

[signature]
Chief, Operations Bureau

NOTICE OF APPLICATION
FOR WATER RIGHT
The following application(s) have
been filed to appropriate the public
waters of the State of Idaho:
96-8419

AFFIDAVIT OF PUBLICATION

STATE OF IDAHO }
County of Bonner, } ss.

.....Pete Thompson.....
being duly sworn, says that he is the publisher
of the PRIEST RIVER TIMES, a weekly newspaper printed and
published at Priest River, Bonner County, Idaho, and has been
continuously and uninterruptedly published in said County during
a period of 78 consecutive weeks prior to the first publication of
the annexed notice for publication, is a newspaper of general cir-
culation made up of at least eight pages of at least six columns
each, printed from typematter or stereotyped forms of at least
nineteen and three-fourths inches depth, has at least 1250 bona fide
subscribers living within said Bonner County, and is published at
regular weekly intervals. That the annexed is a true copy of the
notice for publication in the case of

Dept. of Water Resources #96-8419

as it was published in the regular and entire issue of said paper
for a period of ...two..... consecutive weeks, commencing on
the ...8th..... day of ...November....., 19. 84.
and.....
.....
ending on the ...15th..... day of November....., 19. 84.
and that said notice was published in said newspaper proper, and
not in supplement form.

.....Pete Thompson.....

Subscribed and sworn to before me this
...19th... day of Nov... , 19. 84.

.....Gaye E. Winter.....
Notary Public for Idaho

Residing at Priest River, Idaho
.....Gaye E. Winter.....

HALL, ROGER C.
WHALEN, SHEILA
GENERAL DELIVERY, JACKSON,
WY 83001
Source: UNNAMED STREAM trib. to
SINKS
SPRINGS trib. to SINKS
Date Filed: 10/30/1984
Diversion Pt.: NWSW Sec 14 T 56N R
04W
Use: IRRIGATION (0.04 CFS)
DOMESTIC (0.04 CFS)
In: NWSW Sec 14 T 56N R 04W FOR 1
ACRES

The permit(s) will be subject to all
prior water rights. Protests must be
filed with the Director, Dept. of Water
Resources, 4055 Gov't Way, Coeur
d'Alene, Id. 83814 on or before
NOVEMBER 26, 1984.

Ken Dunn, Dir.
Publ PRT-Nov. 8, 15-21 26

RECEIVED
NOV 15 1984

Department of Water Resources
Bureau of Water Rights

RECEIVED



State of Idaho

DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Statehouse Mail, Boise, Idaho 83720-9000

Phone: (208) 327-7900 FAX: (208) 327-7866

CECIL D. ANDRUS
GOVERNOR

R. KEITH HIGGINSON
DIRECTOR

August 3, 1994

SHEILA WHALEN
ROGER C HALL
15839 14TH AVE NE
SEATTLE WA 98155

RE: WATER RIGHT NO. 96-08419

Dear Water Right Holder(s):

Enclosed herewith is a copy of the Water Right License issued on the above referenced permit. If you have any questions, please contact me within 10 days of receipt of this license.

Sincerely,

A handwritten signature in black ink, appearing to be 'Jim Johnson', written over a horizontal line.

JIM JOHNSON, Manager
Water Right Permits Section

JJ:dc

Enclosure

RECEIVED

SEP 22 1994

LICENSE REVIEW
Cindy Zimmerman

Permit #: 96-8419 Name: Hall / Whalen Date: 7/25/94

	Yes	No	
NAME	☒	☐	Or Address Change? <u>15839 14th Ave Seattle WA 98155</u>
SOURCE	☐	☒	Change/Clarify source <u>spn/sinks</u>
	☐	☐	Prelim. Order to Void - <u>Source change.</u>
P/D	☐	☒	Amendment Needed? clarify? <u>no nwsu</u> -P39, P38
	☐	☒	Overlap(s) _____
P/U	☐	☒	Amendment Needed? reduce? <u>no irr found</u> -P41, P38
	☐	☒	Overlap(s) _____
			*P/D & P/U Amend? <u>P37, P38</u> (See list for feds.)
RATE	☒	☐	Measurement Done? <u>5 gal. in 30 seconds. = 10 gpm / 448.83 = 0.0223</u>
	☐	☒	Theoretical Only? _____
	☐	☒	Theoretical (HP) $\frac{8.8 \times 0.70 \times}{+ (2.31 \times \quad)} =$
	☒	☐	Capacity <u>0.02</u> cfs
			Allowable Amount: <u>0.02</u> cfs
VOLUME	☒	☐	Season of Use: <u>1/1 - 12/31</u> days
			Calculations: _____
			<u>domestic standard</u> = 0.6
			Flow limit: _____ x _____ x 1.9835 = _____ AF
			Allowable volume <u>0.6</u> AF
USES	☐	☒	Change(s) in Nature of Use? _____ -P46
	☐	☐	Amendment Needed? _____
REMARKS	☐	☒	Multiple p/d's in $\frac{1}{4}$? _____
	☒	☐	Other <u>Dom(1)</u>
CONDITIONS	☐	☒	Measuring/Locking Devices
	☐	☒	R04 Watermaster Control - Water District _____
	☐	☒	Irrigation Overlap
	☐	☒	Water Quality
	☐	☒	Other
PRIORITY	☒	☐	Correct fee submitted? Receipt No. <u>C022831</u> 1/2/92
	☐	☒	Order to Reinstate Needed? <u>Done?</u>
	☐	☒	Advance(d)? _____ Advanced to: _____
	☒	☐	App Rcd <u>10/30/84</u> Priority <u>10/30/84</u> Exam done <u>8/27/92</u>

COMMENTS: limited by measured capacity.

RECOMMENDED	CFS	DIV VOL	LICENSE: <u>P49</u>
<u>Dom/1</u>	<u>0.02</u>	<u>0.6</u>	#1 AMEND LTR: P46 or
			P39/P41/P37 & P38
TOTAL	<u>0.02</u>	<u>0.6</u>	#2 AMEND LTR: P42/P47

WR0749NP
No. L96-08419

IDAHO DEPARTMENT OF WATER RESOURCES
WATER RIGHT PROFILE REPORT

DATE: 07/25/94
PAGE: 1

OWNER CODE	NAME & ADDRESS	PRIORITY DATE	WATER USE	USE PERIOD FROM TO	DIVERSION RATE	DIVERSION VOLUME
C	SHEILA WHALEN	10/30/1984	DOMESTIC	01-01 12-31	0.02 CFS	0.60 AFA
C	ROGER C HALL					
	15839 14TH AVE NE					
	SEATTLE WA 98155					
				TOTAL DIVERSION:	0.02 CFS	0.60 AFA

Water Source: SPRING

Tributary to: SINKS

Stage: LICENSE

Point(s) of Diversion Capacity: 0.02 CFS

Point(s) of Diversion: T56N R04W S14 NWNWSW BONNER County

Place of use Legal Description for: DOMESTIC

				NE				NW				SW				SE							
T	R	S	:	NENE	NWNE	SWNE	SENE	:	NENW	NWNW	SWNW	SENW	:	NESW	NWSW	SWSW	SESW	:	NESE	NWSE	SWSE	SESE	:
			:	Lt	Ac	Lt	Ac	:	Lt	Ac	Lt	Ac	:	Lt	Ac	Lt	Ac	:	Lt	Ac	Lt	Ac	:
56N	04W	14	:					:					:					:					:
			:					:					:					:					:
			:					:					:					:					:

Pou County:

Other Water Rights Listing Overlapping Place(s) of use:
96-08419

Remarks: Domestic use is for 1 home.

Dates: App. Received: 10/30/1984 Priority Date: 10/30/1984
Proof Due Date: 01/01/1992 Proof Made Date: 12/23/1991
Exam Made Date: 08/27/1992 Exam Sent to S.O.: 06/30/1994
Licensed Date:

Misc: Water District Number: Field Exam Fee: R (Received)

Audit: 07/25/94 CZIMMER

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
BENEFICIAL USE FIELD REPORT

RECEIVED

JUN 30 1994

Department of Water Resources

A. GENERAL INFORMATION

Permit No. 96-08419

1. Owner: ROGER HALL Phone No. _____

Current Address: 15839 14th AVE., SEATTLE, WA. 98155

2. Accompanied by: ROGER HALL EXAM DATE: 8/27/92

Address: SAME Phone No. _____

Relationship to Permit Holder: OWNER

3. Source: SPRING tributary to SINKS

B. OVERLAP REVIEW

1. Other water rights with the same place of use: N/A

2. Other water rights with the same point of diversion: N/A

C. DIVERSION AND DELIVERY SYSTEM

1. Point(s) of Diversion:

Ident No.	Gov't Lot	1/4	1/4	1/4	Sec.	Twp.	Rge.	County	Method of Determination/Remarks
		NW	NW	SW	14	56N.	4W	BONNER	U.S.G.S. 7.5 min TOPO

2. Place(s) of Use:


Indicate Method of Determination U.S.G.S. TOPO

TWP	RGE	SEC	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
56N.	4W	14										D							

SEP 22 1994

BC

3. **Delivery System Diagram:** Indicate all major components and distances between components. Indicate weir size/ditch size/pipe i.d. as applicable.



Scale: 1" = _____

☒ Copy of USGS Quadrangle Attached Showing location(s) of point(s) of diversion and place(s) of use (required).

☐ Aerial Photo Attached (required for irrigation of 10+ acres)

☒ Photo of Diversion and System Attached

4.

Well or Diversion Identification No.*	Motor Make	Hp	Motor Serial No.	Pump Make	Pump Serial No. or Discharge Size

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calib. Date

2. Measurements: _____

SEP 22 1994

E. NARRATIVE/REMARKS/COMMENTS

WATER FLOWS FROM SPRING BOX THROUGH 1" PVC PIPE TO
60 GALLON RESERVOIR, FROM RESERVOIR, WATER FLOWS
THROUGH 1" PVC PIPE TO PLACE OF USE VIA GRAVITY FLOW.

Have conditions of permit approval been met? ☐ yes ☐ no

[Signature]

SEP 22 1994

F. FLOW CALCULATIONS

Additional Computation Sheets Attached

Measured Method: BUCKET / STOPWATCH

$$\frac{30 \text{ SEC.}}{60 \text{ SEC.}} = \frac{5 \text{ gal}}{\text{X}} = 10 \text{ GPM}$$

AB**G. VOLUME CALCULATIONS**

1. Volume Calculations for Irrigation:

 $V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) =$ _____ $V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation Season}) \times 1.9835 =$ _____ $V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} =$ _____

2. Volume Calculations for Other Uses:

H. RECOMMENDATIONS

1. Recommended Amounts

Beneficial Use	Period of Use		Rate of Diversion Q (cfs)	Annual Volume V (afa)
	From	To		
<u>DOMESTIC</u>	<u>01/01</u>	<u>12/31</u>	<u>0.02</u>	
Totals:			<u>0.02</u>	


2. Recommended Amendments

☐ Change P.D. as reflected above☒ Add P.D. as reflected above☐ None☐ Change P.U. as reflected above☒ Add P.U. as reflected above☐ Other**I. AUTHENTICATION**Field Examiner's Name ALLEN BEARDSLEE Date 8/27/92

Reviewer _____ Date _____

SEAL

SEP 22 1994



FIELD PICTURES


98-08419

TAKEN

8/27/92

AS


SPRING
BOX



CISTERN



SPRING



SEP 22 1994

91'80-8P

SD-0605-1

Idaho Department of Water Resources
Water Rights Point of Diversion Query

Date: 09/13/93

Time: 12:24:34

05917
W3047
59/12/8
24

741992
Y05

STATE

Township: 60N

Range : 04W

Section : 30

Tract : _____

Lot : _____



NO RECORDS FOUND...ENTER MENU OPTION AND/OR PRESS ENTER TO CONTINUE
(Enter=Run)

W3047

741992



January 8, 1992

ROGER C. HALL
SHEILA WHALEN
15839 14TH AVE. N.E.
SEATTLE WA 981550000

PROOF ACKNOWLEDGMENT LETTER

RE: PERMIT NO. 96-08419

Dear Permit Holder:

The department acknowledges receipt of the proof of beneficial use form submitted for the above referenced permit. The next step in the process of developing a water right is for the department to conduct a field examination to determine and confirm the use being made of the water.

If you have questions concerning this matter, please feel free to contact the NORTHERN Regional Office in Coeur D' Alene at (208)765-4639.

Sincerely,

Karen L. Gustafson
Secretary/Records Manager

c: IDWR - Region

RECORDED
FEB 12 1992



State of Idaho

DEPARTMENT OF WATER RESOURCES

1301 North Orchard Street, Statehouse Mail, Boise, Idaho 83720-9000

Phone: (208) 327-7900 FAX: (208) 327-7866

CECIL D. ANDRUS
GOVERNOR

R. KEITH HIGGINSON
DIRECTOR

December 26, 1991

Roger C. Hall
Sheila Whalen
15839 14th Avenue NE
Seattle, WA 98155

Re: Permit No. 96-08419

Dear Permit Holder:

Returned is the proof of beneficial use you submitted in connection with the above referenced permit.

The Department has determined that the permit holder must meet three requirements in order to be exempt from the license exam fee. They are:

1. The water right must use a groundwater source.
2. The rate of diversion must be .04 cfs or less.
3. The extent of use must be for one domestic household purpose only.

As you can see, you do not meet requirements #1 and #3 since you use a spring for your source and your extent of use is for irrigation as well as domestic. Therefore, a license examination fee of \$50 applies to your permit. In order to comply with the mandatory dates, please return the proof of beneficial use and the \$50 license exam fee within 30 days of the date of this mailing.

If you have any questions or if I can be of any further assistance, please feel to contact me.

Sincerely,

Karen L. Gustafson
Karen L. Gustafson
Secretary/Records Manager

FEB 12 1992

ROGER C. HALL
SHEILA WHALEN
15839 14TH AVE. N.E.
SEATTLE WA 981550000

138244
October 31, 1991

PROOF DUE NOTICE

RE: PERMIT NO. 96-08419

Dear Permit Holder:

One of the conditions of approval of the above referenced water permit was that proof of the extent of your beneficial use must be submitted to this office on or before January 1, 1992. (See last page of your approved permit or your last approved extension request.) Enclosed is a form which when accompanied by the license examination fee or a complete field examination report prepared by a certified water right examiner may be used to submit the required proof.

If you have not fully completed your project, and you or a previous owner of this permit have not received a prior extension of time, you may request an extension of time if the delay is for reasonable cause as provided in Section 42-204, Idaho Code. If you have been prevented from proceeding by a governmental agency or by litigation which might bring title to the water in question, more than one extension of time can be granted. An extension of time request form is enclosed for your convenience.

Either an acceptable proof of beneficial use submittal or an acceptable request for an extension of time must be received by this department on or before the above described proof due date. If neither is received, the department will send you a lapse notice. Within sixty (60) days of the mailing of the lapse notice, the permit will no longer be of any force nor effect.

SINCERELY,

Nina Shields
Secretary/Records Manager

Enclosures

NO FEE

RECORDED

FEB 12 1992

January 4, 1990

Roger C. and Shela Whalen
15839 14th Avenue N.E.
Seattle, WA 98155

Dear Mr. and Mrs. Whalen:

Re: Permit No. 96-8419

Enclosed is a copy of the approved request for extension of time. The time within which to submit proof of beneficial use is extended to January 1, 1992.

Note that the department has granted this extension based on due diligence. It is important that you work diligently toward the completion of this project during the construction period allowed. The department may not be able to grant additional requests.

If you have any questions concerning this matter, please feel free to contact this office.

Sincerely,

RITA I. FLECK
Secretary/Records Manager

Enclosure

MICROFILMED

MAR 26 1990

158863

October 31, 1989

ROGER C. HALL
SHEILA WHALEN
15839 14TH AVE. N.E.
SEATTLE, WA 981550000

PROOF DUE NOTICE

RE: PERMIT NO. 96-08419

Dear Permit Holder:

One of the conditions of approval of the above referenced water permit was that proof of the extent of your beneficial use must be submitted to this office on or before January 1, 1990. (See last page of your approved permit or your last approved extension request.) Enclosed is a form which when accompanied by the license examination fee or a complete field examination report prepared by a certified water right examiner may be used to submit the required proof.

If you have not fully completed your project, and you or a previous owner of this permit have not received a prior extension of time, you may request an extension of time if the delay is for reasonable cause as provided in Section 42-204, Idaho Code. If you have been prevented from proceeding by a governmental agency or by litigation which might bring title to the water in question, more than one extension of time can be granted. An extension of time request form is enclosed for your convenience.

Either an acceptable proof of beneficial use submittal or an acceptable request for an extension of time must be received by this department on or before the above described proof due date. If neither is received, the department will send you a lapse notice. Within sixty (60) days of the mailing of the lapse notice, the permit will no longer be of any force nor effect.

SINCERELY,

Rita Fleck
Secretary/Records Manager

Enclosures

MicroFILMED

MAR 26 1990

96- 8419

RECEIVED

OCT 06 1989

Water Dept.,

10/3/89

Department of Water Resources

We wish to inform you of our new address as we understand that the term of our water development permit expires on January 1, 1990. We also understand that you must send us some paperwork prior to this date. Our new address is: 15839 14th AVE NE.
Seattle, WA. 98155

Thank you,

Mr. Roger C. Hall

Computer updated 10/6/89
SA

MICROFILMED

MAR 26 1990

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
COMMENCEMENT OF WORKS

Permit No. 96-8419

Name(s) of Permit Holder(s): ROGER C. HALL & SHEILA WHALEN

Post Office Address: BOX 3267 JACKSON, WYO 83001

Tel. No. 733-5260

☒ I hereby certify that construction of diversion works on the above referenced permit began on 8/10/85 (date) and I understand that I must continue to develop the water system with due diligence to maintain a valid permit.

☐ I hereby certify that construction of diverting works on the above referenced project has not yet begun due to the following reason beyond my control:


*Note: A financing difficulty is not an acceptable reason.

Date

Signature of Permit Holder

Oct 24, 1985 Roger C. Hall & Sheila Whalen

Roger Hall & Sheila Whalen
Box 3267
Jackson, Wyo, 83001



MICROFILMED

MAR 26 1990

IDAHO DEPARTMENT OF WATER RESOURCES
STATEHOUSE
BOISE, IDAHO 83720

RECEIVED

DEC 11 1986

INTER-DEPARTMENT MEMO — 1

FROM Pat

Department of Water Resources

DATE

12/4/86

TO Bert

→ Cheryl

SUBJECT Address Change - 96-8419 HALL

The new address for the above-referenced water right is:

Box 356
LaCledde, Idaho 83841

Please change the computer's records.


THANKS!!

How do you like your new boss???

MICROFILMED

MAR 26 1990

entered 12/18/86
CW



SIGNATURE

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES

STATEHOUSE
BOISE, IDAHO 83720
(208) 334-4440

HALL, ROGER C.
GENERAL DELIVERY
JACKSON, WY 83001

JANUARY 10, 1985

RE: PERMIT NO. 96-8419

DEAR PERMIT HOLDER:

ENCLOSED IS A COPY OF YOUR APPROVED APPLICATION FOR PERMIT. WE DIRECT YOUR ATTENTION TO THE CONDITIONS OF APPROVAL ON THE FOURTH PAGE.

THE 1982 IDAHO LEGISLATURE ADDED A REQUIREMENT THAT AS A PERMIT HOLDER YOU MUST COMMENCE THE EXCAVATION OR CONSTRUCTION OF DIVERTING WORKS WITHIN ONE YEAR OF THE DATE THE PERMIT WAS ISSUED, AND YOU MUST PROCEED DILIGENTLY UNTIL THE PROJECT IS COMPLETED. THE ENCLOSED BLUE CARD MUST BE COMPLETED AND RETURNED TO THIS OFFICE AS SOON AS YOU COMMENCE CONSTRUCTION, NO LATER THAN ONE YEAR FROM THE DATE THE PERMIT WAS APPROVED.

WE HAVE ENCLOSED INSTRUCTIONS ENTITLED "MAKING PROOF OF BENEFICIAL USE". PLEASE READ THE INSTRUCTIONS CAREFULLY SINCE YOU MUST TAKE FURTHER ACTION TO DEVELOP THIS PERMIT INTO A LICENSE.

SINCERELY,

DAVID R. TUTHILL, JR., P.E.
SUPERVISOR, WATER ALLOCATION SECTION

ENCLOSURE

MICROFILMED

96-8419

HALL, ROGER C.
WHALEN, SHEILA

GENERAL DELIVERY, JACKSON, WY 83001

Source: UNNAMED STREAM trib. to SINKS
SPRINGS trib. to SINKS

Date Filed: 10/30/1984

Diversion Pt: NWSW Sec 14 T 56N R 04W D.D.3

Use: IRRIGATION
DOMESTIC

(0.04 CFS)
(0.04 CFS)

In: NWSW Sec 14 T 56N R 04W FOR 1 ACRES

*a changed period
from 3/15/84
to 11/15*

11/21/84

UNRECORDED

Dear Mr. Haynes,

General Delinery
Jackson, Wyo. 83001
November 12, 1984

This letter is in reference to your letter of Oct. 31 informing us that we had applied for too much irrigation water and had the dates wrong also. Please feel free to change our irrigation amount to 0.02 CFS and also to change the irrigation period to show March 15 to November 15. Thank you for bringing this error to our attention.

Sincerely,

Mr. Roger Hall

RECEIVED

NOV 15 1984

Department of Water Resources
Northern District Office

MICROFILM



STATE OF IDAHO DEPARTMENT OF WATER RESOURCES

NORTHERN REGION

A. Kenneth Dunn
Director

Suite No. 9
4055 Government Way
Coeur d'Alene, Idaho 83814
(208) 667-6484

October 31, 1984

Mr. Roger C. Hall
General Delivery
Jackson, Wyo. 83001

Re: 96-8419

Dear Mr. Hall:

During a review of your application for permit, it was discovered that you have applied for 0.04 CFS of water (approx. 18 gpm) for irrigation. You also requested the period of use for irrigation to be from January 1 to December 31.

^{.03}
This amount is excessive for the intended use and our Department will take steps to reduce the amount to 0.02 CFS which is approx. 9 gpm, unless you can prove to the Director's satisfaction that the excess water is needed. The Department will also change the period of use for irrigation to show March 15 to November 15, since that is the normal irrigation season.

If we do not hear from you within 20 days, we shall reduce your amount of water to the normal amount for irrigation which is 0.02 CFS and change the period of use to the normal irrigation season.

^{.03}
If you have any questions, please contact us.

Sincerely,

ROBERT G. HAYNES, P.E.
Regional Supervisor

pms

MICROFILMED