

RECOMMENDATION OF WATERMASTER

Application No: 36-16440 and 36-16441
Applicant Name: Jerome Joint School District

Watermaster's Recommendation:

- a) ☐ I do not oppose approval of this application
- b) ☒ I do not oppose approval of this application if it is conditioned as follows:

as drafted, but with the following additions and modifications to condition R07:

This right authorizes a non-consumptive use of water only. All water diverted under this right must remain in a closed-loop system, and all flows shall be injected back into the ESPA at a rate of injection which is equal to the diversion rate. The injection well must be authorized by a separate injection well permit.

Flows diverted under this right shall not be impounded or stored on the surface. Used flows may not be used for any other purpose unless another authorized right is obtained.


- c) ☐ I oppose approval of this application(s) for the following reasons:
- d) ☒ Additional comment:

Per Jeff's concern, there is diversion rate documentation in each file. Gary Burkett, EHM Engineers, in a telephone conversation of 10-23-2006, indicates that one injection well has been drilled and tested, and that the physical rate of injection will equal or exceed the anticipated diversion rates.

I would still like to see the above conditions placed on the permit so that the non-consumptive requirements of this permit are crystal clear.

Dated: October 23, 2006

Water District 130



Cindy J Yenter, Watermaster