

MEMORANDUM

Date: July 19, 2006
To: Water Right File 21-12849
From: eretelle
Re: license review

WD 01
No overlaps

Field exam indicates there are only 13 homes constructed (or partially constructed) and the other 12 lots are not stubbed in.

We are not issuing this as a municipal right because (1) the entity is not registered with the secretary of state and (2) they are not being regulated by DEQ as a public water supply. DEQ says they were regulated for 1 summer in the early 90s, but have not been since. With only 13 homes, they fall just under the threshold of 15 service connections (or 25 people per day).

The ArcView shape has been changed to reflect which lots were developed at the time of the field exam. They will need another water right for the additional homes.

Recommend approval.