

11. Map of proposed project: show clearly the proposed point of diversion, place of use, section number, township and range number.



Scale: 2 inches equal 1 mile.

BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

George Wilson  
(Applicant)

George Wilson, Mayor  
City of Genesee

# SECTION II - THE WATER SYSTEM

Page 5

(See Accompanying Map of Water System Dated June 30, 1973)

## A. THE EXISTING WATER SYSTEM.

### (1) Water Supply.

Water is supplied to the City from 4 wells as follows:-

| Well                                        | Location & Description                                                                                                                                                 | Discharge  |
|---------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|
| Old City Well No. 1                         | Old Pumping Station @ Laurel & Chestnut<br>180 - 190 Feet Deep. 7½ H.P. Turbine.                                                                                       | 55 G.P.M.  |
| Old City Well No. 2                         | Old Pumping Station @ Laurel & Chestnut.<br>180 - 190 Feet Deep. 15 H.P. Turbine.                                                                                      | 160 G.P.M. |
| New City Well No. 3                         | New Pumping Station on East Side of Old<br>Pumping Station. 12" Hole x 160 Feet<br>Deep. 20 H.P. Turbine. Tested to 275 GPM<br>With 25' Drawdown When Drilled 12/4/63. | 200 G.P.M. |
| Luedke Well.....                            | Just off of Road to Cemetery East of the<br>City. Reported 190' Deep. 3 H.P. Pump.<br>Purchased by City from John Luedke to<br>Supplement Supply.                      | 50 G.P.M.  |
| Total Supply With All Pumps Operating ..... |                                                                                                                                                                        | 465 G.P.M. |

THEORETICAL Q =  $\frac{EFF\% (H.P.)}{TL}$  8.8  
 81 G.P.M.  
 168 G.P.M.  
 251 G.P.M.  
 32 G.P.M.  
 532.5 G.P.M.

EFF% = 80  
 TL = 4' + 2.5' (min)  
 PSI = 40

J.S.  
7-19-82

MICROFILMED

St. Pond

Creek

MEADOWLAND

86-7120

300,000 gal Reservoir

250,000 gal Reservoir

St. Marys Cem

St. Johns Cemetery

GENESSEE

Boilers

Cow

1283

Sewage Disposal

Stock Pond

RESERVATION

State of Idaho  
Department of Water Resources

WATER RIGHT LICENSE

License of Water Right No. 87-7151 ~~86-7120~~ Priority March 2, 1981 Amount 1.04 cfs

THIS IS TO CERTIFY, that City of Genesee  
of Genesee, Idaho, has complied with the terms and conditions of Permit  
No. 86-7120 issued pursuant to Application for Permit dated March 2, 1981,  
and has submitted proof to the Department of Water Resources on July 28, 1981,  
that he has applied water to a beneficial use; an examination by the Department indicates that the works have a  
capacity for the diversion of 1.04 cfs of water from a groundwater source,  
tributary to \_\_\_\_\_, and that the permit holder has applied to a beneficial use and  
established a right to use water as follows:

| Beneficial Use   | Period of Use                                                                 | Rate of Diversion | Annual Volume |
|------------------|-------------------------------------------------------------------------------|-------------------|---------------|
| <u>Municipal</u> | from <u>January 1</u> to <u>December 31</u> at <u>1.04</u> cfs and <u>N/A</u> |                   |               |
|                  | from _____ to _____ cfs and _____                                             |                   |               |
|                  | from _____ to _____ at _____ cfs and _____                                    |                   |               |

(both dates inclusive)

Subject, however, to the condition that no more than 1.04 cfs of water be diverted at any one time, and  
that the amount of water so diverted and to which such right is entitled and confirmed is for the purpose  
aforementioned and is limited to the amount which can actually be beneficially used and shall not exceed  
N/A acre feet per year, said waters to be diverted within the NW $\frac{1}{4}$ SE $\frac{1}{4}$ , Section 13, (3 Points)  
SW $\frac{1}{4}$ NE $\frac{1}{4}$ , Section 14, Twp. 37N, Rge. 5W in the County of Latah

Description and location of place of use:

| Twp. | Range | Sec. | NE $\frac{1}{4}$ |                  |                  |                  | NW $\frac{1}{4}$ |                  |                  |                  | SW $\frac{1}{4}$ |                  |                  |                  | SE $\frac{1}{4}$ |                  |                  |                  | Totals |
|------|-------|------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|--------|
|      |       |      | NE $\frac{1}{4}$ | NW $\frac{1}{4}$ | SW $\frac{1}{4}$ | SE $\frac{1}{4}$ | NE $\frac{1}{4}$ | NW $\frac{1}{4}$ | SW $\frac{1}{4}$ | SE $\frac{1}{4}$ | NE $\frac{1}{4}$ | NW $\frac{1}{4}$ | SW $\frac{1}{4}$ | SE $\frac{1}{4}$ | NE $\frac{1}{4}$ | NW $\frac{1}{4}$ | SW $\frac{1}{4}$ | SE $\frac{1}{4}$ |        |
|      |       |      |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |        |
|      |       |      |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |        |
|      |       |      |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |        |
|      |       |      |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |        |
|      |       |      |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |        |
|      |       |      |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |        |
|      |       |      |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |        |
|      |       |      |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |        |
|      |       |      |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |                  |        |

Total number of acres irrigated \_\_\_\_\_

NOTE: Modifications to or variance from this license must be made within the limits of Section 42-222, Idaho Code, or the applicable Idaho Law. This right may be forfeited by five years of non-use.

The right to the use of the water hereby confirmed is restricted and appurtenant to the lands or place of use  
in described, and is subject to all prior water rights, as provided by the laws of Idaho.

Witness the seal and signature of the Director, affixed at Boise, Idaho, this 28<sup>th</sup> day of  
June \_\_\_\_\_, 19 83.

Director

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES  
APPLICATION FOR PERMIT

APPROVED

To appropriate the public waters of the State of Idaho

1. Name of applicant City of Genesee Phone \_\_\_\_\_

Post office address P. O. Box 38 Genesee, Idaho 83832

2. Source of water supply Groundwater which is a tributary of \_\_\_\_\_

3. Location of point of diversion is 3 POINTS  
SW  $\frac{1}{4}$  of NE  $\frac{1}{4}$  of Section 14 Township 37N

Range 5W B.M. Latah County, additional points of diversion if any: \_\_\_\_\_

NWSE, Sec. 13, T37N, R5W.

4. Water will be used for the following purposes:

Amount 1.04 for Municipal purposes from 1/1 to 12/31 (both dates inclusive)  
(cfs or acre-feet per annum)

Amount \_\_\_\_\_ for \_\_\_\_\_ purposes from \_\_\_\_\_ to \_\_\_\_\_ (both dates inclusive)  
(cfs or acre-feet per annum)

Amount \_\_\_\_\_ for \_\_\_\_\_ purposes from \_\_\_\_\_ to \_\_\_\_\_ (both dates inclusive)  
(cfs or acre-feet per annum)

Amount \_\_\_\_\_ for \_\_\_\_\_ purposes from \_\_\_\_\_ to \_\_\_\_\_ (both dates inclusive)  
(cfs or acre-feet per annum)

5. Total quantity to be appropriated:

a. 1.04 cubic feet per second and/or b. \_\_\_\_\_ acre-feet per annum.

6. Proposed diverting works:

a. Description of ditches, flumes, pumps, headgates, etc. \_\_\_\_\_

4 wells with pump and pipeline

b. Height of storage dam \_\_\_\_\_ feet, active reservoir capacity \_\_\_\_\_ acre-feet; total reservoir capacity \_\_\_\_\_ acre-feet, materials used in storage dam: \_\_\_\_\_

Period of year when water will be diverted to storage \_\_\_\_\_ to \_\_\_\_\_ inclusive.

c. Proposed well diameter is SEE ITEM #10. inches; proposed depth of well is \_\_\_\_\_ feet.  
(Month/Day) (Month/Day)

7. Time required for the completion of the works and application of the water to the proposed beneficial use is 5 years (minimum 1 year — maximum 5 years). Application is for existing wells.

8. Description of proposed uses:

a. If water is not for irrigation: WITHIN THE CITY LIMITS OF GENESEE.  
(1) Give the place of use of water: \_\_\_\_\_  $\frac{1}{4}$  of \_\_\_\_\_  $\frac{1}{4}$  of Section \_\_\_\_\_ Township \_\_\_\_\_

Range \_\_\_\_\_ B.M.

(2) Amount of power to be generated: \_\_\_\_\_ horsepower under \_\_\_\_\_ feet of head.

(3) List number of each kind of livestock to be watered \_\_\_\_\_

(4) Name of municipality to be served Genesee, or number of families to be supplied with domestic water \_\_\_\_\_

(5) If water is to be used for other purposes describe: \_\_\_\_\_

Municipal use including approximately 50 acres of irrigation.

MICROFILMED

**RECEIVED**

[illegible]

Total number of acres to be irrigated

c. Describe any other water rights used for the same purposes as described above.

9. a. Who owns the property at the point of diversion  
City of Genesee

b. Who owns the land to be irrigated or place of use

c. If the property is owned by a person other than the applicant, describe the arrangement enabling the

applicant to make this filing

10. Remarks

~~Well #1 - SWNE, Sec. 14, 20 h.p. turbine pump in 12" x 160' well.~~

Well #2 - SWNE, Sec. 14, 15 h.p. turbine pump in 10' x 190' well


~~Well #3 - SWNE, Sec. 14, 7.5 h.p. turbine pump in 10' x 190' well~~

~~Well #4 - NWSE, Sec. 13, 3 h.p. pump in 8" x 190' well.~~

NOTE: Size of hole for wells #2, #3 and #4 are estimated.

are estimated.

11. Map of proposed project: show clearly the proposed point of diversion, place of use, section number, township and range number.



Scale 2 inches equal 1 mile.

BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

*George Wilson*

(Applicant)  
George Wilson, Mayor  
City of Genesee

MICROFILMED

Proposed Priority 3/2/81

Received by ms Date 3/18/81 Time 12:34pm  
Preliminary check by JB Fee \$ 65.00  
Received by ms Date 3/2/81 (1834)  
Publication prepared by ms Date 3/6/81  
Published in Rocky Mountain  
Publication dates 4/2-9/81  
Publication approved ms Date 4/13/81  
Protests filed by: none  
Copies of protests forwarded by \_\_\_\_\_  
Hearing held by \_\_\_\_\_ Date \_\_\_\_\_  
Recommended for approval denial by ms ms

ACTION OF THE DIRECTOR, DEPARTMENT OF WATER RESOURCES

This is to certify that I have examined Application for Permit to appropriate the public waters of the State of Idaho No. 86-7120, and said application is hereby approved.

1. Approval of said application is subject to the following limitations and conditions:

a. SUBJECT TO ALL PRIOR WATER RIGHTS.

b. Proof of construction of works and application of water to beneficial use shall be submitted on or before May 1, 19 86.

c. The rate of diversion, if water is to be used for irrigation under this permit, when combined with all other water rights for the same land shall not exceed 0.02 cubic feet per second for each acre of land.

d. Other: An access port or other device as specified by the Department shall be

installed by the permit holder to provide for the installation of measuring

equipment and the determination of the rate of diversion by the Department

(2) The issuance of this permit in no way grants any right-of-way or easement

across the land of another.

Witness my hand this 13<sup>th</sup> day of May, 19 81.

D. Munson  
Chief of Bureau

# Affidavit of Publication

STATE OF IDAHO }  
County of Latah } ss.

Ray Rosch

being first duly sworn, on oath,  
deposes and says:

That he is the printer of The DAILY IDAHONIAN, a newspaper of general circulation, printed and published daily except Sunday at Moscow, Latah County, Idaho, in compliance with Sections 60-106, 60-107, and 60-108 of the Idaho Code and the amendments thereto; that the notice of which the annexed is a full, true and correct printed copy was published in the regular and entire issues of said newspaper and not in a supplement thereto, upon the following

dates: APRIL 2, 9,  
1981

the same being the dates designated for the publication of said legal notice.

Ray Rosch  
Subscribed and sworn to before  
me this 9th day of April

1981

Carol Fleener

Notary Public,  
residing at Moscow, Idaho

## NOTICE OF APPLICATION FOR WATER RIGHT

Notice is hereby given that the following application(s) have been submitted for permit to appropriate the public water of the State of Idaho:

86-7120

CITY OF GENESEE

P.O. BOX 38, GENESEE, ID 83832

Source: GROUNDWATER

Date Filed: 03/18/1981

Amount: 1.04 CFS

Diversion Point: SWNE Sect 14 T 37N R 05W NWSE Sec 13 T 37N R 05W, LATAH Co.

Use: MUNICIPAL (1.04 CFS) from 01/01 to 12/31

Diversion Means: 4 WELLS, PUMP AND PIPELINE.

Place of Use: Located within City Limits of Genesee.

If issued, the permit(s) will be subject to all prior water rights. Protests against the granting of any permit must be filed with the Director of the Idaho Department of Water Resources, 4055 Gov't Way, Coeur d'Alene, Id, 83814, on or before APRIL 20, 1981.

C. STEPHEN ALLRED

Director

Apr. 2, 9, 1981

OK  
4/13/81

APR 13 1981

Idaho Department of Water Resources  
Coeur d'Alene Office

# RECEIVED

Form 238-7  
3/95

FEB 25 1996

IDAHO DEPARTMENT OF WATER RESOURCES

POSTAL

## WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

Office Use Only  
Inspected by \_\_\_\_\_  
Twp \_\_\_\_\_ Rge \_\_\_\_\_ Sec \_\_\_\_\_  
1/4 \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4 \_\_\_\_\_  
Lat: \_\_\_\_\_ Long: \_\_\_\_\_

NORTHERN REGION  
IDWR

1. DRILLING PERMIT NO. 87-93-N-39-000  
Other IDWR No. 87-07151 & 87-07150

### 2. OWNER:

Name City of Genesee  
Address Genesee  
City Genesee State Id Zip \_\_\_\_\_

### 3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

|  |  |  |  |
|--|--|--|--|
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |

Twp. 37 North ☒ or South ☐  
Rge. 5 East ☐ or West ☐  
Sec. 14 1/4 NW 1/4 NE 1/4  
Gov't Lot \_\_\_\_\_ County Latah  
Lat: North Long: \_\_\_\_\_  
Address of Well Site End of Latah  
City Latah  
Street West of Latah  
Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

### 4. USE:

☐ Domestic ☒ Municipal ☐ Monitor ☐ Irrigation  
☐ Thermal ☐ Injection ☐ Other \_\_\_\_\_

### 5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other \_\_\_\_\_

### 6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other \_\_\_\_\_

### 7. SEALING PROCEDURES

| SEAL/FILTER PACK |           | AMOUNT    |                 | METHOD      |
|------------------|-----------|-----------|-----------------|-------------|
| Material         | From      | To        | Sacks or Pounds |             |
| <u>Grout</u>     | <u>-3</u> | <u>41</u> |                 | <u>pump</u> |

Was drive shoe used? ☐ Y ☐ N Shoe Depth(s) \_\_\_\_\_  
Was drive shoe seal tested? ☐ Y ☐ N How? \_\_\_\_\_

### 8. CASING/LINER:

| Diameter   | From      | To         | Gauge      | Material     | Casing                              | Liner                    | Welded                              | Threaded                 |
|------------|-----------|------------|------------|--------------|-------------------------------------|--------------------------|-------------------------------------|--------------------------|
| <u>12"</u> | <u>+2</u> | <u>130</u> | <u>250</u> | <u>steel</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <u>10"</u> | <u>+2</u> | <u>430</u> | <u>250</u> | <u>steel</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

### 9. PERFORATIONS/SCREENS

☐ Perforations Method \_\_\_\_\_  
☐ Screens Screen Type \_\_\_\_\_

| From | To | Slot Size | Number | Diameter | Material | Casing                   | Liner                    |
|------|----|-----------|--------|----------|----------|--------------------------|--------------------------|
|      |    |           |        |          |          | <input type="checkbox"/> | <input type="checkbox"/> |
|      |    |           |        |          |          | <input type="checkbox"/> | <input type="checkbox"/> |

### 10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

608 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

NWNE 14 37N 5W

FORWARD WHITE COPY TO WATER RESOURCES

### 11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

| Yield gal/min. | Drawdown | Pumping Level | Time |
|----------------|----------|---------------|------|
| <u>25 gpm</u>  |          |               |      |

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_

Water Quality test or comments: \_\_\_\_\_

Depth first Water Encountered 775

### 12. LITHOLOGIC LOG: (Describe repairs or abandonment)

| Bore Dia. | From | To  | Remarks: Lithology, Water Quality & Temperature | Y | N                                   |
|-----------|------|-----|-------------------------------------------------|---|-------------------------------------|
| 16"       | 0    | 118 | Clay                                            |   | <input checked="" type="checkbox"/> |
| 12"       | 118  | 134 | Dark basalt                                     |   | <input checked="" type="checkbox"/> |
| 12"       | 134  | 140 | Hard Medium basalt                              |   | <input checked="" type="checkbox"/> |
| 12"       | 140  | 157 | Gray basalt                                     |   | <input checked="" type="checkbox"/> |
| 12"       | 157  | 163 | Black basalt                                    |   | <input checked="" type="checkbox"/> |
| 12"       | 163  | 178 | Gray basalt M                                   |   | <input checked="" type="checkbox"/> |
| 12"       | 178  | 190 | shale with basalt                               |   | <input checked="" type="checkbox"/> |
| 12"       | 190  | 197 | Black basalt                                    |   | <input checked="" type="checkbox"/> |
| 12"       | 197  | 210 | Brown basalt                                    |   | <input checked="" type="checkbox"/> |
| 12"       | 210  | 240 | Gray basalt                                     |   | <input checked="" type="checkbox"/> |
| 12"       | 240  | 277 | med brown basalt                                |   | <input checked="" type="checkbox"/> |
| 12"       | 277  | 367 | Black basalt                                    |   | <input checked="" type="checkbox"/> |
| 12"       | 367  | 428 | Light gray basalt                               |   | <input checked="" type="checkbox"/> |
| 6"        | 428  | 530 | Dark gray                                       |   | <input checked="" type="checkbox"/> |
| 6"        | 530  | 825 | green sand basalt                               |   | <input checked="" type="checkbox"/> |

RECEIVED

AUG 22 1996

Department of Water Resources

Completed Depth 825 (Measurable)  
Date: Started 10-22-93 Completed 1-28-94

### 13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Whitcomb Drilling Firm No. 123

Firm Official Ray Whitcomb Date Jan 20, 96

and Supervisor or Operator Ann Whitcomb Date Jan 20, 96

(Sign once if Firm Official & Operator)

86-7120

February 11, 1981

City of Genesee  
P. O. Box 38  
Genesee, Idaho 83832

Gentlemen:

We are returning your Application for Permit for the statutory filing fee of \$45.00 and clarification of the point of diversion (well location).

In Item No. 33, you have indicated the point of diversion as being within the SESW, yet the map shows the well within the NESW. Please clarify this discrepancy and return the application and fee to this Department.

If you have any questions, please contact me at this office.

Sincerely,

TOM D. KING  
Senior Water Resource Agent

TDK/pms

Enc. - Application

MICROFILMED

July 1, 1983


City of Genesee  
P.O. Box 38  
Genesee, ID 83832

Re: No. 86-7120  
9

Gentlemen

Enclosed herewith is a copy of the Water Right License issued on the above referenced Permit.

Sincerely,



JIM JOHNSON  
Water Distribution Supervisor

JJ:kw  
Enclosure

MICROFILMED

86-4120

**richard wyatt engineering inc**

OCT 15 1982

101 THAIN ROAD

October 8, 1982

State of Idaho  
Department of Water Resources  
State Office  
450 W. State Street  
Boise, ID 83720

Dear Sir:

Would you please change our address on your mailing list to read as follows:

R W Engineering, Inc.  
Consulting Engineers  
101 Thain Road  
Lewiston, ID 83501

Thank you.

Sincerely yours,

R W ENGINEERING, INC.

*Richard Wyatt (g)*  
Richard Wyatt, P.E.

RW:g

MICROFILMED

**consulting  
engineers**

208 / 746-2661  
101 THAIN ROAD

LEWISTON, IDAHO 83501

CALCULATION CHECK using information  
provided by Larry W. Lindstrom P.E. on 7-1-82.

Well No. 1

$$Q = \frac{\text{eff (8.8) HP}}{T_L} = \frac{.8(8.8) 7.5}{T_L} = 72.2 \text{ gpm}$$

$$T_L = 190 + 2.3(60)^* = 328$$

Well No. 2

$$Q = \frac{.8(8.8) 15}{T_L} = \frac{105.6}{190 + 2.3(60)} = 144 \text{ gpm}$$

Well No. 3

$$Q = \frac{.8(8.8) 24}{T_L} = \frac{169}{\frac{298}{163} (160 + 2.3(60))} = 254 \text{ gpm}$$

WELL No. 4

$$Q = \frac{.8(8.8) 3}{190 + 2.3(60)} = \frac{21.1}{328} = 28.9 \text{ gpm}$$

\* information provided per telecon  
on 8-30-82


$$\begin{array}{r} 499.1 \text{ gpm} \\ (1.11 \text{ cfs}) \end{array}$$

Amount applied for under permit 86-7120 is 1.04 cfs  
1.11 cfs is greater than 1.04 cfs ∴ allow 1.04 cfs.  
PER PERMIT.

RECORDED

# System Diagram showing distance from wells and storage tank

Information provided by Larry Lindstrom P.E.  
8-30-82



Note! Friction loss in 10" pipe is very small and does not reduce capacity determination significantly.

## Conclusion:

Additional information provided by Larry Lindstrom P.E. shows that the system as installed by the City of Genesee does have the capacity to supply the amount of water as applied for under permits 86-7103 and 86-7120 therefore the licenses under these rights should be issued for 0.78 cfs and 1.04 cfs respectively.

CONVERSATION MEMORANDUM

DATE 8-30-82

FILE 86-7103 & 86-7120

NAME OF PARTY

Jerry Lindstrom

EMPLOYEE

John Johnson

PH. 746-2661

RE:

The above called in reference  
to my letter of 7-27-82.

He provided me the following  
information for the second permit (86-7120)

Length to tank from the well = 800'  
Tank height 64'

pressure of system 60 psi (both rights)

size of pump 24 H.P.

tank capacity 29'0" x 64'

If there is any questions after  
reviewing the above information  
the above can be reached at  
746-2661

MICROFILMED



State of Idaho

## DEPARTMENT OF WATER RESOURCES

STATE OFFICE, 450 W. State Street, Boise, Idaho

JOHN V. EVANS

Governor

A. KENNETH DUNN

Director

Mailing address:  
Statehouse  
Boise, Idaho 83720  
(208) 334-4440

July 27, 1982

RE: Permit Nos. 86-7103 and 86-7120

Larry W. Lindstrom, P.E.  
Richard Wyatt Engineering Inc.  
101 Thain Road  
Lewiston, ID 83501

746-2661

Dear Mr. Lindstrom:

Thank you for sending the additional information concerning the well capacities for the City of Genesee covered under Water Permits Nos. 86-7103 and 86-7120.

After reviewing said information the Department is prepared to issue a license on both permits based upon capacity of this system. However, first we need to know: length of pipe to storage tanks, height of storage tanks and pressure maintained by the system and the size of pump motor installed on the well drilled in 1980.

Your cooperation and assistance on this matter has been a big help and is appreciated. If you have any questions please let me know.

Sincerely,

JIM JOHNSON  
Water Distribution Supervisor

JJ:kw

RECEIVED

# **richard wyatt engineering inc**

July 1, 1982

State of Idaho  
Department of Water Resources  
State Office  
450 W. State Street  
Boise, ID 83720

Attention: Jim Johnson  
Water Distribution Supervisor

Subject: Permit No. 86-7120  
Permit No. 86-7103

Dear Mr. Johnson:

This is in response to our telephone conversation regarding my May 28, 1982, letter in reference to the two applications submitted by the City of Genesee concerning the designated amount of water to be used by permit versus the amount that was applied for on the application.

I am enclosing some backup data that was completed in 1974 when the City hired a consultant to review the water and sewer system for the City of Genesee. Within the contents of that engineering report, please note that on page 5 the four existing water wells have a total yield of 465 gpm, reference Permit No. 86-7120, application for water usage in the amount of 1.04 cfs of water.

A new well was drilled in 1980, reference Permit No. 86-7103. The application applied for 0.78 cfs of water. Enclosed please find the inspection diary notes for the testing of this particular well. Please note that the last test was run at 450 gpm for a period of one hour, and had a total draw down of 118 feet. As indicated in the inspection diary notes, page 43, the flow meter was checked for accuracy and found to be reading on the low side. For example, the gauge showed a 340 gpm when, in fact, the yield was at 450 gallons per minute. Using this same ratio, when the gauge was showing 450 gpm, the pumping rate would have been 595 gallons per minute.

**consulting  
engineers**

208 / 746-2661  
101 THAIN ROAD

LEWISTON, IDAHO 83501

Jim Johnson  
State of Idaho  
July 1, 1982  
Page Two

May the enclosed information substantiate the applied for amount of 1.04 cfs on Permit No. 86-7120, and .78 cfs for Permit No. 86-7103.

Please advise, based upon this information, when these permits can be changed to correspond with the applied amount. If you should need any additional information, please contact me.

Sincerely,

R W ENGINEERING, INC.



Larry W. Lindstrom, P.E.

LWL:g  
Enclosures

cc: City of Genesee  
File: 1002-6

SECTION II - THE WATER SYSTEM

(See Accompanying Map of Water System Dated June 30, 1973)

A. THE EXISTING WATER SYSTEM.

(1) Water Supply.

Water is supplied to the City from 4 wells as follows:-

| Well                | Location & Description                                                                                                                                                 | Discharge  |
|---------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|
| Old City Well No. 1 | Old Pumping Station @ Laurel & Chestnut<br>180 - 190 Feet Deep. 7½ H.P. Turbine.                                                                                       | 55 G.P.M.  |
| Old City Well No. 2 | Old Pumping Station @ Laurel & Chestnut.<br>180 - 190 Feet Deep. 15 H.P. Turbine.                                                                                      | 160 G.P.M. |
| New City Well No. 3 | New Pumping Station on East Side of Old<br>Pumping Station. 12" Hole x 160 Feet<br>Deep. 20 H.P. Turbine. Tested to 275 GPM<br>With 25' Drawdown When Drilled 12/4/63. | 200 G.P.M. |
| Luedke Well.....    | Just off of Road to Cemetery East of the<br>City. Reported 190' Deep. 3 H.P. Pump.<br>Purchased by City from John Luedke to<br>Supplement Supply.                      | 50 G.P.M.  |

Total Supply With All Pumps Operating .....

465 G.P.M.

MICROFILMED

CONVERSATION MEMORANDUM

DATE 6-8-82

FILE 86-7103 & 86-7120

NAME OF PARTY LARRY W. LINDSTROM

EMPLOYEE Jim Johnson

RE: Per telecon w/ Larry, he will be  
sending the pump tests for the well under  
86-7103 - AND The Total Lift under permit  
86-7120. IN ORDER FOR US TO DETERMINE CAPACITY  
OF THE SYSTEM.

These files should be called  
up on June 25, 1982

RECEIVED

JUN 7 1982

Department of Water Resources

## richard wyatt engineering inc

May 28, 1982

State of Idaho  
Department of Water Resources  
State Office  
450 West State Street  
Boise, ID 83720

Attention: Jim Johnson  
Water Distribution Supervisor

Subject: Permit No. 86-7120  
Permit No. 86-7103

Dear Mr. Johnson:

In reference to the amount of water that can be recognized as beneficially used under Idaho law, you have designated 0.68 cfs of water for Permit No. 86-7120. The application was in the amount of 1.04 cfs of water.


Under Permit No. 86-7103, the amount of water that can be recognized as beneficially used under Idaho law is 0.31 cfs of water. The application applied for 0.78 cfs of water.

In each case, the application for permit, and what is presently being used for beneficial use, is the difference for the amount of water projected for a 20 year growth period. The City of Genesee does not wish to establish a fixed amount under its present use should the system continue to grow. The amount in each permit establishes a fixed amount of water to be used, which would prohibit any additional water usage for future growth.

Please advise if these permits should be adjusted to the upper limit as shown on the original applications for the City's total water usage.

Sincerely,

R W ENGINEERING, INC.

  
Larry W. Lindstrom, P.E.

LWL:g

cc: City of Genesee  
File: 1002-6

**consulting  
engineers**

208 / 746-2661  
101 THAIN ROAD

LEWISTON, IDAHO 83501



State of Idaho

## DEPARTMENT OF WATER RESOURCES

STATE OFFICE, 450 W. State Street, Boise, Idaho

JOHN V. EVANS

Governor

A. KENNETH DUNN

Director

Mailing address:  
Statehouse  
Boise, Idaho 83720  
(208) 334-4440

May 12, 1982

RE: Permit No. 86-7120

City of Genesee  
P.O. Box 38  
Genesee, ID 83832

Gentlemen:

A representative of this Department has made an examination of the works covered by your Permit No. 86-7120, and has found the following:

Amount of water that can be recognized as beneficially used under  
Idaho law: 0.68 cfs Source: groundwater

The maximum quantity diverted shall not exceed n/a acre feet  
per year.

Point(s) of diversion: NW $\frac{1}{4}$ SE $\frac{1}{4}$ , Sec. 13; (3 points)SW $\frac{1}{4}$ NE $\frac{1}{4}$ , Sec. 14; Twp.  
37N, Rge. 5W, Latah County

Beneficial use: Municipal use within the city limits of Genesee

Priority date established: March 2, 1981

Conditions (if any):

If you do not concur with these findings please contact us within 10 days, otherwise a water license will be issued as set forth above.

Sincerely,

JIM JOHNSON  
Water Distribution Supervisor

JJ:kw

MICROFILMED

RECEIVED

State of Idaho  
DEPARTMENT OF WATER RESOURCES  
FIELD REPORT

MAY 3 1982

Department of Water Resources

86-7120

Permit No.

## CONTACT WITH PERMIT HOLDER

DATE

INITIALS

REMARKS

☐ Appointment letter mailed:☐ Telephone call made:

(List Telephone No. used)

☐ Appointment scheduled for:

(Date, time, location)

## EXAMINATION

Date 4-6-82Accompanied by Bob L. LUEKETotal Q measured allow 1.04  
0.68 cfs

If source is surface water, estimate total flow of source

Methods of measurement

Meters

Meets Permit requirements?

Yes

## Measurement calculations:

Pump #1 11276 gpm  
#3 220 gpm  
#4 10 gpm  
306 gpm306 gpm  
448.86" pipe @ 40 PSI  
0.68 cfs capacity  
see calculation check in file

| WELL/DIVERSION* NO. | HP  | MOTOR MAKE   | MOTOR SERIAL NO. | PUMP MAKE | PUMP SERIAL NO. | MEASURING DEVICE TYPE | CONDITION OF MEAS. DEV. | REMARKS            |
|---------------------|-----|--------------|------------------|-----------|-----------------|-----------------------|-------------------------|--------------------|
| 1                   | 7.5 | Westinghouse | 1050524          | Pomona    | #1 P11504       | Hershey               | good                    | Aug. Ford 305 12-8 |
| 2                   | 15  | "            | 6536             | "         | N1485           | "                     | "                       | "                  |
| 3                   | 20  | Fairbanks    | F451254          | Fairbanks | P24522          | Hershey               | "                       | "                  |
| 4                   | 3   | GE           | 6K2156638        | Pomona    | A-922           |                       |                         |                    |

## System Description

4 Wells #1-4 with pumps & pipeline to 250,000 gal & 300,000 gal storage tanks  
then gravity flow to low areas and 3 booster pumps for higher areas

\*Code with map on reverse side. Disregard code if only one.

## RECOMMENDED AMOUNTS

Irrigation requirement =

AFA/Acre

USE

Q (cfs)

V (bfa)

FROM

TO

Municipal  
per permit

0.68

N/A

1-1

12-31

1.04

See Calculation  
check

1.04

Total

0.68

Remarks 1,365 @ present - All during #5 summer.

#1 - 4" x 190'  
#2 - 6" x 190' } Per R. Luedtke  
#3 - 6" x 120'  
#4 - 4" x 120'

Mean PSI = 40

60 See conversation  
memo of 8-30-82  
5-13-82

MICROFILMED

Contract of


28/2/7  
28-9-1

Recommended Amendments:

[illegible]

Point(s) of diversion: NW 34, Sec 13, SW 1/4, NE 1/4, T 37N, 36E

(104) (3075)



→ 6" main delivery system (except as noted)

Well  
Reservoir  
Booster

(Include distance from pump to measuring device, if applicable.)

## SCHEMATIC DIAGRAM OF SYSTEM

182 57  
 172 47  
 162 37  
 152 27 14  
 142 17 14  
 132 7 14  
 122 14  
 112 14  
 102 14  
 92 14  
 82 14  
 72 14  
 62 14  
 52 14  
 42 14  
 32 14  
 22 14  
 12 14  
 2 14

**DECEMBER 1997**

MAP (Attach Aerial Photo)

St. Pond

Creek

35

36

34

2758

2758

95

2727

3

86-7120

10

11

12

Creek

300,000 gal  
Reservoir

250,000 gal  
Reservoir

St Marys  
Cem

St Johns  
Cemetery

GENESSEE

Boaters

Cow

1223

15

95

PACIFIC

14

13

2751

2650

4

Sewage  
Disposal

NORTHERN

Creek

22

2648

Stock  
Pond

23

2700

24

RESERVATION

STATE OF IDAHO

DEPARTMENT OF WATER RESOURCES  
Northern Region

JOHN V. EVANS  
Governor  
A. KENNETH DUNN  
Director

4055 Government Way  
Coeur d'Alene, ID 83814  
(208) 667-6454

August 18, 1981

POOR QUALITY ORIGINAL

City of Genessee  
P. O. Box 38  
Genessee, Id. 83832

RE: 86-7120

Gentlemen:

We acknowledge receipt of your statement of completion of water development and use for the above-referenced permit.

Before a license can be issued, a field examination must be made by a representative of this Department. We do not know at this time when he will be able to conduct the examination, however, the examiner will try to contact you at the time he makes the examination so that you may show him the system. If you will not be available to show the system, please provide this office with the name and address of someone who will be able to do so. Your permit will remain valid until the examination is made.

If you have any questions concerning the field examination, please contact this office. Please be sure to use the above-referenced permit number in all future correspondence concerning this examination.

Very truly yours,

TOM D. KING  
Senior Water Resource Agent

K/pms

IDWR - State Office

MICROFILMED

# DEPARTMENT OF WATER RESOURCES

The Idaho Department of Water Resources will consider this card as a statement that the permit holder(s) has completed development to the extent shown below of Permit No. 86-7120.

Name(s) of Permit Holder: CITY OF GENESEE

Post Office Address: P. O. BOX 38

GENESEE, ID

Tel. No. 285-1421  
285-1314

Source of Water: Wells - Five

Extent of Use: ☒ Domestic 335 (number of households)  
☐ Stockwater (number and type of stock)  
☐ Irrigation (acres)  
☐ Other

Measuring Device: Required? ☒ Yes ☐ No Installed? ☒ Yes ☐ No

Access Port: Required? ☐ Yes ☒ No Installed? ☐ Yes ☒ No

The above information is a true statement of the extent to which the above numbered permit has been developed.

7/28/81  
Date

Robert L. Luecke  
Signature of Permit Holder  
*(City of Genesee)*

*Office of General Services*  
*P.O. Box 98*  
*Genesee, Idaho 83832*



IDAHO DEPARTMENT OF WATER RESOURCES  
STATEHOUSE  
BOISE, IDAHO 83720

MICROFILMED

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES

---

STATEHOUSE  
BOISE, IDAHO 83720  
(208) 334-4440

CITY OF GENESEE  
P.O. BOX 38  
GENESEE, ID 83832

MAY 20, 1981

RE: PERMIT NO. 86-7120

DEAR PERMIT HOLDER:

ENCLOSED IS A COPY OF YOUR APPROVED APPLICATION FOR PERMIT. WE DIRECT YOUR ATTENTION TO THE CONDITIONS OF APPROVAL ON THE FOURTH PAGE.

BE SURE TO NOTE THE SPECIAL CONDITION REQUIRING YOU TO INSTALL A MEASURING DEVICE, OR AN ACCESS PORT TO PROVIDE FOR THE INSTALLATION OF MEASURING EQUIPMENT BY THE DEPARTMENT. ENCLOSED PLEASE FIND A LIST OF MEASURING DEVICE OPTIONS, AND SPECIFICATIONS FOR THE INSTALLATION OF THE ACCESS PORT.

WE HAVE ENCLOSED A FORM ENTITLED "MAKING PROOF OF BENEFICIAL USE". PLEASE READ THE INSTRUCTIONS CAREFULLY SINCE YOU MUST TAKE FURTHER ACTION TO DEVELOP THIS PERMIT INTO A LICENSE.

SINCERELY,

DAVID R. TUTHILL, JR., P.E.  
SUPERVISOR, WATER ALLOCATION SECTION

ENCLOSURE

State of Idaho  
Department of Water Resources

APPLICATION FOR PERMIT ANALYSIS SHEET

INITIAL REVIEW BY: LB

APPLICATION NUMBER: 86-7120

CHECK:

- ☒ Source.  
☒ Point of diversion.  
☒ County.  
☒ Description of diverting works.  
☒ Time required for beneficial use of water.  
☒ Place of use or acres irrigated.  
☒ Map.  
☒ Signature.  
☒ Fee.  
☒ Yes ☒ No Field check required.  
☐ Yes ☒ No Critical groundwater area.  
☐ Yes ☒ No Request dam safety information. Sent by: \_\_\_\_\_ Date: \_\_\_\_\_  
☒ Yes ☒ No\* In form to receipt.

Field check by: \_\_\_\_\_

Date: \_\_\_\_\_

Comments: \_\_\_\_\_

\*REQUEST THE FOLLOWING ADDITIONAL INFORMATION FROM THE APPLICANT: \_\_\_\_\_

SEND COPIES TO:

- ☒ Idaho State Health Department.  
☐ Idaho Fish and Game Department.  
☐ Idaho Department of Lands.  
☐ U.S. Bureau of Land Management.  
☐ U.S. Forest Service.  
☐ Other \_\_\_\_\_

Copies sent by: me Date: 3/27/81

PROCESSING:

- ☐ Yes ☐ No Platted by: \_\_\_\_\_ Map No. \_\_\_\_\_  
☐ Yes ☐ No Other rights on same place of use. \_\_\_\_\_

- ☒ Yes ☐ No\* In form for advertising.  
Final date for protests: 4/20/81 ✓  
☐ Yes ☒ No Protests received. If yes, record information on 4th page of application.

FINAL REGIONAL PROCESSING REVIEW:

- ☒ Affidavit of publication received. Date: 4/10/81 ✓  
☒ Application published correctly. If not, record action taken: \_\_\_\_\_  
☒ Fee amount, receipt date & number, recorded on application.  
☒ Publication dates and paper, recorded on application.  
☒ Protests, dates, withdrawal, etc., recorded on application.  
☒ Recommendation & initial, recorded on application.  
☐ Yes ☒ No Measuring device required.  
☐ Yes ☒ No Access port required.  
☐ Yes ☒ No Will water be delivered by watermaster? If yes, what district? \_\_\_\_\_  
3/27/81 Date of priority recommended.  
Special conditions of approval or cover letter. \_\_\_\_\_

MICROFILMED

By: RAH Date: 4/20/81

STATE OFFICE REVIEW:

- return receipt w/ cover letter  
SLW/L03 OK, 04  
☐ See attached sheet for more information.

By: Tejpa Date: 5/3/81

10-000000-00000000

86-7120-

CITY OF GENESEE

P.O. BOX 38, GENESEE, ID 83832

Source: GROUNDWATER

Date Filed: 03/18/1981

Amount: 1.04 CFS

Diversion Point: SWNE Sec 14 T 37N R 05W NWSE Sec 13 T 37N R 05W,  
LATAH Co.

Use: MUNICIPAL (1.04 CFS) from 01/01 to 12/31

Diversion Means: 4 WELLS, PUMP AND PIPELINE.

Place of Use: Located within City Limits of Genesee

MICROFILMED

March 27, 1981

Mr. Russ Schaff  
Divn. of Environment  
P. O. Drawer B  
Lewiston, Id. 83501

Re: 86-7120

Dear Mr. Schaff:

Enclosed is a recent filing that may be of interest to your agency.

Sincerely,

ROBERT G. HAYNES, P.E.  
Regional Supervisor

pms

Enc.



## richard wyatt engineering inc

March 16, 1981

State of Idaho  
Department of Water Resources  
Suite No. 1  
4055 Government Way  
Coeur d'Alene, ID 83814

Attention: Tom D. King  
Senior Water Resource Agent

Subject: Form 202 Application  
City of Genesee, Idaho

Dear Mr. King:

In followup of your letter dated March 3, 1981, we are transmitting the application and filing fee requested. The application is for a permit to appropriate ground waters from the four existing City of Genesee water system ground water wells.

If there are any questions concerning the application, please let me know.

Sincerely,

R W ENGINEERING, INC.

Clifton Morey, P.E.

CM:g  
Enclosures

File: 0259-6

cc: City of Genesee

MICROFILMED

**consulting  
engineers**

208 / 746-2661  
101 THAIN ROAD

LEWISTON, IDAHO 83501

RECEIVED

MAR 18 1981

Department of Water Resources  
Northern District Office

| INVOICE NO.                                                                | DESCRIPTION                                                                                                                | GROSS AMOUNT | DISCOUNTS<br>AND DEDUCTIONS | NET AMOUNT   |
|----------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------|-----------------------------|--------------|
| <div data-bbox="266 176 495 787" data-label="Text"> <p>RECEIVED</p> </div> | <p>application for water rights on 4<br/>existing wells<br/>#1, #2 &amp; #3 all<br/>SWNE, Sec. 14<br/>#4 NWSE, Sec. 13</p> |              |                             | <p>65.00</p> |

VI ©S

ATTACHED CHECK IS IN FULL PAYMENT OF ITEMS LISTED ABOVE. PLEASE DETACH THIS STATEMENT BEFORE DEPOSITING.

**SEWER AND WATER FUND WARRANT - CITY OF GENESEE, GENESEE, IDAHO 83832**

March 3, 1981

Mr. George Wilson, Mayor  
City of Genesee  
P. O. Box 38  
Genesee, Idaho 83832

Dear Mr. Wilson:

We are returning the City of Genesee's four Application for Permits and Check No. 92-108 in the amount of \$70.00. If you wish to refile these applications, the fee will be \$150.00.

In your best interest, I have taken the liberty of combining the four Application for Permits into one application with a filing fee of \$65.00. If you wish to file this application which I have prepared, Please do the following:

1. Indicate the location of the wells on the map provided.
2. List the well sizes in the blank spaces I have left in Item No. 10.
3. Check the application to insure accuracy.
4. Sign and return it to this office with a \$65.00 filing fee.

If you have any questions, please contact me at this office.

Sincerely,

TOM D. KING  
Senior Water Resource Agent

TDK/pms

Enc. - Check  
Applications (5)

Identification No. \_\_\_\_\_

Application No. \_\_\_\_\_

**STATE OF IDAHO**  
**DEPARTMENT OF WATER RESOURCES**  
**APPLICATION FOR PERMIT**

**To Appropriate the Public Waters of the State of Idaho**  
(TYPE OR PRINT IN INK)

1. Name of applicant City of Genesee Phone: (208) 285-1421  
post office address P. O. Box 38, Genesee, Idaho 83832
2. Source of water supply Existing City Well which is a tributary of N/A
3. a. Location of point of diversion is NW  $\frac{1}{4}$  of SE  $\frac{1}{4}$  of Section 13 Township 37N  
Range 5 W B.M. Latah County; additional points of diversion if any: N/A
- b. If water is not consumed, it will be discharged into -- at a point in --  $\frac{1}{4}$  of --  $\frac{1}{4}$  of Section -- Township -- Range -- B.M. --
4. Water will be used for the following purposes:  
Amount 0.11 for Municipal purpose from Jan. 1 to Dec. 31 (both dates inclusive)  
(cfs or acre-feet per annum)  
Amount        for        purpose from        to        (both dates inclusive)  
(cfs or acre-feet per annum)  
Amount        for        purpose from        to        (both dates inclusive)  
(cfs or acre-feet per annum)
5. Total quantity to be appropriated:  
a. 0.11 cubic feet per second and/or  
b.        acre feet per annum.
6. Proposed diverting works:  
a. Description of ditches, flumes, pumps, headgates, etc. 3 H.P. pump pumping directly into municipal water system.
- b. Height of storage dam -- feet, active reservoir capacity -- acre feet; total reservoir capacity -- acre feet, materials used in storage dam: --  
Period of year during which storage will occur -- to -- inclusive.  
(Mo. Day) (Mo. Day)
- c. Proposed well diameter is        inches; proposed depth of well is 190 feet.
7. a. Time required for the completion of the works and application of the water to the proposed beneficial use is N/A years. Existing Well.  
b. Estimated construction cost is \$ N/A.
8. Description of proposed uses:  
a. If water is **not** for irrigation: Municipal for City of Genesee  
(1) Give the place of use of water: --  $\frac{1}{4}$  of --  $\frac{1}{4}$  of Section -- Township --  
Range -- B.M.         
(2) Amount of power to be generated: -- hp under -- feet of head.  
(3) List number of each kind of livestock to be watered N/A
- (4) Name of municipality to be served City of Genesee, or number of families to be supplied with domestic water N/A.
- (5) If water is to be used for other purposes describe: N/A

b. If water is for irrigation, indicate acreage in each subdivision in the tabulation below: (See Remarks)

| TWP. | RANGE | SEC. | NE 1/4 |        |        |        | NW 1/4 |        |        |        | SW 1/4 |        |        |        | SE 1/4 |        |        |        | TOTALS |
|------|-------|------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
|      |       |      | NE 1/4 | NW 1/4 | SW 1/4 | SE 1/4 | NE 1/4 | NW 1/4 | SW 1/4 | SE 1/4 | NE 1/4 | NW 1/4 | SW 1/4 | SE 1/4 | NE 1/4 | NW 1/4 | SW 1/4 | SE 1/4 |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |

Total number of acres to be irrigated \_\_\_\_\_

c. Describe any other water rights used for the same purposes as described above. \_\_\_\_\_

This is one of two existing wells outside the city limits, in addition to three inside the present city limits.

9. a. Who owns the property at the point of diversion City of Genesee


b. Who owns the land to be irrigated or place of use N/A

c. If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing N/A

10. Remarks Reference Item 8b, the City of Genesee is a typical Northern Idaho small community and has within its corporate limits a number of small lot acreages, which are presently undeveloped and are now being used for pasture land. This area is minimal, however, some city water has been provided to these areas in the past for irrigation purposes. It is estimated that the total acreage being served on a periodic basis is no more than 50 acres.

MICROFILMED

11. Map of proposed project: show clearly the proposed point of diversion, place of use, section number, township and range number.



Scale: 2 inches equal 1 mile

BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

George Wilson  
(Applicant)

Mayor George Wilson  
City of Genesee, Idaho

Received by PA Date 3/2/81 Time 1:00 PM  
Preliminary check by \_\_\_\_\_ Fee \$ \_\_\_\_\_  
Receipted by \_\_\_\_\_ Date \_\_\_\_\_  
Publication prepared by \_\_\_\_\_ Date \_\_\_\_\_  
Published in \_\_\_\_\_  
Publication dates \_\_\_\_\_  
Publication approved \_\_\_\_\_ Date \_\_\_\_\_  
Priority reduced to \_\_\_\_\_ Reason \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
Protests filed by: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
Copies of protests forwarded by \_\_\_\_\_  
Hearing held by \_\_\_\_\_ Date \_\_\_\_\_  
Recommended for approval denial by \_\_\_\_\_

#### ACTION OF THE DIRECTOR, DEPARTMENT OF WATER RESOURCES

This is to certify that I have examined Application for Permit to appropriate the public waters of the State of Idaho No. \_\_\_\_\_, and said application is hereby \_\_\_\_\_.

1. Approval of said application is subject to the following limitations and conditions:

- a. SUBJECT TO ALL PRIOR WATER RIGHTS.
- b. Proof of construction of works and application of water to beneficial use shall be submitted on or before \_\_\_\_\_, 19\_\_\_\_.
- c. Other: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

2. Denial of said application is for the following reasons: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Witness my hand this \_\_\_\_\_ day of \_\_\_\_\_ 19\_\_\_\_.

\_\_\_\_\_  
Director

Identification No. \_\_\_\_\_


Application No. \_\_\_\_\_

**STATE OF IDAHO**  
**DEPARTMENT OF WATER RESOURCES**  
**APPLICATION FOR PERMIT**

**To Appropriate the Public Waters of the State of Idaho**  
(TYPE OR PRINT IN INK)

1. Name of applicant City of Genesee Phone: (208) 285-1421  
post office address P.O. Box 38, Genesee, Idaho 83832
2. Source of water supply Existing City Well which is a tributary of N/A
3. a. Location of point of diversion is SW  $\frac{1}{4}$  of NE  $\frac{1}{4}$  of Section 14 Township 37N  
Range 5W B.M. Latah County; additional points of diversion if any: N/A
- b. If water is not consumed, it will be discharged into -- at a point in --  $\frac{1}{4}$   
of --  $\frac{1}{4}$  of Section -- Township -- Range -- B.M. --
4. Water will be used for the following purposes:  
Amount 0.12 CFS for Municipal purpose from Jan. 1 to Dec. 31 (both dates inclusive)  
(cfs or acre-feet per annum)  
Amount        for        purpose from        to        (both dates inclusive)  
(cfs or acre-feet per annum)  
Amount        for        purpose from        to        (both dates inclusive)  
(cfs or acre-feet per annum)
5. Total quantity to be appropriated:  
a. 0.12 CFS cubic feet per second and/or  
b.        acre feet per annum.
6. Proposed diverting works:  
a. Description of ditches, flumes, pumps, headgates, etc. 7½ H.P. Turbine pump pumping directly into municipal water system.
- b. Height of storage dam -- feet, active reservoir capacity -- acre feet; total reservoir capacity -- acre feet, materials used in storage dam: --  
Period of year during which storage will occur -- to -- inclusive.  
(Mo. Day) (Mo. Day)
- c. Proposed well diameter is        inches; proposed depth of well is 190 feet.
7. a. Time required for the completion of the works and application of the water to the proposed beneficial use is N/A years. Existing Well  
b. Estimated construction cost is \$ N/A
8. Description of proposed uses:  
a. If water is **not** for irrigation: Municipal for City of Genesee.  
(1) Give the place of use of water: --  $\frac{1}{4}$  of --  $\frac{1}{4}$  of Section -- Township --  
Range -- B.M.         
(2) Amount of power to be generated: -- hp under -- feet of head.  
(3) List number of each kind of livestock to be watered N/A  
(4) Name of municipality to be served City of Genesee, or number of families to be supplied with domestic water N/A  
(5) If water is to be used for other purposes describe: N/A

11. Map of proposed project: show clearly the proposed point of diversion, place of use, section number, township and range number.



Scale: 2 inches equal 1 mile

BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

*George Wilson*  
(Applicant)  
Mayor George Wilson  
City of Genesee, Idaho

b. If water is for irrigation, indicate acreage in each subdivision in the tabulation below: (See Remarks)

[illegible]

Total number of acres to be irrigated \_\_\_\_\_

c. Describe any other water rights used for the same purposes as described above. This is one of three existing wells within the present city limits in addition to two outside the city limits.

9. a. Who owns the property at the point of diversion City of Genesee

b. Who owns the land to be irrigated or place of use N/A

c. If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing N/A

10. Remarks Reference Item 8b, the City of Genesee is a typical Northern Idaho small  
community and has within its corporate limits a number of small lot acreages,  
which are presently undeveloped and are now being used for pasture land. This  
area is minimal, however, some city water has been provided to these areas in  
the past for irrigation purposes. It is estimated that the total acreage  
being served on a periodic basis is no more than 50 acres.

**RECEIVED**

Received by        Date 7/21 Time 6:00 PM

Preliminary check by        Fee \$       

Received by        Date       

Publication prepared by        Date       

Published in       

Publication dates       

Publication approved        Date       

Priority reduced to        Reason       

Protests filed by:       

Copies of protests forwarded by       

Hearing held by        Date       

Recommended for approval denial by       

#### ACTION OF THE DIRECTOR, DEPARTMENT OF WATER RESOURCES

This is to certify that I have examined Application for Permit to appropriate the public waters of the State of Idaho No.       , and said application is hereby       .

1. Approval of said application is subject to the following limitations and conditions:

a. SUBJECT TO ALL PRIOR WATER RIGHTS.

b. Proof of construction of works and application of water to beneficial use shall be submitted on or before       , 19      .

c. Other:       

2. Denial of said application is for the following reasons:       

Witness my hand this        day of        19      .

        
Director

RECEIVED

Identification No. \_\_\_\_\_

Application No. \_\_\_\_\_

**STATE OF IDAHO**  
**DEPARTMENT OF WATER RESOURCES**  
**APPLICATION FOR PERMIT**

**To Appropriate the Public Waters of the State of Idaho**  
(TYPE OR PRINT IN INK)

1. Name of applicant City of Genesee Phone: (208) 285-1421  
post office address P. O. Box 38, Genesee, Idaho 83832

2. Source of water supply Existing City Well which is a tributary of N/A

3. a. Location of point of diversion is SW  $\frac{1}{4}$  of NE  $\frac{1}{4}$  of Section 14 Township 37N  
Range 5 W B.M. Latah County; additional points of diversion if any: \_\_\_\_\_

b. If water is not consumed, it will be discharged into -- at a point in --  $\frac{1}{4}$   
of --  $\frac{1}{4}$  of Section -- Township -- Range -- B.M. --

4. Water will be used for the following purposes:

Amount 0.36 CFS for Municipal purpose from Jan. 1 to Dec. 31 (both dates inclusive)  
(cfs or acre-feet per annum)

Amount \_\_\_\_\_ for \_\_\_\_\_ purpose from \_\_\_\_\_ to \_\_\_\_\_ (both dates inclusive)  
(cfs or acre-feet per annum)

Amount \_\_\_\_\_ for \_\_\_\_\_ purpose from \_\_\_\_\_ to \_\_\_\_\_ (both dates inclusive)  
(cfs or acre-feet per annum)

5. Total quantity to be appropriated:

a. 0.36 CFS cubic feet per second and/or

b. \_\_\_\_\_ acre feet per annum.

6. Proposed diverting works:

a. Description of ditches, flumes, pumps, headgates, etc. \_\_\_\_\_  
15 H.P. Turbine pump pumping directly into municipal water system.

b. Height of storage dam -- feet, active reservoir capacity -- acre feet; total reservoir  
capacity -- acre feet, materials used in storage dam: --

Period of year during which storage will occur -- to -- inclusive.  
(Mo. Day) (Mo. Day)

c. Proposed well diameter is \_\_\_\_\_ inches; proposed depth of well is 190 feet.

7. a. Time required for the completion of the works and application of the water to the proposed beneficial use  
is N/A years. Existing Well.

b. Estimated construction cost is \$ N/A

8. Description of proposed uses:

a. If water is **not** for irrigation: Municipal for City of Genesee.

(1) Give the place of use of water: --  $\frac{1}{4}$  of --  $\frac{1}{4}$  of Section -- Township --  
Range -- B.M. --

(2) Amount of power to be generated: -- hp under -- feet of head.

(3) List number of each kind of livestock to be watered N/A

(4) Name of municipality to be served City of Genesee, or number of families to be  
supplied with domestic water N/A

(5) If water is to be used for other purposes describe: N/A

b. If water is for irrigation, indicate acreage in each subdivision in the tabulation below: (See Remarks)

| TWP. | RANGE | SEC. | NE 1/4 |        |        |        | NW 1/4 |        |        |        | SW 1/4 |        |        |        | SE 1/4 |        |        |        | TOTALS |
|------|-------|------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
|      |       |      | NE 1/4 | NW 1/4 | SW 1/4 | SE 1/4 | NE 1/4 | NW 1/4 | SW 1/4 | SE 1/4 | NE 1/4 | NW 1/4 | SW 1/4 | SE 1/4 | NE 1/4 | NW 1/4 | SW 1/4 | SE 1/4 |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |
|      |       |      |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |        |

Total number of acres to be irrigated \_\_\_\_\_


c. Describe any other water rights used for the same purposes as described above. \_\_\_\_\_  
This is one of three existing wells within the present city limits, in addition to two outside the city limits.

9. a. Who owns the property at the point of diversion \_\_\_\_\_ City of Genesee  
b. Who owns the land to be irrigated or place of use \_\_\_\_\_ N/A  
c. If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing \_\_\_\_\_ N/A

10. Remarks \_\_\_\_\_ Reference Item 8b, the City of Genesee is a typical Northern Idaho small community and has within its corporate limits a number of small lot acreages, which are presently undeveloped and are now being used for pasture land. This area is minimal, however, some city water has been provided to these areas in the past for irrigation purposes. It is estimated that the total acreage being served on a periodic basis is no more than 50 acres.

MICROFILMED

11. Map of proposed project: show clearly the proposed point of diversion, place of use, section number, township and range number.



Scale: 2 inches equal 1 mile

BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

George Wilson  
(Applicant)  
Mayor George Wilson  
City of Genesee, Idaho

Received by PA Date 3/2/51 Time 1:00 PM (P.M.)  
Preliminary check by \_\_\_\_\_ Fee \$ 145  
Received by \_\_\_\_\_ Date \_\_\_\_\_  
Publication prepared by \_\_\_\_\_ Date \_\_\_\_\_  
Published in \_\_\_\_\_  
Publication dates \_\_\_\_\_  
Publication approved \_\_\_\_\_ Date \_\_\_\_\_  
Priority reduced to \_\_\_\_\_ Reason \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
Protests filed by: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
Copies of protests forwarded by \_\_\_\_\_  
Hearing held by \_\_\_\_\_ Date \_\_\_\_\_  
Recommended for approval denial by \_\_\_\_\_

#### ACTION OF THE DIRECTOR, DEPARTMENT OF WATER RESOURCES

This is to certify that I have examined Application for Permit to appropriate the public waters of the State of Idaho No. \_\_\_\_\_, and said application is hereby \_\_\_\_\_.

1. Approval of said application is subject to the following limitations and conditions:

- a. SUBJECT TO ALL PRIOR WATER RIGHTS.
- b. Proof of construction of works and application of water to beneficial use shall be submitted on or before \_\_\_\_\_, 19\_\_\_\_.
- c. Other: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

2. Denial of said application is for the following reasons: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Witness my hand this \_\_\_\_\_ day of \_\_\_\_\_ 19\_\_\_\_.

\_\_\_\_\_  
Director

110233

Identification No. \_\_\_\_\_

Application No. \_\_\_\_\_

**STATE OF IDAHO**  
**DEPARTMENT OF WATER RESOURCES**  
**APPLICATION FOR PERMIT**

**To Appropriate the Public Waters of the State of Idaho**  
(TYPE OR PRINT IN INK)

1. Name of applicant City of Genesee Phone: (208) 285-1421  
post office address P. O. Box 38, Genesee, Idaho 83832
2. Source of water supply Existing City Well which is a tributary of N/A
3. a. Location of point of diversion is SW  $\frac{1}{4}$  of NE  $\frac{1}{4}$  of Section 14 Township 37 N  
Range 5 W B.M. Latah County; additional points of diversion if any: N/A
- b. If water is not consumed, it will be discharged into -- at a point in --  $\frac{1}{4}$  of --  $\frac{1}{4}$  of Section -- Township -- Range -- B.M. --
4. Water will be used for the following purposes:  
Amount 0.45 CFS for Municipal purpose from Jan. 1 to Dec. 31 (both dates inclusive)  
(cfs or acre-feet per annum)  
Amount            for            purpose from            to            (both dates inclusive)  
(cfs or acre-feet per annum)  
Amount            for            purpose from            to            (both dates inclusive)  
(cfs or acre-feet per annum)
5. Total quantity to be appropriated:  
a. 0.45 CFS cubic feet per second and/or  
b.            acre feet per annum.
6. Proposed diverting works:  
a. Description of ditches, flumes, pumps, headgates, etc. 20 H.P. Turbine pump pumping directly into municipal water system.
- b. Height of storage dam -- feet, active reservoir capacity -- acre feet; total reservoir capacity -- acre feet, materials used in storage dam: --  
Period of year during which storage will occur -- to -- inclusive.  
(Mo. Day) (Mo. Day)
- c. Proposed well diameter is 12 inches; proposed depth of well is 160 feet.
7. a. Time required for the completion of the works and application of the water to the proposed beneficial use is N/A years. Existing Well  
b. Estimated construction cost is \$ N/A
8. Description of proposed uses: Municipal for City of Genesee  
a. If water is **not** for irrigation:  
(1) Give the place of use of water: --  $\frac{1}{4}$  of --  $\frac{1}{4}$  of Section -- Township --  
Range -- B.M.             
(2) Amount of power to be generated: -- hp under -- feet of head.  
(3) List number of each kind of livestock to be watered N/A  
(4) Name of municipality to be served City of Genesee, or number of families to be supplied with domestic water N/A  
(5) If water is to be used for other purposes describe: N/A

MICROFILMED

(See Remarks)

[illegible]

Total number of acres to be irrigated\_\_\_\_\_

c. Describe any other water rights used for the same purposes as described above.

This is one of three existing wells within the present city limits, in addition to two outside the city limits.


9. a. Who owns the property at the point of diversion City of Genesee

b. Who owns the land to be irrigated or place of use N/A

c. If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing N/A

10. Remarks Reference Item 8b, the City of Genesee is a typical Northern Idaho small  
community and has within its corporate limits a number of small lot acreages,  
which are presently undeveloped and are now being used for pasture land. This  
area is minimal, however, some city water has been provided to these areas in  
the past for irrigation purposes. It is estimated that the total acreage  
being served on a periodic basis is no more than 50 acres.

11. Map of proposed project: show clearly the proposed point of diversion, place of use, section number, township and range number.



Scale: 2 inches equal 1 mile

BE IT KNOWN that the undersigned hereby makes application for permit to appropriate the public waters of the State of Idaho as herein set forth.

George Wilson  
(Applicant)

Mayor George Wilson  
City of Genesee, Idaho

Received by     Date 3/2/81 Time 1:00 PM (stacy)  
Preliminary check by     Fee \$ 115  
Receipted by     Date      
Publication prepared by     Date      
Published in      
Publication dates      
Publication approved     Date      
Priority reduced to     Reason      
     
     
     
Protests filed by:      
     
     
Copies of protests forwarded by      
Hearing held by     Date      
Recommended for approval denial by    

**ACTION OF THE DIRECTOR, DEPARTMENT OF WATER RESOURCES**

This is to certify that I have examined Application for Permit to appropriate the public waters of the State of Idaho No.    , and said application is hereby    .

1. Approval of said application is subject to the following limitations and conditions:

- a. SUBJECT TO ALL PRIOR WATER RIGHTS.
- b. Proof of construction of works and application of water to beneficial use shall be submitted on or before    , 19   .
- c. Other:

2. Denial of said application is for the following reasons:      
     
     
     
     
   

Witness my hand this     day of     19   .

\_\_\_\_\_  
Director

**MICROFILMED**