

State of Idaho
Department of Water Resources

RECOMMENDATION OF WATERMASTER

Application No: Transfer 72541
Water Right No: 36-15710
Applicant Name: Horizon Organic Dairy

Watermaster's Recommendation:

- a) ☐ I do not oppose approval of this application
b) ☒ I do not oppose approval of this application if it is conditioned as follows:


As recommended by reviewer – include magnetic flow meter condition

- c) ☐ I oppose approval of this application(s) for the following reasons:
d) ☒ Additional comment:

Transfer rate of flow should be limited to 0.75 cfs due to combined flow limitations on water right. See recommended conditions and discussion between reviewer and SO.

Dated: June 19, 2006

Water District 130


Cindy J Yenter, Watermaster