

Printed 11/17/2004
Drilling Permit No. 826181
Well Tag No. D0034445
Well ID # 396808
Water Right No.
Receipt # S027089
Approved Date 11/17/2004

**STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
DRILLING PERMIT**

Relationship: Owner/Operator
Name: SOUTHERN IDAHO SOLID WASTE
Address: PO BOX 159
BURLEY ID 83318

Phone: (208) 432-9082

Proposed Well Location: Township 02S, Range 17E, Section 11, SE, NW
COUNTY LINCOLN

Street Address of Well Site: WEST MAGIC ROAD AND SIX MILES OFF HWY 75
SHOSHONE ID

Proposed Use of Well: Other

Well Construction Information:

- A. New Well
- B. Proposed Surface Diameter: 6 Inches. Proposed Depth 250 Feet.
- C. Anticipated Bottom Hole Temperature: 85F and less

Construction Start Date: Nov 18 2004

Anticipated Well Drilling Company: WALKER WATER SYSTEMS INC (No. 15)

Applicant's Signature: _____ Date _____

Title: _____


Well ID # 396808

Well Tag No. D0034445

ACTION OF THE DEPARTMENT OF WATER RESOURCES

This permit is Approved on Wednesday, November 17, 2004.

1. This drilling permit is valid for two (2) months from the approval date for the start of construction and is valid for one (1) year from the approval date for completion of the well unless an extension has been granted.
2. This permit does not constitute an approval of the local Health District or the Idaho Department of Environmental Quality which may be required prior to construction of this well. The local Health District should be contacted for septic tank/drainfield locations. Domestic wells must not be drilled closer than 100 ft. from any drainfield and 50 ft. from any septic tank. Public Water Supply wells must not be drilled closer than 100 ft. from any drainfield or septic tank.
3. The well shall be constructed by a driller currently licensed in the state of Idaho who must maintain a copy of the drilling permit at the drilling site.
4. Approval of this drilling permit does not authorize trespass on the land of another party.
5. This permit does not constitute other local, county, state or federal approvals that may be required for construction of a well.
6. This drilling permit does not represent a right to divert and use the water of the State of Idaho. If the well being drilled is associated with approved water rights(s) use of the well must comply with conditions of said water right(s).
7. If a bottom hole temperature of 85 Degrees F (29.44 oC) or greater is encountered, well construction shall cease and the well driller and the well owner shall contact the Department of Water Resources immediately.
8. Idaho Code, S 55-2201 - 55-2210 requires the applicant and/or its contractors to contact "Dig-line" (Dig-Line is a one-call center for utility notification) not less than 2 working days prior to the start of any excavation for this project. The "Dig-Line " Number for this location is 1-800-342-1585
9. Please be advised that this drilling permit should be considered and treated as a preliminary permit. If you are in disagreement with this preliminary permit you have fourteen (14) days of the service date of this permit to petition the Idaho Department of Water Resources for reconsideration, pursuant to Section 67-5243, Idaho Code.
10. The well tag for the drilling permit/start card shall be securely and permanently attached to the well casing through welding or by the use of four closed end domed stainless steel pop rivets. The tag attachment will be done at the time of completion of the well, and prior to removing the drill rig from the drill site.
11. Domestic uses other than for homes, organization camps, public campgrounds or livestock where the diversion rate and volume does not exceed .04 cfs and 2500 gpd (42-111[B]).



Signature of Authorized Dept Representative

Southern Region Manager

Title