

State of Idaho
Department of Water Resources

RECOMMENDATION OF WATERMASTER

Application No: Transfer 72652 and Amendment of Permit
Water Right No: 36-8550, 36-8738
Applicant Name: City of Heyburn

Watermaster's Recommendation:

- a) ☐ I do not oppose approval of this application
- b) ☒ I do not oppose approval of this application if it is conditioned as follows:
standard WD130 conditions; lockable/controllable and measurement conditions
- c) ☐ I oppose approval of this application(s) for the following reasons:
- d) ☐ Additional comment:

Existing City of Heyburn wells are designated as follows in WMIS (this is a little inconsistent with notes found in the application for transfer)

A0007813	Well #1	measured 2002, 627 gpm
E0007526	Well #2	measured 2002 and 2004, 510 gpm
A0007815	Well #3	measured 2004, 290 gpm

This may not necessarily represent the maximum discharge from each existing pod, however, it does indicate that the system is operating well below the currently authorized combined diversion rate of 9.97 cfs. Therefore, no enlargement is evident with the addition of a point of diversion.

Dated: May 3, 2006

Water District 130


Cindy Yenter, Watermaster