

State of Idaho  
Department of Water Resources

## RECOMMENDATION OF WATERMASTER

Application No: Transfer 72652 and Amendment of Permit  
Water Right No: 36-8550, 36-8738  
Applicant Name: City of Heyburn

Watermaster's Recommendation:

- a) ☐ I do not oppose approval of this application
- b) ☒ I do not oppose approval of this application if it is conditioned as follows:  
standard WD130 conditions; lockable/controllable and measurement conditions
- c) ☐ I oppose approval of this application(s) for the following reasons:
- d) ☐ Additional comment:

Existing City of Heyburn wells are designated as follows in WMIS (this is a little inconsistent with notes found in the application for transfer)

|          |         |                                 |
|----------|---------|---------------------------------|
| A0007813 | Well #1 | measured 2002, 627 gpm          |
| E0007526 | Well #2 | measured 2002 and 2004, 510 gpm |
| A0007815 | Well #3 | measured 2004, 290 gpm          |

This may not necessarily represent the maximum discharge from each existing pod, however, it does indicate that the system is operating well below the currently authorized combined diversion rate of 9.97 cfs. Therefore, no enlargement is evident with the addition of a point of diversion.

Dated: May 3, 2006

Water District 130

  
Cindy Yenter, Watermaster