



SPF Water Engineering, LLC
water resource consultants

RECEIVED

JUN 23 2005

Department of Water Resources RECEIVED

JUN 21 2005

WATER RESOURCES
WESTERN REGION

June 20, 2005

Steve Lester
Idaho Department of Water Resources
2735 Airport Way
Boise, ID 83705

Subject: Proof of Beneficial Use and Beneficial Use Field Report – 63-31354

Dear Steve:

On behalf of the Idaho State Building Authority, I have enclosed Proof of Beneficial Use and Beneficial Use Field Report for permit 63-31354. The permit authorizes diversion of 3.0 cfs of groundwater for cooling purposes at the Idaho Water Center Building. Calculated diversion capacity is 2.45 cfs and measured diversion rate is 2.23 cfs. Recommended diversion volume is 250 acre feet annually.

Please contact me with any questions.

Sincerely,

Terry M. Scanlan, P.E., P.G.

Cc: Vivan Otero-Epley – Idaho State Building Authority
Spencer Shaw – Lemley/3D-I