

M E M O R A N D U M

Date: January 11, 2006
To: Water Right File 79-7089
From: kwalker
Re: License Review

In review of this permit I found that the applicant is on PURPA power sales contract listing provided by PUC. This system is recorded under FERC No. 5865 and is shown to have first provided power on June 20, 1986. They received a 35 year contract to sell the power so expiration date of June 20, 2021, was listed in condition on license for possible Director review at that date. Capacity of system found 22.6 cfs could be diverted, however, the power plant generates more power if the flow is reduced to 16.9 cfs. The system is operated at 16.9 cfs for generation of 651 kw. Amendment of permit needed to complete license since place of use was permitted in Sec. 14 but developed in S13.