

SWI

POD Data

12S 21E 24 SWSWSW

Legal Description	GPS Site ID	Diversion Name	Meas Option	POD
12S 21E 24 SWSWSW	A0006859	12S 21E 24CCC2		900154
Latitude 042:21:34.000 Longitude -113:56:59.000 GPS File				
Comments WELL BEING OVERHAULED				

Reporters

Type	Name / Address	Phone(s)
Owner	CRANNEY, MICHAEL CRANNEY BROTHERS 1310 SOUTH 600 WEST OAKLEY, ID 83346	300-3472 Doug (Fax)
Owner	CRANNEY, MICHAEL CRANNEY BROTHERS CRANNEY BROTHERS RT 1 BOX 44-A OAKLEY, ID 83346	300-3472 Doug (Fax)

PCC Data

Year	Total KWH	PCC Acre-Ft	Qualifier	PCC	PCC Date	Utility	Account Number	Service Number
2002	1587000.00	1452.1	4	1092.89	01/01/2003	IP		3047289188
Comments:						Tracking:	Preferred:	Validated:
							Change Date:	2/3/2005
2003	1376400.00	1203.9	2	1143.26	01/01/2003	IP	2584833941	3047289188
Comments:						Tracking:	Preferred:	Validated:
							Change Date:	2/3/2005
2001	1366560.00	1237.1	4	1104.69	07/11/2001	IP	2584833941	3047289188
Comments:						Tracking:	Preferred:	Validated:
							Change Date:	2/3/2005

PCC Calibration

Date	PCC	Change Date
01/01/2003	1092.89	3/3/2003

Kilowatt-Hour Meter		Condition #1									
Utility	IP	KW	431.44	GPM	2144	PCC	1092.89	PSI	0	Percent	100
Pole No	1687	Descrip									
Meter Mfr	G										
Meter S/N	92551310										
Disk Const	4.8										
Multiplier	120										

Condition #2		Condition #3							
KW	0	GPM	0	PCC	0	PSI	0	Percent	0
Descrip									

Date	PCC	Change Date
01/01/2002	1092.9	

Legal Description	GPS Site ID	Diversion Name	Meas Option	POD
Kilowatt-Hour Meter Utility IP Pole No 1687 Meter Mfr G Meter S/N 92551310 Disk Const 4.8 Multiplier 120	Condition #1 KW 431.44 GPM 2144 PCC 1092.89 PSI 0 Percent 100 Descrip			
	Condition #2 KW 0 GPM 0 PCC PSI 0 Percent 0 Descrip			
	Condition #3 KW 0 GPM 0 PCC PSI 0 Percent 0 Descrip			
Date 07/11/2001 PCC: 1104.69 Change Date: 6/3/2002				
Kilowatt-Hour Meter Utility IP Pole No 1687 Meter Mfr G Meter S/N 92551310 Disk Const 4.8 Multiplier 120	Condition #1 KW 431.44 GPM 2144 PCC 1092.89 PSI 0 Percent 95 Descrip Booster on.			
	Condition #2 KW 345.41 GPM 1263 PCC 1485.29 PSI 50 Percent 5 Descrip 8/2/01			
	Condition #3 KW 0 GPM 0 PCC 0 PSI 0 Percent 0 Descrip			

Water Level Data

Year	Seq	Date	Water Level	Status	Method	Acceptable	USGS Use Codes	Examiner
		6/21/1997	414.7	A		Y	I	USGS
Comments								
Change Date:								

Site Visits

Site Visit Date	Site Examiner	Reason	Change Date:
8/2/2001	JHIGGS	PCC Calibration	8/9/2004
Notes: Couldn't get a measurement in the same spot so measured by the pump. Good measurement. 4 bars, 8x power.			
7/11/2001	JHIGGS	PCC Calibration	3/18/2004
Notes: Very bad reading, lots of turbulence and maybe air. Measured in 3 places but could only get 1 one min. reading that is bad. Booster is on. 3 bars, 8x power.			