

Comment Report

37-8720

1. BALDWIN 7/5/1991 PROTEST

Comment: UNTIMELY PROTEST RECEIVED FROM USDI-BLM, PO BOX 28, SHOSHONE, ID 83352 ON 7-1-1991. PLEASE CONSIDER THEM A CORRESPONDENT IN ALL MATTERS CONCERNING THIS WATER RIGHT.

2. MILLER 6/25/1992 SUPPLEMENTAL IRRIGATION

Comment: This right is for supplemental irrigation to be used in conjunction with Big Wood Canal Company rights.

3. ZIMMERMA 5/19/1993 MORATORIUM EXEMPTION

Comment: This amended permit falls within the acceptable parameters of the Eastern Snake River Plain Moratorium. P/D & POU OWNERSHIP Point of diversion is owned by the applicant. Place of use located within S31, T06S, R15E is owned by applicant. Place of use located within S05, T07S, R15E is owned by State of Idaho and leased by applicant. AMENDED PERMIT This permit has been amended to change the point of diversion and place of use. CORPORATE OFFICERS Corporate officers for Faulkner Land & Livestock Co. are John Faulkner, president; Mike Faulkner, secretary/treasurer; Mark Faulkner, director; Jack Faulkner, director.

4. ZIMMERMA 6/17/1993 DIVERSION DESCRIPTION

Comment: Drilling permit no. 37-93-C-0089-000. Proposed driller Eaton Drilling & Pump. Proposed well to have 16 in casing by 350 ft deep.

5. VAULT 7/15/1993 Proof of Beneficial Use Rcvd

Comment: Proof of Beneficial Use Rcvd

6. kwalker 8/19/2002 Place of Use

Comment: In review of this field exam I found lands on map in SWNW, S4, T7S, R15E that examiner had not included in his recommendation. This land only turns out to be 1 acre but should be included per discussion with examiner. Also, lands in S1/2NE1/4, Sec. 5 overlap with right 37-8005B. ArcView reads those lands as I described but in license, claim and recommendation in SRBA they are listed in N1/2NE1/4, Sec. 5. Will edit to make legals consistent with 37-8005B so right holder does not get the idea that he has rights for entire NE1/4. Lands recommended in GL4, NWNW, Sec. 5 are covered under 37-8702. No irrigation for those lands under this right. Created GIS shape for this proposed license which does not match acreage determined by examiner but covers same lands. Rounded acres to whole numbers for license.

7. kwalker 8/20/2002 Capacity of Well

Comment: The well under this right was measured by Steelhead Engineering on 6/27/1997. They found the capacity to be 5.83 cfs which is what examiner has recommended as capacity of well. See measurement in file 37-8702.

8. kwalker 10/7/2002 Rate of Diversion

Comment: I have recommended a reduced rate of diversion on the proposed license due to an indepth review of the water rights from this well. It is recommended that we allow 2.99 cfs for this license so that the 3 rights allowed on the 324 acre ppu do not exceed the capacity of the well.