

MEMORANDUM

Date: September 23, 2005
To: Water Right File 29-8080
From: Shelley Keen *SK*
Re: Annual Volume

The field examiner recommended an annual volume of 104.4 af, which is 1.2 af for each of the 87 homes. I added 2.8 af for the clubhouse for a total of 107.2 af. The 2.8 af figure is 2500 gallons per day over 365 days.