



State of Idaho

DEPARTMENT OF WATER RESOURCES

322 East Front Street, P.O. Box 83720, Boise, ID 83720-0098

Phone: (208) 287-4800 Fax: (208) 287-6700 Web Site: www.idwr.idaho.gov

DIRK KEMPTHORNE
Governor

KARL J. DREHER
Director

August 4, 2005

TERRY SCANLAN
SPF WATER ENGINEERING LLC
600 EAST RIVER PARK LN STE 105
BOISE ID 83706

RE: Water-Bearing Zone for Permit No. 63-12530

Dear Terry:

In response to your request to deviate from the water-bearing zone of 380 to 430 ft. below ground surface described on Permit No. 63-12530, IDWR finds that the change is acceptable without filing an application to amend the permit. The change you have proposed – diverting from a water-bearing zone of 350 to 400 feet below ground surface -- is not a “substantial change” to the proposed method of diverting water, and it is not likely to interfere with the ability of other ground water users to pump water from their wells. Please note that the well drilling permit issued by IDWR may have additional limitations.

If you have any questions, please call me at 208-287-4947, or email me at shelley.keen@idwr.idaho.gov.

Sincerely,

Shelley W. Keen
Water Rights Supervisor