

Comment Report

96-9182

1. dball 6/16/2004 11:46:57 AM Comment Letter Notes

Comment: WHO: IDF&G Mary Terra-Berns

RESPONSE: Conditional Recommendation

DATE RECEIVED: 6/16/2004

Applicant should obtain necessary encroachment permits from IDL before installing diversion structures, lines, etc. in state waters.

Recommend installation beneath lake, river or stream during low water periods.

Dug materials should be sidecast to only one side and the bottom contour and substrate restored. Water intakes should be screened with maximum mesh size of 0.25 inches to prevent entrainment of fish; approach velocities not to exceed 0.5 ft per second to prevent losses of juvenile fish.

For additional information see letter in file.

2. E Retelle 7/19/2004 Permit review

Comment: Recommend approval as suggested by IDWR Northern.