

State of Idaho
Department of Water Resources

RECOMMENDATION OF WATERMASTER

Application No: 71604 (amended)
Water right No: 36-4157F, et al
Applicant Name: William Millenkamp

Watermaster's Recommendation:

- a) ☐ I do not oppose approval of this application
- b) ☒ I do not oppose approval of this application if it is conditioned as follows:

(115) mag meters with data loggers
combined rate and volume limits

Applicant must show that existing domestic well is not connected to the
stockwater distribution system.


Mitigation required

- c) ☐ I oppose approval of this application(s) for the following reasons:
- d) ☒ Additional comment:

Existing wells D0016540 and D0016729 are reporting to WD130.

Dated: June 15, 2005

Water District 130


Cindy J Yenter, Watermaster