

Comment Report

67-7293

1. e retelle 1/12/2005 PoDs

Comment: PoD is the dam for the reservoir, then there are 3 re-diversions 1) pump south of the reservoir on Scott Creek 2) Outlet into ditches on the east side of the reservoir 3) pump at the NW corner of the reservoir

2. eretelle 1/12/2005 overlap

Comment: all the rights mentioned by the field examiner as overlapping except 7784 were found to be from different PoDs, differnt ownership and not used on the same lands.

3. e retelle 1/13/2005 diversion capacity

Comment: FE reports 1.62 cfs for the rediversion pump in Scott Creek, 3 cfs for the reservoir diversion through the mainline system and 9-10 cfs for the reservoir outlet. The spillway was observed flowing at 15 cfs. From these values, I estimated a total system capacity (all 3 diversions) of appx 14 cfs.