

Comment Report

22-13155

1. dcarlson 8/18/2004 Field Report Narrative

Comment: 2 well to a pump house with 4 pumps, pressure tanks and control system
113 home subdivision with a pump house and lawn/park.

40 HP US Electrical motors

15 HP US Electrical motors

7.5 HP US Electrical motor

7.5 HP US Electrical motor

four motors and pumps interconnected to work when needed.

114 units X 1.2 AF= 136.8 AF/A

Darby Creek water right gets cut early in the season.

2. E Retelle 9/22/2004 number of homes

Comment: Field exam said 113 homes and 1 pumphouse. The plat showed 115 lots. I spoke to Dave Carlson who said there were only 10 homes up so far and the rest of the lots stubbed in. Out of the 115 lots on the new plat, 3 are not for homes. We agreed the license should be for 112 homes, not 113. The pumphouse is not allowed. The annual volume was adjusted accordingly.