

Comment Report

23-7065

1. dcarlson 7/25/2003 Field Report Narrative

Comment: two springs have pipes driven into them. open discharge residence fill water jugs to be use at their residences for drinking and household use. GW license 23-7098 is a well piped to each lot.

2. kwalker 1/27/2004 License Review

Comment: Permit was approved for domestic use in 35-45 homes. Examiner recommended use for 49 homes. I have reduced that number to 45 pursuant to the permit.

Also revisited the volume to be licensed. Examiner recommended 0.2 afa. I determined that 45 homes at 0.6 af (normal amount for in-house use) per year was 27.0 afa. I also found that the diversion rate limits the volume to 7.9 afa when using the 200 days recommended by the examiner. Recommend licensing for 7.9 afa.