

Comment Report

29-8020

1. dcarlson 3/24/2003 Field Report Narrative

Comment: well/pump to sprinkler system. 125 hp motor/pump GE or us motors motor aurora verti-line pump 5K626BXHIA.

2. eretelle 12/23/2004 flow rate

Comment: The field examiner used 170 sprinkler heads x 5gpm to get 1.89 cfs. This rule of thumb estimate seemed low compared to the permitted and proof of beneficial use flow of 3.66 cfs. There was not enough information to use the horsepower equation with much accuracy. Dave Carlson, the field examiner, told me by telephone that he attempted to get a sonic meter reading at the time but was unable. He said he used the bucket/stopwatch method on a number of the nozzles and they produced 5 gpm on average. I am relying on his recommendation.

3. eretelle 1/10/2005 amendment

Comment: PoD is in different section, PoU slight changes also P49 if not amended

4. VAULT 1/11/1994 Proof of Beneficial Use Rcvd

Comment: Proof of Beneficial Use Rcvd