

State of Idaho
Department of Water Resources

RECOMMENDATION OF WATERMASTER


Application No: Transfer 71183
Water Right No: 37-7252A, 7252B, 7677
Applicant Name: Glanbia Foods

Watermaster's Recommendation:

- a) ☐ I do not oppose approval of this application
- b) ☒ I do not oppose approval of this application if it is conditioned as follows:
- (R05) Watermaster jurisdiction, Water District 130
(131) Measuring device required or waiver obtained
No additional points of diversion to be constructed
- c) ☐ I oppose approval of this application for the following reasons:
- d) ☒ Additional comment:
- All six existing wells have flow meters installed. Four of these meters have been tested by WD130 and found accurate to within $\pm 5\%$ of a standard meter; condition 131 is therefore appropriate and a waiver will be recommended. The other two wells are not usually used. I agree with Allen that the position of one of these two wells in an adjacent model cell should not jeopardize approval of the transfer.

Dated: May 28, 2004

Water District 130


Cindy J Yeater, Watermaster