

State of Idaho
Department of Water Resources

RECOMMENDATION OF WATERMASTER

Application No: Transfer 71184
Water Right No: 37-7051, 8903
Applicant Name: Glanbia Foods

Watermaster's Recommendation:

- a) ☐ I do not oppose approval of this application
- b) ☒ I do not oppose approval of this application if it is conditioned as follows:

(R05) Watermaster jurisdiction, Water District 130
(131) Measuring device required or waiver obtained
No additional points of diversion to be constructed

- c) ☐ I oppose approval of this application for the following reasons:

- d) ☒ Additional comment:

The two existing plant wells are equipped with a common flow meter. Water District 130 has tested this meter and found that it is operating within prescribed accuracy limits; condition 131 is therefore appropriate. This facility has petitioned to join the North Snake GWD for mitigation purposes.

Dated: May 28, 2004

Water District 130


Cindy J Yenter, Watermaster